




FILL IN AND SIGN WITH INK

960296

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT



Portland, Maine, .....

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

24 APR 11 1996

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location: 40 Shepherd Ln (L #3) Use of Building: 1-Flr No. Stories: New Building Existing "
Name and address of owner of appliance: Kasprzak, Inc.
Installer's name and address: Kevin's Burner Service, P.O. Box 653 WARRIOR, ME 04087 Telephone: 247-3041
General Description of Work: Oil Fired - Forced hot water heating system
To install: Oil Fired - Forced hot water heating system

IF HEATER OR POWER BOILER

Location of appliance: Basement Any burnable material in floor surface or beneath? No
If so, how protected? Kind of fuel? 18"
Minimum distance to burnable material, from top of appliance or casing top of furnace: 18"
From top of smoke pipe: 18" From front of appliance: 18" From sides or back of appliance: 18"
Size of chimney flue: 6" Other connections to same flue: Yes - chimney
If gas fired, how vented? Rated maximum demand per hour: 105,000 BTU
Will sufficient fresh air be supplied to the appliance to insure proper and safe combustion? Yes

IF OIL BURNER

Name and type of burner: Beckett Labelled by underwriters' laboratories? Yes
Will operator be always in attendance? No Does oil supply line feed from top or bottom of tank? Bottom
Type of floor beneath burner: concrete Size of vent pipe: 1 1/4"
Location of oil storage: Basement Number and capacity of tanks: 1-275
Low water shut off: Yes Make: safeguard No.
Will all tanks be more than five feet from any flame? Yes How many tanks enclosed? none
Total capacity of any existing storage tanks for furnace burners: 1-275

IF COOKING APPLIANCE

Location of appliance: Any burnable material in floor surface or beneath?
If so, how protected? Height of Legs, if any
Skirting at bottom of appliance? Distance to combustible material from top of appliance?
From front of appliance: From sides and back: From top of smokepipe
Size of chimney flue: Other connections to same flue
Is hood to be provided? Forced or gravity?
If gas fired, how vented? Rated maximum demand per hour

MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

KEVIN MCCLINTIC Vector Oil Burner #1121 Permit Fee: 2500
COST OF WORK: 5,000.00
Amount of fee enclosed?

APPROVED:

Will there be in charge of the above installation a person competent to see that the State and City requirements regarding thereto are observed?
1. Burner and piping installed in accordance with the code.
2. Name & Label on Burner.
3. Return to main vent.
4. High limit control.
5. Main control valve.
6. Low limit control.
7. High limit control.
8. Low limit control.
9. Piping in accordance with code.
10. High limit control.
11. Piping in accordance with code.
12. Capacity of tank.
13. Oil gauge.
14. Oil gauge.
15. Oil gauge.
16. Oil gauge.
17. Oil gauge.
18. Oil gauge.
19. Oil gauge.
20. Oil gauge.

CS 30C INSPECTION FILE APPLICANTS ASSESSORS COPY

Signature of Installer