



... Fire Protection by Computer Design

DEAN & ALLYN, INC.  
PO BOX 709  
116 LEWISTON ROAD  
GRAY, MAINE 04039  
207-657-5646

Job Name : 1704 WASHINGTON AVE  
Drawing :  
Location : 1704 WASHINGTON AVE PORTLAND MAINE  
Remote Area : ONE  
Contract : C111036  
Data File : 1704 WASHINGTON.WXF

HYDRAULIC DESIGN INFORMATION SHEET

Name - 1704 WASHINGTON AVE. Date - 10-7-11  
 Location - 1704 WASHINGTON AVE PORTLAND MAINE  
 Building - System No. - ONE  
 Contractor - DEAN AND ALLYN, INC. Contract No. - C111036  
 Calculated By - H. KING Drawing No. - 1 OF 1  
 Construction: (X) Combustible ( ) Non-Combustible Ceiling Height 8'  
 OCCUPANCY - RESIDENCE

S Type of Calculation: ( )NFPA 13 Residential ( )NFPA 13R (X)NFPA 13D  
 Y Number of Sprinklers Flowing: ( )1 (X)2 ( )4 ( )  
 S ( )Other  
 T ( )Specific Ruling Made by Date  
 E  
 M Listed Flow at Start Point - 12 Gpm System Type  
 Listed Pres. at Start Point - 9 Psi (X) Wet ( ) Dry  
 D MAXIMUM LISTED SPACING 14 x 14 ( ) Deluge ( ) PreAction  
 E Domestic Flow Added - Gpm Sprinkler or Nozzle  
 S Additional Flow Added - Gpm Make VIKING Model FREEDOM  
 I Elevation at Highest Outlet - 24' Feet Size K-Factor 4.0  
 G Note:CUSHION 19.9 PSI Temperature Rating 155  
 N

Calculation Gpm Required 24.7 Psi Required 33.8 PUMP  
 Summary C-Factor Used: Overhead 120 Underground 120

W Water Flow Test: Pump Data: Tank or Reservoir:  
 A Date of Test - Rated Cap. Cap.  
 T Time of Test - @ Psi Elev.  
 E Static (Psi) - 55 Elev.  
 R Residual (Psi) - 50 Other Well  
 Flow (Gpm) - 50 Proof Flow Gpm  
 S Elevation - 0

P Location: GOULDS PUMP CURVE

P  
 L Source of Information:  
 Y

## Fittings Used Summary

DEAN & ALLYN, INC.  
1704 WASHINGTON AVE

Page 2  
Date 10-7-11

Fitting Legend		1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
Abbrev.	Name																				
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65					
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121

## Units Summary

Diameter Units           Inches  
Length Units             Feet  
Flow Units                US Gallons per Minute  
Pressure Units           Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with \*. The fittings marked with a \* show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a \* will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

DEAN & ALLYN, INC.  
1704 WASHINGTON AVE

Page 3  
Date 10-7-11

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
1	24.0	4	9.0	na	12.0	0.06	196	9.0
2	24.0	4	10.13	na	12.73	0.06	196	9.0
10	16.0		12.97	na				
11	16.0		14.16	na				
12	16.0		15.09	na				
13	16.0		15.51	na				
14	16.0		16.9	na				
15	8.0		22.58	na				
TR	8.0		25.7	na				
FF	0.0		32.44	na				
PMP	0.0		33.79	na				

The maximum velocity is 9.18 and it occurs in the pipe between nodes 13 and 14

Final Calculations - Hazen-Williams

DEAN & ALLYN, INC.  
1704 WASHINGTON AVE

Page 4  
Date 10-7-11

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
1	12.00	1.049	1E	2.0	8.000	9.000			K Factor = 4.00	
to		120.0		0.0	2.000	3.465				
10	12.0	0.0506		0.0	10.000	0.506			Vel = 4.45	
	0.0									
	12.00					12.971			K Factor = 3.33	
2	12.73	1.049	1E	2.0	8.000	10.127			K Factor = 4.00	
to		120.0		0.0	2.000	3.465				
11	12.73	0.0564		0.0	10.000	0.564			Vel = 4.73	
	0.0									
	12.73					14.156			K Factor = 3.38	
10	12.00	1.049	1E	2.0	30.000	12.971				
to		120.0	2T	10.0	12.000	0.0				
12	12.0	0.0506		0.0	42.000	2.124			Vel = 4.45	
	0.0									
	12.00					15.095			K Factor = 3.09	
11	12.73	1.049	1T	5.0	19.000	14.156				
to		120.0		0.0	5.000	0.0				
13	12.73	0.0564		0.0	24.000	1.354			Vel = 4.73	
	0.0									
	12.73					15.510			K Factor = 3.23	
12	12.00	1.049		0.0	8.200	15.095				
to		120.0		0.0	0.0	0.0				
13	12.0	0.0506		0.0	8.200	0.415			Vel = 4.45	
13	12.73	1.049	1T	5.0	2.200	15.510				
to		120.0		0.0	5.000	0.0				
14	24.73	0.1926		0.0	7.200	1.387			Vel = 9.18	
14	0.0	1.049	1E	2.0	9.500	16.897				
to		120.0		0.0	2.000	3.465				
15	24.73	0.1927		0.0	11.500	2.216			Vel = 9.18	
15	0.0	1.049	2T	10.0	6.200	22.578				
to		120.0		0.0	10.000	0.0				
TR	24.73	0.1927		0.0	16.200	3.122			Vel = 9.18	
TR	0.0	1.049	2S	10.0	7.000	25.700				
to		120.0		0.0	10.000	3.465				
FF	24.73	0.1927		0.0	17.000	3.276			Vel = 9.18	
FF	0.0	1.049	2E	4.0	3.000	32.441				
to		120.0		0.0	4.000	0.0				
PMP	24.73	0.1927		0.0	7.000	1.349			Vel = 9.18	
	0.0									
	24.73					33.790			K Factor = 4.25	

# Water Supply Curve (C)

DEAN & ALLYN, INC.  
1704 WASHINGTON AVE

Page 5  
Date 10-7-11

City Water Supply:  
C1 - Static Pressure : 55  
C2 - Residual Pressure: 50  
C2 - Residual Flow : 50

Demand:  
D1 - Elevation : 10.394  
D2 - System Flow : 24.729  
D2 - System Pressure : 33.790  
Hose ( Demand ) :  
D3 - System Demand : 24.729  
Safety Margin : 19.851

