DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



This is to certify that

BERRY LISA M

Located at

23 SHEPHERD LN

PERMIT ID: 2014-02284

ISSUE DATE: 10/21/2014

CBL: 351 B001001

has permission to For the construction of a 26'-8" x 30'-0" garage addition with a mudroom and bonus room over the new, attached one- (1-) car garage.

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

N/A

/s/ Tammy Munson

Fire Official

Building Official

THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY THERE IS A PENALTY FOR REMOVING THIS CARD

Approved Property Use - Zoning single family

Building Inspections

Fire Department

BUILDING PERMIT INSPECTION PROCEDURES Please call 874-8703 (ONLY)

or email: buildinginspections@portlandmaine.gov

Check the Status or Schedule an Inspection On-Line at http://www.portlandmaine.gov/planning/permitstatus.asp

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.
- Permits expire in 6 months. If the project is not started or ceases for 6 months.
- If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.
- Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.

REQUIRED INSPECTIONS:

Setbacks and Footings Prior to Pouring Close-in Plumbing/Framing Electrical - Residential Final Inspection

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

PERMIT ID: 2014-02284 **Located at:** 23 SHEPHERD LN **CBL:** 351 B001001

Date Applied For: City of Portland, Maine - Building or Use Permit 10/01/2014 2014-02284 351 B001001 389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716 Proposed Use: Proposed Project Description: Same: Single Family For the construction of a 26'-8" x 30'-0" garage addition with a mudroom and bonus room over the new, attached one- (1-) car garage. **Dept:** Zoning **Status:** Approved w/Conditions Reviewer: Marge Schmuckal **Approval Date:** 10/09/2014

Permit No:

CBL:

Ok to Issue:

Conditions:

Note:

- 1) This property shall remain a single family dwelling. Any change of use shall require a separate permit application for review and approval. The area above the garage is NOT being approved for any kitchen facilities or a separate living unit.
- 2) As discussed during the review process, the property must be clearly identified prior to pouring concrete and compliance with the required setbacks must be established. Due to the proximity of the setbacks of the proposed addition, it may be required to be located by a surveyor.
- 3) This is NOT an approval for an additional dwelling unit. You SHALL NOT add any additional kitchen equipment including, but not limited to items such as stoyes, microwaves, refrigerators, or kitchen sinks, etc. Without special approvals.

Reviewer: Tammy Munson 10/21/2014 **Dept:** Building **Status:** Approved w/Conditions **Approval Date:** Note: Ok to Issue:

Conditions:

- 1) Hardwired photoelectric interconnected battery backup smoke detectors shall be installed in all bedrooms, protecting the bedrooms, and on every level.
 - The same is required for existing buildings, where permanent wiring is feasible; or at the very least battery operated smoke detectors are required. Verification of this will be upon inspection.
- 2) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.
- 3) If there are 4 or more risers, a handrail is required on one side of stairs with ends returned if the guardrail does not meet graspability dimensions. A 2x4 is not considered graspable. One handrail is required on ramps exceed a pitch of 12:1.
- 4) When over 30" above a floor or grade, guardrail openings shall be less than 4", stairail openings shall be less than 4-3/8", and at the open side of a stair, less than 6" is allowed at the triangle of the tread/riser at the bottom rail.
- 5) Egress size windows are required (1) in each bedroom per IRC Sec. R310
- 6) Carbon Monoxide (CO) alarms shall be installed in each area within or giving access to bedrooms. That detection must be powered by the electrical service (plug-in or hardwired) in the building and battery.
- 7) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.

Located at: 23 SHEPHERD LN CBL: 351 B001001 **PERMIT ID:** 2014-02284