44 Dole

The boiler is hung on a stud wall c
cement wall with the factory bracket.
The vent kit is Factory pipe within a pipe
vent Through the stud and cement wall
18" off the Ground and 18" under Deck
as per Code.

RESURGAM. CITY OF PORTLAND, MAINE
Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 01/02/15