

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that

PETERSON JEFFREY L & LAURA M
PETERSON/Robert Dunham

Located at

39 ALLISON AVE

PERMIT ID: 2013-01030 **ISSUE DATE:** 06/26/2013 **CBL:** 353 A018001

has permission to **Upgrading basement to family/play room -framing, insulate and sheet rock** provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Chris Pirone

/s/ Tammy Munson

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

Single Family Dwelling

Building Inspections

Use Group: Single Family Dwelling
Type: ENTIRE

Fire Department

Classification: One or Two Family Dwellings
ENTIRE
2009 NFPA

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

REQUIRED INSPECTIONS:

Close-in Plumbing/Framing

Final Inspection

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No: 2013-01030	Date Applied For: 05/21/2013	CBL: 353 A018001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Same: Single Family	Proposed Project Description: Upgrading basement to family/play room -framing, insulate and sheet rock			
Dept: Zoning Status: Approved w/Conditions Reviewer: Marge Schmuckal Approval Date: 05/22/2013				
Note:				Ok to Issue: <input checked="" type="checkbox"/>
Conditions:				
1) This is NOT an approval for an additional dwelling unit. You SHALL NOT add any additional kitchen equipment including, but not limited to items such as stoves, microwaves, refrigerators, or kitchen sinks, etc. Without special approvals.				
2) This property shall remain a single family dwelling. Any change of use shall require a separate permit application for review and approval. The area in the basement is considered to be a family room and not a separate dwelling unit to be rented out or used separately from the principal dwelling unit.				
Dept: Building Status: Approved w/Conditions Reviewer: Tammy Munson Approval Date: 06/26/2013				
Note:				Ok to Issue: <input checked="" type="checkbox"/>
Conditions:				
1) Hardwired photoelectric interconnected battery backup smoke alarms shall be installed in each bedroom, protecting the bedrooms, and on every level.				
2) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.				
3) Permit approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.				
Dept: Fire Status: Approved w/Conditions Reviewer: Chris Pirone Approval Date: 06/23/2013				
Note:				Ok to Issue: <input checked="" type="checkbox"/>
Conditions:				
1) Contractor states renovation of the existing structure plus addition will not exceed 50% of the completed structure.				
2) A sprinkler system is recommended but not required based on the following: Plans indicate the addition will not exceed _50_% of the total completed structure.				
3) Required only in areas affected by the renovation: Single-station photoelectric smoke alarms are required. They shall be powered by the building's electrical service with battery backup and shall be interconnected. Smoke alarms shall be installed in the following locations: (1) All sleeping rooms (2) Outside each separate sleeping area, in the immediate vicinity of the sleeping rooms (3) On each level of the dwelling unit, including basements. Single-station Carbon Monoxide (CO) alarms are required. They shall be powered by the building's electrical service with battery backup and shall be interconnected. CO alarms shall be installed in the following locations: (1) Outside each separate dwelling unit sleeping area in the immediate vicinity of the bedrooms (2) On every occupiable level of the dwelling unit, including basements, excluding attics and crawl spaces				
4) All construction shall comply with City Code Chapter 10.				