



... Fire Protection by Computer Design

DEAN AND ALLYN, INC.
116 LEWISTON ROAD
GRAY MAINE 04039
207 657 5646

Job Name : SURFACE CREATIONS OF MAINE
Building :
Location : 25 RICE STREET PORTLAND MAINE
System : ONE
Contract : C141204
Data File : 25 RICE STREET.WXF

Hydraulic Design Information Sheet

Name - SURFACE CREATIONS OF MAINE Date - 4-14-14
 Location - 25 RICE STREET PORTLAND MAINE
 Building - System No. - ONE
 Contractor - DEAN AND ALLYN, INC. Contract No. - C141204
 Calculated By - H. KING Drawing No. - 1 OF 1
 Construction: () Combustible (X) Non-Combustible Ceiling Height - 12'
 Occupancy - GRANITE COUNTERTOP SHOW ROOM AND OFFICES

S (X) NFPA 13 () Lt. Haz. Ord.Haz.Gp. (X) 1 () 2 () 3 () Ex.Haz.
 Y () NFPA 231 () NFPA 231C () Figure Curve
 S Other
 T Specific Ruling Made By Date
 E
 M Area of Sprinkler Operation - 1950 System Type Sprinkler/Nozzle
 Density - .15 () Wet Make RELIABLE
 D Area Per Sprinkler - 120 (X) Dry Model F1FR
 E Elevation at Highest Outlet - 13 () Deluge Size 1/2"
 S Hose Allowance - Inside - () Preaction K-Factor 5.6
 I Rack Sprinkler Allowance - () Other Temp.Rat.155
 G Hose Allowance - Outside - 250
 N Note CUSHION 9.3 PSI

Calculation Flow Required - 707.9 Press Required - 69.0 CITY
 Summary C-Factor Used: 100 Overhead 140 Underground

W Water Flow Test: Pump Data: Tank or Reservoir:
 A Date of Test - 9-7-2011 Cap. -
 T Time of Test - Rated Cap.- Elev.-
 E Static Press - 79 @ Press -
 R Residual Press - 77 Elev. - Well
 Flow - 1331 Proof Flow
 S Elevation - 0
 U
 P Location - RICE STREET AT RIVERSIDE IND. PARKWAY
 P
 L Source of Information - PWD RECORDS
 Y

C Commodity Class Location
 O Storage Ht. Area Aisle W.
 M Storage Method: Solid Piled % Palletized % Rack
 M
 () Single Row () Conven. Pallet () Auto. Storage () Encap.
 S R () Double Row () Slave Pallet () Solid Shelf () Non
 T A () Mult. Row () Open Shelf
 O C
 R K Flue Spacing Clearance:Storage to Ceiling
 A Longitudinal Transverse
 G
 E Horizontal Barriers Provided:

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/UL	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	***** Notes *****
01A to 01	18.00 18.0	1.049 100 0.1499	2E 1T 3.427 3.568 0.0	2.000 6.423 8.423	10.332 -0.433 1.263		K Factor = 5.60 Vel = 6.68
	0.0 18.00					11.162	K Factor = 5.39
01 to 02	18.03 18.03	1.049 100 0.1555	0.0 0.0 0.0	8.700 0.0 8.700	11.162 0.0 1.353		K Factor @ node 01 Vel = 6.69
02 to 03	19.06 37.09	1.38 100 0.1504	0.0 0.0 0.0	7.500 0.0 7.500	12.515 0.0 1.128		K Factor @ node 01 Vel = 7.96
03 to 04	19.90 56.99	1.38 100 0.3328	0.0 0.0 0.0	8.500 0.0 8.500	13.643 0.0 2.829		K Factor @ node 01 Vel = 12.22
04 to 05	21.87 78.86	1.61 100 0.2865	0.0 0.0 0.0	8.200 0.0 8.200	16.472 0.0 2.349		K Factor @ node 01 Vel = 12.43
05 to 06	23.37 102.23	1.61 100 0.4631	0.0 0.0 0.0	12.000 0.0 12.000	18.821 0.0 5.557		K Factor @ node 01 Vel = 16.11
06 to 77	26.60 128.83	1.61 100 0.7103	0.0 0.0 0.0	12.000 0.0 12.000	24.378 0.0 8.524		K Factor @ node 01 Vel = 20.30
	0.0 128.83					32.902	K Factor = 22.46
07 to 08	18.00 18.0	1.049 100 0.1501	0.0 0.0 0.0	8.700 0.0 8.700	11.162 0.0 1.306		K Factor @ node 01 Vel = 6.68
08 to 09	19.02 37.02	1.38 100 0.1498	0.0 0.0 0.0	12.000 0.0 12.000	12.468 0.0 1.798		K Factor @ node 01 Vel = 7.94
09 to 10	20.35 57.37	1.38 100 0.3369	2E 0.0 0.0	4.141 4.282 17.282	13.000 0.0 5.822		K Factor @ node 01 Vel = 12.31
10 to 11	24.15 81.52	1.61 100 0.3047	0.0 0.0 0.0	12.000 0.0 12.000	20.088 0.0 3.656		K Factor @ node 01 Vel = 12.85
11 to 53	26.25 107.77	1.61 100 0.5105	1T 0.0 0.0	5.71 5.710 23.710	18.000 0.0 12.104		K Factor @ node 01 Vel = 16.98
	0.0 107.77					35.848	K Factor = 18.00

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/UL	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	***** Notes *****
12 to 13	18.87	1.049 100	0.0	10.800	12.268		K Factor @ node 01
		0.1637	0.0	0.0	0.0		Vel = 7.01
13 to 14	18.87	1.38 100	0.0	12.000	14.036		K Factor @ node 01
		0.1653	0.0	0.0	0.0		Vel = 8.38
14 to 15	20.18	1.38 100	0.0	10.000	16.020		K Factor @ node 01
		0.3731	0.0	0.0	0.0		Vel = 13.00
15 to 16	23.94	1.61 100	0.0	12.000	19.751		K Factor @ node 01
		0.3259	0.0	0.0	0.0		Vel = 13.33
16 to 51	26.21	1.61 100	1T	5.71	18.000	23.662	K Factor @ node 01
		0.5371	0.0	5.710	0.0		Vel = 17.46
	0.0 110.77					36.397	K Factor = 18.36
17 to 18	18.82	1.049 100	0.0	10.800	12.206		K Factor @ node 01
		0.1630	0.0	0.0	0.0		Vel = 6.99
18 to 19	20.14	1.38 100	0.0	12.000	13.966		K Factor @ node 01
		0.1646	0.0	0.0	0.0		Vel = 8.36
19 to 20	21.51	1.38 100	0.0	10.000	15.941		K Factor @ node 01
		0.3714	0.0	0.0	0.0		Vel = 12.97
20 to 21	23.88	1.61 100	0.0	12.000	19.655		K Factor @ node 01
		0.3244	0.0	0.0	0.0		Vel = 13.29
21 to 50	26.15	1.61 100	1T	5.71	18.000	23.548	K Factor @ node 01
		0.5347	0.0	5.710	0.0		Vel = 17.41
	0.0 110.50					36.225	K Factor = 18.36
77 to 52	128.83	2.067 100	1T	7.137	6.000	32.902	
		0.2103	0.0	7.137	0.0		Vel = 12.32
	0.0 128.83					35.665	K Factor = 21.57
50 to 51	110.50	3.26 100	0.0	10.000	36.225		
		0.0172	0.0	0.0	0.0		Vel = 4.25

Final Calculations - Standard

DEAN AND ALLYN, INC.
SURFACE CREATIONS OF MAINE

Page 4
Date 4-14-14

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/UL	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
51	110.77	3.26	1T 14.388	1.000	36.397				
to		100	0.0	14.388	0.0				
54	221.27	0.0623	0.0	15.388	0.958		Vel = 8.51		
	0.0								
	221.27				37.355		K Factor = 36.20		
52	128.83	3.26	0.0	8.000	35.665				
to		100	0.0	0.0	0.0				
53	128.83	0.0229	0.0	8.000	0.183		Vel = 4.95		
53	107.78	3.26	1T 14.388	7.000	35.848				
to		100	0.0	14.388	0.0				
54	236.61	0.0705	0.0	21.388	1.507		Vel = 9.09		
54	221.26	3.26	4E 10.714	63.500	37.355				
to		100	1T 14.388	41.245	0.866				
TR	457.87	0.2389	0.0	104.745	25.019		Vel = 17.60		
TR	0.0	6.357	1D 42.176	11.000	63.240				
to		100	1G 2.692	73.584	4.764				
FF	457.87	0.0092	1S 28.716	84.584	0.782		Vel = 4.63		
FF	0.0	8.27	1G 6.326	100.000	68.786				
to		140	1T 55.354	90.149	0.0				
CTY	457.87	0.0014	1E 28.468	190.149	0.262		Vel = 2.73		
	250.00						Qa = 250.00		
	707.87				69.048		K Factor = 85.19		

Fittings Used Summary

DEAN AND ALLYN, INC.
SURFACE CREATIONS OF MAINE

Page 5
Date 4-14-14

Fitting Legend																						
Abbrev.	Name	½	¾	1	1¼	1½	2	2½	3	3½	4	5	6	8	10	12	14	16	18	20	24	
D	Generic Dry Pipe Valve	0	0	0	0	0	0	9.5	17	0	28	0	47	0	0	0	0	0	0	0	0	0
E	90' Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61	
G	Generic Gate Valve	0	0	1	1	1	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13	
S	Generic Swing Check Vlv	4	5	5	7	9	11	14	16	19	22	27	32	45	55	65	76	87	98	109	130	
T	90' Flow Thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121	

Pressure / Flow Summary - STANDARD

DEAN AND ALLYN, INC.
SURFACE CREATIONS OF MAINE

Page 6
Date 4-14-14

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
01A	12.0	5.6	10.33	na	18.0	.15	120	7.0
01	13.0	K = K @ 01	11.16	na	18.0			
02	13.0	K = K @ 01	12.52	na	19.06			
03	13.0	K = K @ 01	13.64	na	19.9			
04	13.0	K = K @ 01	16.47	na	21.87			
05	13.0	K = K @ 01	18.82	na	23.37			
06	13.0	K = K @ 01	24.38	na	26.6			
07	13.0	K = K @ 01	11.16	na	18.0			
08	13.0	K = K @ 01	12.47	na	19.02			
09	13.0	K = K @ 01	14.27	na	20.35			
10	13.0	K = K @ 01	20.09	na	24.15			
11	13.0	K = K @ 01	23.74	na	26.25			
12	13.0	K = K @ 01	12.27	na	18.87			
13	13.0	K = K @ 01	14.04	na	20.18			
14	13.0	K = K @ 01	16.02	na	21.56			
15	13.0	K = K @ 01	19.75	na	23.94			
16	13.0	K = K @ 01	23.66	na	26.21			
17	13.0	K = K @ 01	12.21	na	18.82			
18	13.0	K = K @ 01	13.97	na	20.13			
19	13.0	K = K @ 01	15.94	na	21.51			
20	13.0	K = K @ 01	19.65	na	23.89			
21	13.0	K = K @ 01	23.55	na	26.14			
77	13.0		32.9	na				
50	13.0		36.23	na				
51	13.0		36.4	na				
52	13.0		35.67	na				
53	13.0		35.85	na				
54	13.0		37.35	na				
TR	11.0		63.24	na				
FF	0.0		68.79	na				
CTY	0.0		69.05	na	250.0			

The maximum velocity is 20.3 and it occurs in the pipe between nodes 06 and 77

Water Supply Curve (C)

DEAN AND ALLYN, INC.
SURFACE CREATIONS OF MAINE

Page 7
Date 4-14-14

City Water Supply:
C1 - Static Pressure : 79
C2 - Residual Pressure: 77
C2 - Residual Flow : 1331

