



DEMOLITION WORK NOTES:

- ① ALL EXISTING CAT 5/5E WITHIN FACILITY SHALL BE REMOVED.
- ② TELCO ROOM 105 TO BE MOVED TO NEW LOCATION ON MEZZANINE. REFER TO DRAWING E2.21 FOR NEW LOCATIONS.

GENERAL ELECTRICAL DEMOLITION NOTES

- 1. REFER TO DRAWINGS E1.** AND E2.** FOR NEW ELECTRICAL WORK.
- 2. ELECTRICAL CONTRACTOR SHALL REMOVE AND SAFELY DISCARD ALL EXISTING ELECTRICAL OUTLETS NOTED WITH "RV". REFER TO DRAWINGS E1.** AND E2.** FOR MORE INFORMATION.
- 3. PROVIDE BLANK PLATES AT ABANDONED DEVICES AND DISCONNECT OR REMOVE WIRING WHERE WALLS ARE OPEN. DE-ENERGIZE ABANDONED WIRING AT THE SOURCE TO THE DEVICE BEING REMOVED. MAINTAIN CONTINUITY TO EXISTING DEVICES THROUGH SPLICES WHERE DEVICES ARE REMOVED ON COMMON CIRCUITS.
- 4. DEVICES TO BE REMOVED ARE SHOWN. CONTRACTOR IS RESPONSIBLE TO VISIT THE SITE TO MAKE THE FINAL DETERMINATION OF REMOVALS REQUIRED.
- 5. REFER TO DRAWINGS E1.11, E1.12 AND E1.21 FOR ALL LIGHTING CHANGES, TO INCLUDE RELOCATION AND REMOVAL OF LIGHTING FIXTURES.

400A DISCONNECT CONNECTED TO EXISTING RTU-1
12.5kVA XFMR

TRANSFORMER AND 400A DISCONNECT, SUPPLYING POWER TO RTU-1 TO BE RELOCATED TO NEW ELECTRICAL ROOM ON MEZZANINE. SEE DRAWING E2.13 FOR NEW LOCATION. EXISTING RTU-1 SHALL REMAIN IN PLACE AND WILL NEED TO BE RECONNECTED. COORDINATE WITH MECHANICAL CONTRACTOR FOR PROPER SHUT DOWN AND START UP OF RTU-1

DESIGNER

BENNETT ENGINEERING
MECHANICAL • ELECTRICAL
(207) 865-9475

OWNER

UNITIL

6 LIBERTY LANE WEST
HAMPTON, NEW HAMPSHIRE
03842

PROJECT

NORTHERN UTILITIES, INC.
FIT-UP

400 RIVERSIDE INDUSTRIAL PARKWAY
PORTLAND, MAINE 04101

DRAWING

SECOND FLOOR
DEMO POWER
PLAN-AREA "A"

REVISIONS

NO.	DATE	DESCRIPTION

DRAWING NUMBER
DE1.21

SCALE: 1/8" = 1'-0"
DATE: 04/17/15