



LIGHTING WORK NOTES:

- ① EXISTING OFFICE AREAS SHALL BE COMPLETELY RE-LAMPED, 3500K TEMP, WITH BALLASTS CHANGED AS NEEDED.
- ② EXISTING WAREHOUSE AREAS SHALL BE COMPLETELY RE-LAMPED, COLOR TEMP TBD, WITH BALLASTS CHANGED AS NEEDED.
- ③ EXISTING LIGHTING WITHIN AREA OF NEW WELDING ROOM TO BE RECONFIGURED AND SINGLE POLE SWITCH ADDED.

DESIGNER

BENNETT ENGINEERING
MECHANICAL • ELECTRICAL
C207-865-9475

OWNER

UNITIL

6 LIBERTY LANE WEST
HAMPTON, NEW HAMPSHIRE
03842

PROJECT

NORTHERN UTILITIES, INC. FIT-UP

400 RIVERSIDE INDUSTRIAL PARKWAY
PORTLAND, MAINE 04101

DRAWING

FIRST FLOOR LIGHTING PLAN AREA "B"

REVISIONS

NO.	DESCRIPTION

DRAWING NUMBER

E1.12

SCALE: 1/8" = 1'-0"
DATE: 04/17/15