

**Benjamin Wallace - Re: 910 Riverside Street permit 2013-01185**

---

**From:** Rich Brobst <rich@protectionprofessionals.net>  
**To:** Benjamin Wallace <wallaceb@portlandmaine.gov>  
**Date:** 6/11/2013 12:44 PM  
**Subject:** Re: 910 Riverside Street permit 2013-01185

---

I will change them to heats but I don't think it is necessary.

*Thank you for your time;*

*Rich Brobst, Jr  
NICET IV  
Master Electrician  
Protection Professionals  
325 US Route One  
Falmouth, Maine 04105  
207-775-5755  
Cell: 207-899-7761*

*This email was sent from the firm of Protection Professionals. It may contain information that is privileged or confidential. If you suspect that you were not the intended recipient, please delete it and notify us as soon as possible. Further dissemination, copying or distribution of this message or associated files is strictly prohibited. We do not accept responsibility for the security or safety of this message due to the vulnerability of the internet and the recipient should therefore exercise all due caution. Thank you.*

---

**From:** "Benjamin Wallace" <wallaceb@portlandmaine.gov>  
**To:** "Rich Brobst" <Rich@protectionprofessionals.net>  
**Sent:** Tuesday, June 11, 2013 12:30:12 PM  
**Subject:** 910 Riverside Street permit 2013-01185

Hi Rich,

The plan and wiring diagram calls for smoke detectors in the bathrooms. If they desire automatic detection please switch those to heat detectors.

Please let me know if you're going to remove the smokes in the bathroom or change them to heat detectors so I can issue the permit.

Thanks,  
Ben

Lt. Benjamin Wallace Jr.  
Fire Prevention Officer  
Portland Fire Department  
380 Congress Street  
Portland, Maine 04101  
(207)874-8400  
wallaceb@portlandmaine.gov

>>> Aaron Shields 6/7/2013 11:12 AM >>>

Please see attached permit application and supporting data / plans / specs

Also would someone please confirm receipt of this? Thank you

Aaron D. Shields - Project Manager

City of Portland, Maine

Public Buildings Division

Ph (207) 756-8292

Fax (207) 874-8473

Cell (207) 232-0570

[ads@portlandmaine.gov](mailto:ads@portlandmaine.gov)

Notice: Under Maine law, documents - including e-mails - in the possession of public officials or city employees about government business may be classified as public records. There are very few exceptions. As a result, please be advised that what is written in an e-mail could be released to the public and/or the media if requested.