



**... Fire Protection by Computer Design**

DEAN & ALLYN, INC.  
32 LEWISTON ROAD BUILDING 1C  
P.O. BOX 709  
GRAY, ME 04039  
207-657-5646

Job Name : PAYSON STREET CHILD CARE  
Building : ONE  
Location : 1340 RIVERSIDE STREET PORTLAND MAINE  
System : ONE  
Contract : TBD  
Data File : PAYSON CHILD CARE 2.WXF

HYDRAULIC DESIGN INFORMATION SHEET

Name - PAYSON STREET CHILD CARE Date - 8-9-08  
Location - 1340 RIVERSIDE STREET PORTLAND MAINE  
Building - ONE System No. - ONE  
Contractor - DEAN AND ALLYN, INC. Contract No. - TBD  
Calculated By - H KING Drawing No. - 1 OF 1  
Construction: (X) Combustible ( ) Non-Combustible Ceiling Height 8'  
OCCUPANCY - CHILD CARE FAC.

S Type of Calculation: ( )NFPA 13 Residential ( )NFPA 13R (X)NFPA 13D  
Y Number of Sprinklers Flowing: ( )1 ( )2 ( )4 (X)3  
S ( )Other  
T ( )Specific Ruling Made by Date  
E  
M Listed Flow at Start Point - 17 Gpm System Type  
Listed Pres. at Start Point - 12.5 Psi (X) Wet ( ) Dry  
D MAXIMUM LISTED SPACING 16 x 16 ( ) Deluge ( ) PreAction  
E Domestic Flow Added - 0 Gpm Sprinkler or Nozzle  
S Additional Flow Added - 0 Gpm Make VIKING Model FREEDOM  
I Elevation at Highest Outlet - 24' Feet Size 1/2" K-Factor 4.9  
G Note:CUSHION 5.96PSI Temperature Rating 155  
N

Calculation Gpm Required 34.46 Psi Required 46.53 At Test  
Summary C-Factor Used: Overhead 120 Underground 120

W Water Flow Test: Pump Data: Tank or Reservoir:  
A Date of Test - Rated Cap. Cap.  
T Time of Test - @ Psi Elev.  
E Static (Psi) - 55 Elev.  
R Residual (Psi) - 50 Other Well  
Flow (Gpm) - 50 Proof Flow Gpm  
S Elevation - 0

P Location:  
P  
L Source of Information:  
Y

# Fittings Used Summary

DEAN & ALLYN, INC.  
PAYSON STREET CHILD CARE

Page 2  
Date 8-9-08

## Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
E	90' Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
S	Generic Swing Check Valve	4	5	5	7	9	11	14	16	19	22	27	32	45	55	65	76	87	98	109	130
T	90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121

## Units Summary

Diameter Units           Inches  
 Length Units            Feet  
 Flow Units               US Gallons per Minute  
 Pressure Units          Pounds per Square Inch

# Pressure / Flow Summary - STANDARD

DEAN & ALLYN, INC.  
PAYSON STREET CHILD CARE

Page 3  
Date 8-9-08

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
5A	24.0	4.9	12.0	na	16.97	0.06	256	12.0
5	24.0	K = K @ 5	12.58	na	16.97			
6	24.0	K = K @ 5	13.34	na	17.49			
1	24.0		19.04	na				
2	24.0		19.79	na				
3	24.0		21.24	na				
10	24.0		21.24	na				
11	23.0		25.42	na				
12	16.0		29.76	na				
13	16.0		32.06	na				
14	8.0		38.05	na				
TR	8.0		40.53	na				
FF	0.0		46.06	na				
PMP	0.0		46.52	na				

The maximum velocity is 12.79 and it occurs in the pipe between nodes 6 and 1

# Final Calculations - Hazen-Williams

DEAN & ALLYN, INC.  
PAYSON STREET CHILD CARE

Page 4  
Date 8-9-08

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
5A	16.97	1.049	1T	5.0	1.000	12.000			K Factor = 4.90	
to		120		0.0	5.000	0.0				
5	16.97	0.0960		0.0	6.000	0.576			Vel = 6.30	
	0.0									
	16.97					12.576			K Factor = 4.79	
5	16.97	1.049		0.0	8.000	12.576			K Factor @ node 5	
to		120		0.0	0.0	0.0				
6	16.97	0.0961		0.0	8.000	0.769			Vel = 6.30	
6	17.49	1.049	2E	4.0	12.000	13.345			K Factor @ node 5	
to		120		0.0	4.000	0.0				
1	34.46	0.3561		0.0	16.000	5.697			Vel = 12.79	
1	0.0	1.38		0.0	8.000	19.042				
to		120		0.0	0.0	0.0				
2	34.46	0.0936		0.0	8.000	0.749			Vel = 7.39	
2	0.0	1.38	1E	3.0	6.500	19.791				
to		120	1T	6.0	9.000	0.0				
10	34.46	0.0936		0.0	15.500	1.451			Vel = 7.39	
	0.0									
	34.46					21.242			K Factor = 7.48	
3	0.0	1.38	1E	3.0	5.200	21.242				
to		120	1T	6.0	9.000	0.0				
10	0.0	0.0		0.0	14.200	0.0			Vel = 0	
10	34.46	1.38	3E	9.0	25.000	21.242				
to		120	1T	6.0	15.000	0.433				
11	34.46	0.0936		0.0	40.000	3.746			Vel = 7.39	
11	0.0	1.38	1T	6.0	8.000	25.421				
to		120		0.0	6.000	3.032				
12	34.46	0.0936		0.0	14.000	1.310			Vel = 7.39	
12	0.0	1.38	2E	6.0	6.500	29.763				
to		120	2T	12.0	18.000	0.0				
13	34.46	0.0936		0.0	24.500	2.294			Vel = 7.39	
13	0.0	1.38	3E	9.0	12.000	32.057				
to		120	1T	6.0	15.000	3.465				
14	34.46	0.0936		0.0	27.000	2.528			Vel = 7.39	
14	0.0	1.38	2T	12.0	14.500	38.050				
to		120		0.0	12.000	0.0				
TR	34.46	0.0937		0.0	26.500	2.482			Vel = 7.39	
TR	0.0	1.38	2E	6.0	6.000	40.532				
to		120	1S	7.0	13.000	3.465				
FF	34.46	0.1084	1Z	0.0	19.000	2.060			Vel = 7.39	
FF	0.0	1.38		0.0	5.000	46.057				
to		120		0.0	0.0	0.0				
PMP	34.46	0.0936		0.0	5.000	0.468			Vel = 7.39	
	0.0									
	34.46					46.525			K Factor = 5.05	

# Water Supply Curve (C)

DEAN & ALLYN, INC.  
PAYSON STREET CHILD CARE

Page 5  
Date 8-9-08

City Water Supply:  
C1 - Static Pressure : 55  
C2 - Residual Pressure: 50  
C2 - Residual Flow : 50

Demand:  
D1 - Elevation : 10.394  
D2 - System Flow : 34.4592  
D2 - System Pressure : 46.525  
Hose ( Adj City ) : \_\_\_\_\_  
Hose ( Demand ) : \_\_\_\_\_  
D3 - System Demand : 34.4592  
Safety Margin : 5.964

