
WIRE SCHEDULE					
TAG	DESCRIPTION	WIRE	GROUND	CONDUIT	Note
А	PV ARRAY STRINGS TO INVERTERS	(18) #10 PV WIRE [+ / -]	#6 BARE STRANDED CU	FREE AIR, TO J-BOX, 2½" CONDUIT	3 STRINGS PER INVERTER, TYPICAL OF 3 INVERTERS
В	INVERTERS TO AC COMBINER	(3) #8 [LI,L2,L3]; (I) #8 [N]	#8 THWN-2 Cu GEC	¾" EMT (TYP 3) OR TROUGH	TYPICAL OF 3 INVERTERS
С	AC COMBINER TO TRANSFORMER	(3) I/0 [LI,L2,L3]; (I) #6 THWN-2 [N]	#6 THWN-2 Cu GEC	I1⁄2" EMT / FMC	
D	TRANSFORMER TO INTERCONNECTION	(2) 2/0 PER PHASE [LI,L2,L3]; (I) I/0 THWN-2 [N]	I/0 THWN-2 CU GEC	2½" EMT / FMC	PARALLELS PER PHASE





142 PRESUMPSCOT STREET PORTLAND, ME 04103 (207) 221-6342

CUSTOMER NAME:

MAINE HISTORICAL SOCIETY 1000 RIVERSIDE STREET PORTLAND, ME 04103

SYSTEM TYPE:

III.69 KW_{DC}

GRID TIED PHOTOVOLTAIC ARRAY

 DESIGNED BY:
 LB

 DATE:
 DECEMBER 19, 2016

 REV.
 0

ONE-LINE DIAGRAM

E0I

© COPYRIGHT REVISION ENERGY

THIS DIAGRAM IS PROVIDED AS A SERVICE AND IS BASED ON THE UNDERSTANDING OF THE INFORMATION SUPPLIED. IT IS SUBJECT TO CHANGE BASED ON ACTUAL CONDITIONS, APPLICABLE EDITION OF THE NATIONAL ELECTRIC CODE, AND LOCAL GOVERNMENTAL AUTHORITIES.