Fire System Sequence of Operations

Actuation	Audio visual activation	Activate Audio/Visual signal at FACP & Ann	Device Desc. At FACP & Ann	Shutdown of HVAC Equip.	Log Events in System History	Silencing of Audible devices inclkuding FACP & Ann	Event Acknowledgement	Reset all system functions and visual devices	Transmission to Central Alarm Station A-Alarm T-Trouble S-Supervisory L-Log
	Action								
Smoke Detectors in common area	X	X	X		X				A
Duct installed smoke detectors		X	X	X	X				S
Sprinkler flow switches	X	X	X		X				A
Sprinkler tamper switch		X	X		X				S
FACP/annunciator silence button		X	X		X		X		L
FACP/annunciator acknowledge button		X	X		X				
FACP/annunciator reset button		X	X		X			X	L
Device Removals		X	X		X				T
Ground Faults		X	X		X				T
System wiring open		X	X		X				T
Power Loss		X	X		X				T
Back-up power loss		X	X		X				T
Communication Loss		X	X		X				T
Manual Pull Stations	X	X	X	X	X				A