
FW: ADA

4 messages

Pat Watson <pwatson@flexospan.com>
To: Jeanie Bourke <jmb@portlandmaine.gov>
Cc: Kevin Bosworth <kmbosworth@gmail.com>

Thu, Sep 21, 2017 at 3:18 PM

Good afternoon Jeanie:

Attached is DSI's ADA information. Please let me know if you need anything else.

Thanks,

Patricia A Watson,
V.P. Self Storage Buildings &
Custom Engineered Buildings
Flexospan Steel Buildings, Inc.
P.O. Box 515
Sandy Lake, PA. 16145
[800-245-0396](tel:800-245-0396)
[724-376-3864](tel:724-376-3864) Fax
pwatson@flexospan.com

-----Original Message-----

From: sales@flexospan.com [mailto:sales@flexospan.com]
Sent: Thursday, September 21, 2017 2:50 PM
To: Pat Watson <pwatson@flexospan.com>
Subject:

This E-mail was sent from "RNP11860C" (C4040).

Scan Date: 09.21.2017 14:49:35 (-0400)
Queries to: sales@flexospan.com



20170921144935981.pdf
847K

Jeanie Bourke <jmb@portlandmaine.gov>
To: Pat Watson <pwatson@flexospan.com>
Cc: Kevin Bosworth <kmbosworth@gmail.com>

Mon, Sep 25, 2017 at 3:22 PM

Hi Pat,

Thanks for the door design information, I just emailed Kevin and mentioned that the rope pull down will also need to have a loop handle so as not to require pinching to operate. Is this feature something that comes standard with the door, does the manufacturer provide this?

Thanks,
Jeanie

Jeanie Bourke
Code Enforcement Officer/Plan Reviewer
Team Leader

City of Portland
Permitting and Inspections Department

389 Congress St. Rm 315
Portland, ME 04101
jmb@portlandmaine.gov
(207)874-8715

[Quoted text hidden]

Pat Watson <pwatson@flexospan.com>
To: Jeanie Bourke <jmb@portlandmaine.gov>

Mon, Sep 25, 2017 at 3:36 PM

Hi Jeanie: Yes the door company does supply this for the handicap units.

Patricia A Watson,
V.P. Self Storage Buildings &
Custom Engineered Buildings
Flexospan Steel Buildings, Inc.
P.O. Box 515
Sandy Lake, PA. 16145
[800-245-0396](tel:800-245-0396)
[724-376-3864](tel:724-376-3864) Fax
pwatson@flexospan.com

From: Jeanie Bourke [<mailto:jmb@portlandmaine.gov>]
Sent: Monday, September 25, 2017 3:23 PM
To: Pat Watson <pwatson@flexospan.com>
Cc: Kevin Bosworth <kmbosworth@gmail.com>
Subject: Re: FW: ADA

[Quoted text hidden]

Notice: Under Maine law, documents - including e-mails - in the possession of public officials or city employees about government business may be classified as public records. There are very few exceptions. As a result, please be advised that what is written in an e-mail could be released to the public and/or the media if requested.

Jeanie Bourke <jmb@portlandmaine.gov>
To: Pat Watson <pwatson@flexospan.com>

Tue, Sep 26, 2017 at 10:49 AM

Ok, thanks Pat.

Jeanie Bourke
Code Enforcement Officer/Plan Reviewer
Team Leader

City of Portland
Permitting and Inspections Department
389 Congress St. Rm 315
Portland, ME 04101

9/26/2017

City of Portland Mail - FW: ADA

jmb@portlandmaine.gov
(207)874-8715

[Quoted text hidden]