Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 10/12/17

1/4A CORNER JAMB DETAIL
REFERENCE DRAWING 3A

2/4A TYPICAL SIDEWALL JAMB DETAIL
REFERENCE DRAWING 3A

3/4A CORNER JAMB DETAIL
REFERENCE DRAWING 3A

SECTION THRU FDN. @ JAMB

* MINIMUM REQUIREMENTS OF THE CONCRETE SLAB TO ACCEPT OUR BUILDING. BASED ON 3000 PSI COMPRESSIVE STRENGTH CONCRETE AND 1500 PSF ALLOWABLE BEARING PRESSURE. CONSULT WITH LOCAL AUTHORITY FOR COMPLIANCE WITH STATE AND LOCAL CODES.

4/4A SECTION THRU FND. @ DOOR
REFERENCE DRAWING 3A

5/4A 6" x 2 1/2" COLUMN DETAIL
REFERENCE DRAWING 3A

6/4A SECTION THRU FND. @ ADA UNITS
REFERENCE DRAWING 3A

STATE OF MAINE
SCOT J. NOTTINGHAM
No. 7351
LICENSED
PROFESSIONAL ENGINEER
10/5/17

GROUND SNOW LOAD: 70 PSF
WIND LOAD: 90 MPH

REV.	BY	DATE	DESCRIPTION
A	J.R.H.	9-25-17	REVISED FOR FOUNDATION TO FROST.
B	J.R.H.	10-5-17	REVISED FOR INSULATION & GRAVEL.

APPROVALS:

APPROVED			APPROVED AS NOTED
☐	CUSTOMER :	DATE	☐
☐	ARCHITECT :	DATE	☐
☐	CONTRACTOR:	DATE	☐
☐	DEALER :	DATE	☐
☐	OTHER :	DATE	☐
☐	:	DATE	☐

FLEXOSPAN
BOX 515 RAILROAD STREET
SANDY LAKE, PA. 16145-0515
PHONE: 800-245-0396
FAX: 724-376-3884

FOUNDATION DETAILS
JMC STORAGE
980 RIVERSIDE DRIVE
PORTLAND, ME
207-653-6339

DRAWN BY AZACCARI 10/25/16
CHECKED BY
21667M-4A