Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 10/12/17

FOUNDATION PLAN

(N.T.S.)

ANCHOR BOLTS REQ'D

(62) 3/8"Ø x 3 3/4" THUNDERSTUDS

STATE OF MAINE
SCOT J. NOTTINGHAM
No. 7351
LICENSED
PROFESSIONAL ENGINEER
10/6/17

GROUND SNOW LOAD: 70 PSF
WIND LOAD: 90 MPH

REV.	BY	DATE	DESCRIPTION
1	SJN	10/6/17	REV. SECTION 6/4A WAS 5/4A

APPROVALS:

APPROVED			APPROVED AS NOTED
☐ CUSTOMER	:	DATE	☐
☐ ARCHITECT	:	DATE	☐
☐ CONTRACTOR	:	DATE	☐
☐ DEALER	:	DATE	☐
☐ OTHER	:	DATE	☐
☐	:	DATE	☐

FLEXOSPAN
BOX 515 RAILROAD STREET
SANDY LAKE, PA. 16145-0515
PHONE: 800-245-0396
FAX: 724-376-3864

FOUNDATION PLAN & DETAILS
JMC STORAGE
980 RIVERSIDE DRIVE
PORTLAND, ME
207-653-6339

DRAWN BY AZACCARI 10/25/16
CHECKED BY
21667M-3A