



FILL IN AND SIGN WITH INK

9 50740

PERMIT ISSUED

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

JUL 19 1995

CITY OF PORTLAND

Portland, Maine

To the INSPECTOR OF BUILDINGS, PORTLAND, ME. 19 July 1995

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 2022 Washington Ave Use of Building 1-fam No. Stories New Building Existing "
Name and address of owner of appliance Tim Higgins
Installer's name and address Richard E. McDonald 197 Bridge St Westbrook, ME 04092 Telephone 854-9253
General Description of Work

To install Oil Fired Forced hot water Heating System

IF HEATER, OR POWER BOILER

Location of appliance basement Any burnable material in floor surface or beneath? no
If so, how protected? Kind of fuel? #2 oil
Minimum distance to burnable material, from top of appliance or casing top of furnace 5'
From top of smoke pipe 4' From front of appliance 20' From sides or back of appliance 6', 20'
Size of chimney flue 6" Other connections to same flue no
If gas fired, how vented? Rated maximum demand per hour 104,000
Will sufficient fresh air be supplied to the appliance to insure proper and safe combustion? Yes

IF OIL BURNER

Name and type of burner Beckett Labelled by underwriters' laboratories? Yes
Will operator be always in attendance? no Does oil supply line feed from top or bottom of tank? bottom
Type of floor beneath burner concrete Size of vent pipe 1 1/4"
Location of oil storage basement Number and capacity of tanks 1-275
Low water shut off Yes Make OEM No. 170
Will all tanks be more than five feet from any flame? Yes How many tanks enclosed? 1
Total capacity of any existing storage tanks for furnace burners 1-275

IF COOKING APPLIANCE

Location of appliance Any burnable material in floor surface or beneath?
If so, how protected? Height of Legs, if any
Skirting at bottom of appliance? Distance to combustible material from top of appliance?
From front of appliance From sides and back From top of smokepipe
Size of chimney flue Other connections to same flue
Is hood to be provided? If so, how vented? Forced or gravity?
If gas fired, how vented? Rated maximum demand per hour

MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

Richard E. McDonald 5104 Master Oil Burner
Cost of Work: 3,500.00 60.00 Permit Feet

Amount of fee enclosed:

APPROVED:

Handwritten signature

Will there be in charge of the above work a competent person who is familiar with the State and City requirements and who will observe the work?
observed?
1. 1/2" FILL PIPE
2. 1/4" VENT PIPE
3. Kind of heat & venting
4. Burner rigidity & support
5. Name & Label
6. Remote control
7. High limit control
8. Main circuit switch
9. Low water cutoff
10. High limit control
11. Piping support & bracing
12. Valves in supply line
13. Capacity of tanks
14. Tank rigidity & support
15. Combustion air
16. Clearances
17. Oil pipes thereto
18. Adequacy of venting
19. Smokestack
20. Thermal expansion switch

Signature of Installer

Richard E. McDonald

INSPECTION COPY

CS 300

1. 1 1/2" FILL PIPE
2. 1 1/4" VENT PIPE
3. Kind of hood
4. Burner rigidity & support
5. Name & Label
6. Remote control
7. High limit control
8. Main cut-off switch
9. Low water cutoff
10. High limit control
11. Piping support & protection
12. Valves in supply line
13. Capacity of tanks
14. Tank rigidity & support
15. Oil gauge
16. Instruction card
17. Oil leaks
18. Adequate ventilation
19. Smokepipe to combustibles
20. Thermal contact switch

2022-1-10

NOTES

Permit No. 950 940

Location 2022 Wash. Ave

Owner Tim Higgins

Date of permit 7-19-95

Approved 4-26-96

REGULATION CODE