

ELECTRICAL PERMIT

City of Portland, Me.

5/26/86



To the Chief Electrical Inspector, Portland Maine:
 The undersigned hereby applies for a permit to make electrical installations
 in accordance with the laws of Maine, the City of Portland Electrical Ordinance,
 National Electrical code and the following specification:

Date 14 May 1996
 Permit # 3931

LOCATION: 202 Washington Ave

OWNER Tim Higgins ADDRESS _____

							TOTAL EACH FEE		
OUTLETS									
	Receptacles		Switches		Smoke Detector		60	.20	12.00
FIXTURES	(number of)								
	incandescent		fluorescent				14	.20	2.80
	fluorescent strip							.20	
SERVICES									
	Overhead				TTL AMPSTO	800	100	15.00	15.00
	Underground					800		15.00	
TEMPORARY SERV.									
	Overhead				AMPS OVER	800		25.00	
	Underground					800		25.00	
METERS	(number of)						1	1.00	1.00
MOTORS	(number of)							2.00	
RESID/COM	Electric units							1.00	
HEATING	oil/gas units							5.00	
APPLIANCES	Ranges	1	Cook Tops		Wall Ovens			2.00	
	Water heaters		Fans	1	Dryers	1		2.00	
Disposals	Dishwasher	1	Compactors		Others (denote)			2.00	8.00
MISC. (number of)	Air Cond/win							3.00	
	Air Cond/cent							10.00	
	Signs							5.00	
	Pools							10.00	
	Alarms/res							5.00	
	Alarms/com							15.00	
	Heavy Duty							2.00	
	Outlets								
	Circus/Carnv							25.00	
	Alterations							5.00	
	Fire Repairs							15.00	
	E Lights							1.00	
	E Generators							20.00	
	Panels							4.00	
TRANSFORMER	0-25 Kva							5.00	
	25-200 Kva							8.00	
	Over 200 Kva							10.00	

TOTAL AMOUNT DUE
 MINIMUM FEE/COMMERCIAL 35.00
 MINIMUM FEE 25.00
 38.80

INSPECTION: Will be ready 5/20 or will call XXXX Credit -25.00
 See Attached 13.80

CONTRACTORS NAME Breggia Electric
 ADDRESS 1901 Forest Ave
 TELEPHONE 797-8888
 MASTER LICENSE No. 3931
 LIMITED LICENSE No. _____

SIGNATURE OF CONTRACTOR

ELECTRICAL INSTALLATIONS—

INSPECTION: Service 6/3/96 by max
 Service called in 6/6/96
 Closing-in 5/21/96 by max

Permit Number 3931
 Location 2226 Washington Ave.
 Owner Tim Higgins
 Date of Permit 5/14/96
 Final Inspection 6/11/96
 By Inspector [Signature]

PROGRESS INSPECTIONS: 5/20/96 (ROUGH-IN)
6/3/96 (SERVICE)
6/6/96 (SERVICE)
6/11/96 (FINAL)
 | |
 | |

reinspection

DATE:	REMARKS:
5/20/96	DW & DISPOSED ARE NOT ON SEPERATE CIRCUIT FROM LIGHTING (must be seperated)
6/4/96	SERVICE RED TAGGED (NEED TO PUT GROUND WIRE IN (1/2" PVC & BOND WIRE TO PANEL IN BASEMENT)
6/6/96	(SERVICE OK)
6/10/96	- Foyer light missing (need capped)
"	- Bed room open level fan light not working
"	- Doorbell system not working

TRANSFORMER
 0-25 KVA
 25-200 KVA
 Over 200 KVA

MINIMUM FEE COMMERCIAL 35.00
 MINIMUM FEE 28.00
 TOTAL AMOUNT DUE 38.50

or will call XXXX
 25.00
 17.50

SIGNATURE OF CONTRACTOR
 [Signature]

DATE
 [Date]