

CITY OF PORTLAND
FIRE PREVENTION BUREAU
380 Congress Street, Portland, Maine 04101
fireprevention@portlandmaine.gov
(207) 874-8400

NOTICE OF VIOLATION AND ORDER TO CORRECT

April 27, 2017

Responsible Party 1: HAUGHEY PHILIP C TRUSTEE 1660 SOLDIERS FIELD RD BOSTON, MA 02135		
Location 1392 RIVERSIDE ST	CBL 369 A005001	Inspection Date 4/11/2017
Inspector Brad James	Inspection Type FP Routine Inspection Commerci	Status Failed

The City of Portland Fire Department inspected this property, and found the fire and life safety code violations listed below, which you are hereby ordered to correct. You must propose a date of completion to remedy each violation, a final date of completion, and a date of re-inspection.

You must send this form to the Fire Prevention Bureau no later than 5/15/2017.

Your failure to submit a plan of action by the date provided, or to correct any violation within the applicable time frame, may result in legal action against you, the imposition of civil penalties, and the pursuit of other legal remedies.

Violation	Proposed Date of Completion
NFPA 101- 9.1.2 CERTIFY ELECTRICAL SYSTEM; Electrical wiring and equipment shall be in accordance with NFPA 70, unless such installations are approved existing installations, which shall be permitted to be continued in service.	
NFPA 70- ARTICLE 410.42 EXPOSED LIVE ELECTRICAL WIRES; Exposed metal parts shall be connected to an equipment grounding conductor or insulated from the equipment grounding conductor and other conducting surfaces or be inaccessible to unqualified personnel. Lamp tie wires, mounting screws, clips, and decorative bands on glass spaced at least 38 mm from lamp terminals shall not be required to be grounded.	
NFPA 101- 9.1.2 IMPROPER WIRING, NOT TO CODE; Electrical wiring and equipment shall be in accordance with NFPA 70, unless such installations are approved existing installations, which shall be permitted to be continued in service.	
NFPA 70- ARTICLE 590.6 EXT. CORD USED FOR PERMENANT WIRING; Ground-fault protection for personnel for all TEMPORARY wiring installations shall be provided to comply with 590.6 (A) and (B). This section shall apply only to temporary wiring installations used to supply temporary power to equipment used by personnel during construction, remodeling, maintenance, repair, or demolition of buildings, structures, equipment or similar activities.	

Violation	Proposed Date of Completion
NFPA 1- 10.1.1 STRUCTURE NEEDS REPAIR; Every new and existing building or structure shall be constructed, arranged, equipped, maintained, and operated in accordance with this code so as to provide a reasonable level of life safety, property protection, and public welfare from the actual and potential hazards created by fire, explosion, and other hazardous conditions. Structural column has been damaged by a vehicle in the warehouse area.	
NFPA 10- 7.1.1 FIRE EXTINGUISHERS NEED ANNUAL SERVICE; The owner or designated agent or occupant of a property in which fire extinguishers are located shall be responsible for inspection, maintenance, and recharging.	
N.F.P.A. 101 CHP. 31.3.3.2 HOLE IN CEILING NEEDS REPAIR; InteriorWall and Ceiling Finish Interior walls and ceiling finish materials complying with 10.2 shall be permitted as follows: 1) Exit enclosures -- Class A or class B 2) Lobbies and corridors--Class A or Class B 3) Other spaces Class A, orClass B, or Class C Ceiling tile in offices missing and damaged due to leak in roof.	
NFPA 101- 9.7.5. PROVIDE TEST & COMPLIANCE DOCUMENTATION; All automatic sprinkler and standpipe systems required by this Code shall be inspected, tested, and maintained in accordance with NFPA 25, Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems. Needs inspection	___/___/___
NFPA 101- 7.10.1.1 EXITS CLEARLY VISIBLE OR CONSPICUOUSLY INDICATED; Where Required: Means of egress shall be marked in accordance with section 7.10 where required in Chapters 11 through 43.	___/___/___
1-4.5.8 MAINTENANCE, INSPECTION, AND TESTING; WHENEVER OR WHEREVER ANY DEVICE, EQUIPMENT, SYSTEM, CONDITION, ARRANGEMENT, LEVEL OF PROTECTION, FIRE-RESISTIVE CONSTRUCTION, OR ANY OTHER FEATURE IS REQUIRED FOR COMPLIANCE WITH THE PROVISIONS OF THIS CODE, SUCH DEVICE, EQUIPMENT, SYSTEM, CONDITION, ARRANGEMENT, LEVEL OF PROTECTION, FIRE-RESISTIVE CONSTRUCTION, OR OTHER FEATURE SHALL THEREAFTER BE CONTINUOUSLY MAINTAINED.	___/___/___
NFPA 70- ARTICLE 314.28 OPEN ELECTRICAL JUNCTION BOX; Boxes and conduit bodies used as pull or junction boxes shall comply with 314.28 (A) through (D).	___/___/___
FINAL DATE OF COMPLETED VIOLATION(S)	___/___/___
FIRE PREVENTION BUREAU RE-INSPECTION OF COMPLETED VIOLATION(S)	___/___/___

The Bureau reserves the right to reject or modify any proposed plan of action, and may require evidence of sufficient financial and technical capacity to complete the proposed plan. Please contact the Bureau with any questions.

VIOLATOR CERTIFICATION

I agree to remedy the violations listed within the timeframes provided. If I require additional time to comply, I understand that I must contact the Fire Prevention Bureau prior to the deadline to request an extension, which is entirely within the Bureau's discretion to grant or deny.

I further understand that it is my responsibility to schedule a reinspection of my property once the violations have been remedied to do so. My failure to schedule a reinspection shall be deemed an admission that the violations have not been remedied.

If I fail to comply with this agreement, I understand that I am liable for penalties pursuant to the City of Portland Code of Ordinances §§ 1-15 and 10-25, and 30-A M.R.S. § 4452 and may be subject to further legal action.

Date

Responsible Party

Date

Responsible Party

SEEN AND AGREED

Date

Fire Prevention Bureau