DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



This is to certify that

INFINITY FEDERAL CREDIT UNION

Located at

4 DAVIS FARM RD

PERMIT ID: 2014-01503

ISSUE DATE: 07/16/2014

CBL: 369 A019001

has permission to Alterations, which include the construction of a 15 foot interior wall to divide the existing conference room into two (2) offices.

paragraph of paragraphs from an administration accounting this pa

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Chris Pirone

/s/ Laurie Leader

Fire Official

Building Official

THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY THERE IS A PENALTY FOR REMOVING THIS CARD

Approved Property Use - Zoning

Credit Union Offices

Building Inspections

Use Group: B Type: 5B

Business - Credit union Occupant load=28

ENTIRE

MUBEC/IBC 2009

Fire Department Classification:

Business

ENTIRE 2009 NFPA

....

BUILDING PERMIT INSPECTION PROCEDURES Please call 874-8703 (ONLY)

or email: buildinginspections@portlandmaine.gov

Check the Status or Schedule an Inspection On-Line at http://www.portlandmaine.gov/planning/permitstatus.asp

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.
- Permits expire in 6 months. If the project is not started or ceases for 6 months.
- If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.
- Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.

REQUIRED INSPECTIONS:

Close-in Plumbing/Framing w/Fire & Draft Stopping Above Ceiling Inspection Electrical Close-in w/Fire & Draftstopping Final - Commercial

Final - Electric

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

Permit No: Date Applied For: CBL: City of Portland, Maine - Building or Use Permit 07/10/2014 2014-01503 369 A019001 389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716 Proposed Use: Proposed Project Description: Same: Office Building Alterations, which include the construction of a 15 foot interior wa to divide the existing conference room into two (2) offices.

Dept: Zoning **Status:** Approved w/Conditions **Reviewer:** Marge Schmuckal

Approval Date: 07/14/2014

Ok to Issue: Note:

Conditions:

1) It is understood that this project has been requested to be removed from the "Fast Track" route and will be handled through the regular review route.

07/15/2014 **Dept:** Building **Status:** Approved w/Conditions Reviewer: Laurie Leader **Approval Date:** Note: Ok to Issue:

Conditions:

- 1) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.
- 2) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.

Dept: Fire **Status:** Approved w/Conditions **Reviewer:** Chris Pirone **Approval Date:** 07/15/2014 Note: Ok to Issue:

Conditions:

- 1) Through-penetrations and membrane penetrations in fire walls, fire barrier walls, and fire resistance rated horizontal assemblies shall be protected by firestop systems or devices in conformance with NFPA 101:8.3.5 (ASTM E 814 or ANSI/UL 1479). Providing firestop labels at each firestop system or device and an onsite manual containing the detail for each firestop system or device used for the project will streamline final inspection approvals.
- 2) Shall comply with 2009 NFPA 1 Chapter 16 Safeguards During Building Construction, Alteration, and Demolition Operations. Any cutting and welding done will require a Hot Work Permit from Fire Department.
- 3) All construction shall comply with City Code Chapter 10. http://www.portlandmaine.gov/citycode/chapter010.pdf Shall comply with 2009 NFPA 101 Chapter 39 Existing Business Occupancies Shall comply with 2009 NFPA 1 Chapter 20.13 Business Occupancies.
- 4) Street addresses shall be marked on the structure
- 5) All outstanding code violations shall be corrected prior to final inspection.
- 6) Any Fire alarm or Sprinkler systems shall be reviewed by a licensed contractor(s) for code compliance. A separate Fire Alarm Permit is required for new systems; or for work effecting more than 5 fire alarm devices; or replacement of a fire alarm panel with a different model. This review does not include approval of fire alarm system design or installation. A separate Suppression System Permit is required for all new suppression systems or sprinkler work effecting more than 20 heads. This review does not include approval of sprinkler system design or installation.

Fire Alarm system shall be maintained. If system is to be off line over 4 hours a fire watch shall be in place. Dispatch notification required 874-8576.

Located at: 4 DAVIS FARM RD CBL: 369 A019001 **PERMIT ID:** 2014-01503