

Memo

To: Doug Brown/
From: Mike Nugent/Manager of Inspection Services
CC: Sam Hoffses/Building Inspector
Date: 07/19/01
Re: Grade adjacent to above ground pools

This office has reviewed your request for grading for the above installation, and find that 2 feet of net area is not sufficient to provide a barrier of 48" as required by Code. After consulting BOCA (code author) and meeting with Sam Hoffses, Building Inspector, our position is that a 3 foot wide net area before any grade change would provide adequate protection as required by the Code. Please feel free to call me at 874-8700.