

## COMMENTS

2-4-00 Met at City Hall w/ contractor (owner) for pre-con went over all plan requirements inc. Egress, Joists/RISERS, sizes of lumber, sooms, scheduled progress inspections. owner will call when lot lines are marked J.R.

3/23/00 - Sch/West for footing - approval of off strip on front plus to Stahls in 100m Accident locate Res. Per. - Blen. will meet tomorrow w/ me & Surveyor P

3/24/00 Met w/ Bldg & Surveyor - Surveyor set lines, submitted letter measured 15' 6" width, 13' 9" width - 38' front etc to pour (near over 50') P

3/31/00 for Backfill - Ken with driveway problem in rear - Part of S. 2 side I set apt for 4/3/00 w/ J.R. to do Back P

4/3/00 checked Back for Backfill. Already partially filled in instructed contractor to remove all Backfill and fill in w/ SAND. He began while I was still there J.R.

5/8 - Skuttle / Carry header down below front entry provide header @ base of stairs to bsmnt (both) / recheck egress windows (YM) - Windows being adjusted.

5/12 - Plumbing - OK - All above issues on 5/8 - corrected (YM)

6/24 Final OH Per P. & P.

22  
144  
5.7  
100  
129  
820.8

### Inspection Record

| Type                | Date        |
|---------------------|-------------|
| Foundation: _____   | _____       |
| Framing: <u>OK</u>  | <u>5/12</u> |
| Plumbing: <u>OK</u> | <u>5/12</u> |
| Final: _____        | _____       |
| Other: _____        | _____       |



CITY OF PORTLAND, MAINE  
Department of Building Inspection

# Certificate of Occupancy

LOCATION 394 Palmer Ave 370-A-033

Issued to James Piacentini

Date of Issue July 7, 2000

This is to certify that the building, premises, or part thereof, at the above location, built — altered — changed as to use under Building Permit No. 000055, has had final inspection, has been found to conform substantially to requirements of Zoning Ordinance and Building Code of the City, and is hereby approved for occupancy or use, limited or otherwise, as indicated below.

PORTION OF BUILDING OR PREMISES

APPROVED OCCUPANCY

Entire

single family dwelling use group R3  
Type 5B boca 96

Limiting Conditions:

This certificate supersedes  
certificate issued

Approved:

7/7/00  
(Date)

*Chris Washell*  
Inspector

*G. James*  
Inspector of Buildings

Notice: This certificate identifies lawful use of building or premises, and ought to be transferred from owner to owner when property changes hands. Copy will be furnished to owner or lessee for one dollar.