

... Fire Protection by Computer Design

EASTERN FIRE PROTECTION
170 KITTYHAWK AVE
AUBURN, ME 04210
(207) 784-1507

Job Name : 56 ALLISON AVE
Drawing : Wood Frame
Location : Allison Ave
Remote Area : Wet
Contract : AU-5096
Data File : 5096 - ALLISON AVE.WXF

HYDRAULIC DESIGN INFORMATION SHEET

Name - 56 ALLISON AVE Date - 10/31/2013
Location - Allison Ave
Building - Wood Frame System No. - Wet
Contractor - Eastern Fire Protection Contract No. - AU-5096
Calculated By - Derek Cash Drawing No. - 1 of 1
Construction: (X) Combustible () Non-Combustible Ceiling Height 7'-9"
OCCUPANCY - Residential

S Type of Calculation: ()NFPA 13 Residential ()NFPA 13R (X)NFPA 13D
Y Number of Sprinklers Flowing: ()1 (X)2 ()4 ()
S ()Other
T (X)Specific Ruling 13D SYSTEM Made by FIRE MARSHAL Date
E
M Listed Flow at Start Point - 16 Gpm System Type
Listed Pres. at Start Point - 13.2 Psi (X) Wet () Dry
D MAXIMUM LISTED SPACING 16 x 16 () Deluge () PreAction
E Domestic Flow Added - Gpm Sprinkler or Nozzle
S Additional Flow Added - Gpm Make TYCO Model LF II
I Elevation at Highest Outlet - 115'-8Feet Size 1/2" K-Factor 4.4
G Note: Temperature Rating 155
N

Calculation Gpm Required 32.23 Psi Required 36.6 At Pump
Summary C-Factor Used: Overhead 120 Underground 120

W Water Flow Test: Pump Data: Tank or Reservoir:
A Date of Test - Rated Cap. 20 Cap. 990
T Time of Test - @ Psi 54.13 Elev. 100'
E Static (Psi) - Elev. 100
R Residual (Psi) - Other Well
Flow (Gpm) - Proof Flow Gpm
S Elevation -

P Location: PUMP LOCATED IN BASEMENT


P
L Source of Information: PUMP MANUFACTURER TECHNICAL DATA
Y

Water Supply Curve C

EASTERN FIRE PROTECTION
56 ALLISON AVE

Pump Data:
 P1 - Pump Churn Pressure : 54.99
 P2 - Pump Rated Pressure : 54.13
 P2 - Pump Rated Flow : 20
 P3 - Pump Pressure @ Max Flow : 45.03
 P3 - Pump Max Flow : 60

Demand:
 D1 - Elevation : 6.785
 D2 - System Flow : 32.234
 D2 - System Pressure : 36.600
 Hose (Demand) : 32.234
 D3 - System Demand : 16.828
 Safety Margin



Fittings Used Summary

EASTERN FIRE PROTECTION
56 ALLISON AVE

Fitting Legend Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24	
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61	
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																				
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65						
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121	

Units Summary

- Diameter Units Inches
- Length Units Feet
- Flow Units US Gallons per Minute
- Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Flow Summary - NFPA 2007

EASTERN FIRE PROTECTION
56 ALLISON AVE

Page 4
Date 10/31/2013

SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
PUMP	See Information on Pump Curve			53.428	32.23	36.6

NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
1	115.667	4.4	13.64	16.25	
2	115.667	4.4	13.2	15.99	
3	115.667		13.66		
4	107.25		19.07		
5	108.167		20.7		
TOR	108.167		28.39		
PUMP	100.0		36.6		

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv.	Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
1 to 3	115.667 115.667	4.40	16.25 16.25	1 1.101		0.0 0.0	0.583 0.0	150 0.0463	13.637 0.0			Vel = 5.48
3			0.0 16.25						13.664		K Factor = 4.40	
2 to 3	115.667 115.667	4.40	15.99 15.99	1 1.101	T	9.563 0.0	0.750 9.562	150 0.0450	13.200 0.0			Vel = 5.39
3 to 4	115.667 107.250		16.24 32.23	1 1.101	T	9.563 0.0	1.167 9.562	150 0.1645	13.664 3.645			Vel = 10.86
4 to 5	107.250 108.167		0.0 32.23	1 1.101	E	3.825 0.0	8.500 3.825	150 0.1645	19.074 -0.397			Vel = 10.86
5 to TOR	108.167 108.167		0.0 32.23	1.25 1.38	E 4T	4.533 36.266	99.458 40.799	150 0.0548	20.705 0.0			Vel = 6.91
TOR to PUMP	108.167 100		0.0 32.23	1.25 1.38	Fsp 2S	0.0 14.0	6.250 14.000	120 0.0828	28.387 6.537		** Fixed Loss = 3	Vel = 6.91
PUMP			0.0 32.23						36.600		K Factor = 5.33	