

PERMIT ISSUED

City of Portland, Maine - Building or Use Permit Application
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No: 01-0331 Issue Date: APR 17 2001 CBL: 370 AB001001

Location of Construction: 423 Riverside Industrial Parkway Owner Name: Douglas Brothers Owner Address: n/a
Business Name: n/a Contractor Name: Langford & Low, Inc. Contractor Address: Warren Ave. Portland Phone: 2077975141
Lessee/Buyer's Name: n/a Phone: n/a Permit Type: Alterations - Commercial Zone: J-1

Past Use: Commercial / Office Space Proposed Use: Office Space / renovate office & install handicap bathrooms.
Permit Fee: \$1,224.00 Cost of Work: \$200,000.00 CEO District: 1

Proposed Project Description: Renovate office space
FIRE DEPT: Approved Denied INSPECTION: Use Group: B Type: RC
Signature: [Signature] Signature: [Signature]
PERMIT ISSUED WITH REQUIREMENTS

PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.)
Action: Approved Approved w/Conditions Denied
Signature: Date:

Permit Taken By: gg Date Applied For: 04/10/2001 Zoning Approval

1. This permit application does not preclude the Applicant(s) from meeting applicable State and Federal Rules.
2. Building permits do not include plumbing, septic or electrical work.
3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..

Special Zone or Reviews
 Shoreland
 Wetland
 Flood Zone
 Subdivision
 Site Plan
Maj Minor MM
Date: OK 4/13/01

Zoning Appeal
 Variance
 Miscellaneous
 Conditional Use
 Interpretation
 Approved
 Denied
Date:

Historic Preservation
 Not in District or Landmark
 Does Not Require Review
 Requires Review
 Approved
 Approved w/Conditions
 Denied
Date:

PERMIT ISSUED WITH REQUIREMENTS

CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provision of the code(s) applicable to such permit.

SIGNATURE OF APPLICANT ADDRESS DATE PHONE

RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE DATE PHONE

THIS IS NOT A PERMIT/CONSTRUCTION CANNOT COMMENCE UNTIL THE PERMIT IS ISSUED

Minor/Minor Site Review for New Detached Single Family Dwelling,

All Purpose Building Permit Application

In the interest of processing your application in the quickest possible manner, please complete the Information below for a Building or Use Permit.

If you or the property owner owes real estate or personal property taxes or user charges on any property within the City, payment arrangements must be made before permits of any kind are accepted.

Location/Address of Construction: 423 RIVERSIDE INDUSTRIAL PARKWAY

Total Square Footage of Proposed Structure	Square Footage of Lot
--	-----------------------

Tax Assessor's Chart, Block & Lot Number Chart# 370 Block# AB Lot# 00	Owner: Douglas Bros	Telephone#:
--	---------------------	-------------

Lessee/Buyer's Name (If Applicable)	Owner's/Purchaser/Lessee Address:	Cost Of Work: \$200,000 ⁰⁰ Fee: \$1,224
-------------------------------------	-----------------------------------	--

Current use: OFFICE SPACE

If the location is currently vacant, what was prior use:
Approximately how long has it been vacant:

Proposed use: OFFICE SPACE

Project description: RENOVATE Existing OFFICE SPACE AND Install HANDICAP BATH ROOMS

Contractor's Name, Address & Telephone: LANGFORD & SON INC (207) 7975141
P.O. Box 662
PORTLAND MAINE 04104 (207) 7970919

Applicants Name, Address & Telephone: Jim ELLSWORTH

Who should we contact when the permit is ready: Jim ELLSWORTH
Telephone: (207) 7975141

If you would like the permit mailed, what mailing address should we use:
SAME AS ABOVE

DEPT. OF BUILDING INSPECTION
CITY OF PORTLAND, ME
APR 10 2001

4/10/01
Rec'd By: Gayb

THIS IS NOT A PERMIT/CONSTRUCTION CANNOT COMMENCE UNTIL THE PERMIT IS ISSUED

SEPARATE PERMITS ARE REQUIRED FOR INTERNAL & EXTERNAL PLUMBING, HVAC AND ELECTRICAL INSTALLATIONS

- All construction must be conducted in compliance with the 1999 B.O.C.A. Building Code as amended by Section 6-Art II.
- All plumbing must be conducted in compliance with the State of Maine Plumbing Code.
- All Electrical Installation must comply with the 1999 National Electrical Code as amended by Section 6-Art III.
- HVAC (Heating, Ventilation and Air Conditioning) installation must comply with the 1993 BOCA Mechanical Code.

Minor/Minor Site Review Fee: \$300.00/Building Permit Fee: \$30.00 for the 1st \$1000.cost plus \$6.00 per \$1,000.00 construction cost thereafter.

ONE SET OF SUBMISSIONS INCLUDING CONSTRUCTION AND SITE PLAN DRAWINGS MUST BE SUBMITTED ON PAPER NO LARGER THAN 11" x 17" BEFORE ANY BUILDING PERMIT WILL BE ISSUED

Certification

I hereby certify that I am the Owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his/her authorized agent. I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in this application is issued, I certify that the Code Official's authorized representative shall have the authority to enter all areas covered by this permit at any reasonable hour to enforce the provisions of the codes applicable to this permit.

Signature of applicant: 	Date: 4/10/01
---	---------------

Please note that exact replacement of any structure including decks, stairs and sheds will still need a scaled plot plan.

BUILDING PERMIT REPORT

DATE: 13 APRIL 2001 ADDRESS: 423 Riverside Ind. Pkwy CBL: 370-A13-001

REASON FOR PERMIT: Interior Reno.

BUILDING OWNER: Douglas Brothers

PERMIT APPLICANT: CONTRACTOR Langford's Low, Inc

USE GROUP: B CONSTRUCTION TYPE: 2C CONSTRUCTION COST: 200,000.00 PERMIT FEES: 1,224.00

The City's Adopted Building Code (The BOCA National Building Code/1999 with City Amendments)
The City's Adopted Mechanical Code (The BOCA National Mechanical Code/1993)


CONDITION(S) OF APPROVAL

This permit is being issued with the understanding that the following conditions shall be met: *1, *21, *22, *23, *24, *28, *30, *31

- 1. This permit does not excuse the applicant from meeting applicable State and Federal rules and laws.
2. Before concrete for foundation is placed, approvals from the Development Review Coordinator and Inspection Services must be obtained.
3. Foundation drain shall be placed around the perimeter of a foundation that consists of gravel or crushed stone containing not more than 10 percent material that passes through a No. 4 sieve.
4. Foundations anchors shall be a minimum of 1/2" in diameter, 7" into the foundation wall, minimum of 12" from corners of foundation and a maximum 6' O.C. between bolts.
5. Waterproofing and dampproofing shall be done in accordance with Section 1813.0 of the building code.
6. Precaution must be taken to protect concrete and masonry. Concrete Sections 1908.9-19.8.10/ Masonry Sections 2111.3-2111.4.
7. It is strongly recommended that a registered land surveyor check all foundation forms before concrete is placed. This is done to verify that the proper setbacks are maintained.
8. Private garages located beneath habitable rooms in occupancies in Use Group R-1, R-2, R-3 or I-1 shall be separated from adjacent interior spaces by fire partitions and floor/ceiling assembly which are constructed with not less than 1-hour fire resisting rating.
9. All chimneys and vents shall be installed and maintained as per Chapter 12 of the City's Mechanical Code.
10. Sound transmission control in residential building shall be done in accordance with Chapter 12, Section 1214.0 of the City's Building Code.
11. Guardrails & Handrails: A guardrail system is a system of building components located near the open sides of elevated walking surfaces for the purpose of minimizing the possibility of an accidental fall from the walking surface to the lower level.
12. Headroom in habitable space is a minimum of 7'6".
13. Stair construction in Use Group R-3 & R-4 is a minimum of 10" tread and 7 1/4" maximum rise.
14. The minimum headroom in all parts of a stairway shall not be less than 80 inches.
15. The Minimum required width of a corridor shall be determined by the most restrictive of the criteria under section 1011.3 but not less than 36".
16. Every sleeping room below the fourth story in buildings of Use Groups R and I-1 shall have at least one operable window or exterior door approved for emergency egress or rescue.
17. Each apartment shall have access to two (2) separate, remote and approved means of egress.
18. All vertical openings shall be enclosed with construction having a fire rating of at least one (1) hour, including fire doors with self closure's.
19. The boiler shall be protected by enclosing with (1) hour fire rated construction including fire doors and ceiling, or by providing automatic extinguishment.

A/10

20. All single and multiple station smoke detectors shall be of an approved type and shall be installed in accordance with the provisions of the City's Building Code Chapter 9, Section 920.3.2 (BOCA National Building Code/1999), and NFPA 101 Chapter 18 & 19. (Smoke detectors shall be installed and maintained at the following locations):
 - In the immediate vicinity of bedrooms
 - In all bedrooms
 - In each story within a dwelling unit, including basements
- *21. A portable fire extinguisher shall be located as per NFPA #10. They shall bear the label of an approved agency and be of an approved type. (Section 921.0)
- *22. The Fire Alarm System shall be installed and maintained to NFPA #72 Standard.
- *23. The Sprinkler System shall be installed and maintained to NFPA #13 Standard.
- *24. All exit signs, lights and means of egress lighting shall be done in accordance with Chapter 10 Section & Subsections 1023.0 & 1024.0 of the City's Building Code. (The BOCA National Building Code/1999)
25. Section 25 - 135 of the Municipal Code for the City of Portland states, "No person or utility shall be granted a permit to excavate or open any street or sidewalk from the time of November 15 of each year to April 15 of the following year".
26. The builder of a facility to which Section 4594-C of the Maine State Human Rights Act Title 5 MRSA refers, shall obtain a certification from a design professional that the plans commencing construction of the facility, the builder shall submit the certification the Division of Inspection Services.
27. Ventilation and access shall meet the requirements of Chapter 12 Sections 1210.0 and 1211.0 of the City's Building Code. (Crawl spaces & attics).
- *28. All electrical, plumbing and HVAC permits must be obtained by Master Licensed holders of their trade. No closing in of walls until all electrical (min. 72 hours notice) and plumbing inspections have been done.
29. All requirements must be met before a final Certificate of Occupancy is issued.
- *30. All building elements shall meet the fastening schedule as per Table 2305.2 of the City's Building Code (The BOCA National Building Code/1996).
- *31. Ventilation of spaces within a building shall be done in accordance with the City's Mechanical code (The BOCA National Mechanical Code/1993). (Chapter M-16)
32. Please read and implement the attached Land Use Zoning report requirements.
33. Boring, cutting and notching shall be done in accordance with Sections 2305.3, 2305.3.1, 2305.4.4 and 2305.5.1 of the City's Building Code.
34. Bridging shall comply with Section 2305.16.
35. Glass and glazing shall meet the requirements of Chapter 24 of the building code. (Safety Glazing Section 2406.0)
36. All flashing shall comply with Section 1406.3.10.
37. All signage shall be done in accordance with Section 3102.0 signs of the City's Building Code, (The BOCA National Building Code/1999).


 P. Samuels, Building Inspector
 Cc: Mr. McDougall, PFD
 Marge Schmuckal, Zoning Administrator
 Michael Nugent, Inspection Service Manager





PSH 10/1/00

****This permit is herewith issued, on the basis of plans submitted and conditions placed on these plans, any deviations shall require a separate approval.**

*****THIS PERMIT HAS BEEN ISSUED WITH THE UNDERSTANDING THAT ALL THE CONDITIONS OF THE APPROVAL SHALL BE COMPLETED. THEREFORE, BEFORE THE WORK IS COMPLETED A REVISED PLAN OR STATEMENT FROM THE PERMIT HOLDER SHALL BE SUBMITTED TO THIS OFFICE SHOWING OR EXPLAINING THAT THE CONDITIONS HAVE BEEN MET. IF THIS REQUIREMENT IS NOT RECEIVED YOUR CERTIFICATE OF OCCUPANCY SHALL BE WITHHELD. (You Shall Call for Inspections)**

******ALL PLANS THAT REQUIRE A PROFESSIONAL DESIGNER'S SEAL, (AS PER SECTION 114.0 OF THE BUILDING CODE) SHALL ALSO BE PRESENTED TO THIS DIVISION ON AUTO CAD LT. 2000, DXF FORMAT OR EQUIVALENT.**


*******CERTIFICATE OF OCCUPANCY FEE \$50.00**



SAME RM
(OPP. HAND)
SAME CRITERIA.

GRAB BARS,
4'-8" ROBRIK # B6806.99
3'-0" ROBRIK # B6806.99

17" HIGH TOILET BOWL.
29" MIN (TOP OF LAV)
(COVER EXPOSED PIPING)



UTILITY ROOM
(SIZE?)

6'-6" CLEAR

42" GRAB BAR

3" GRAB BARS

6" MIN

MEN

WOMEN

30" x 30" MIRROR

3'-0" DOOR W/
SARGENT 10 SERIES
LEVER HANDLES

ADA APPROVED
LAV & WATER CLOS. ONLY

DOUGLASS BROTHERS HANDICAP TOILET PLAN'S

1/4" = 1'-0"

ELECTRICAL PERMIT

City of Portland, Me.



To the Chief Electrical Inspector, Portland Maine:
 The undersigned hereby applies for a permit to make electrical installations
 in accordance with the laws of Maine, the City of Portland Electrical Ordinance,
 National Electrical Code and the following specifications:

Date 5/9/01
 Permit # 1492
 CBL# 312A006
370 AB 001

LOCATION: 423 RIVERSIDE INDUSTRIAL PKWY METER MAKE & # _____
 CMP ACCOUNT # _____ OWNER DOUBLAS BROS.
 TENANT DOUBLAS BROS. PHONE # 8797-6771

OUTLETS		Receptacles	Switches	Smoke Detector	TOTAL EACH FEE
	5				.20
FIXTURES		Incandescent	Fluorescent	Strips	.20
SERVICES		Overhead	Underground	TTL AMPS <800	15.00
	7	Overhead	Underground	TTL AMPS >800	25.00
Temporary Service		Overhead	Underground	TTL AMPS	25.00
METERS	1	(number of)			25.00
MOTORS WELDERS	30	(number of)			1.00
RESID/COM		Electric units			2.00
HEATING		oil/gas units	Interior	Exterior	1.00
APPLIANCES		Ranges	Cook Tops	Wall Ovens	5.00
		Insta-Hot	Water heaters	Fans	2.00
		Dryers	Disposals	Dishwasher	2.00
		Compactors	Spa	Washing Machine	2.00
		Others (denote)			2.00
MISC. (number of)		Air Cond/win			3.00
		Air Cond/cent		Pools	10.00
		HVAC	EMS	Thermostat	5.00
		Signs			10.00
		Alarms/res			5.00
		Alarms/com			15.00
		Heavy Duty(CRKT)			2.00
		Circus/Carnv			25.00
		Alterations			5.00
		Fire Repairs			15.00
		E Lights			1.00
		E Generators			20.00
PANELS		Service	2 Remote	Main	4.00
TRANSFORMER		0-25 Kva			5.00
		25-200 Kva			8.00
		Over 200 Kva			10.00
MINIMUM FEE/COMMERCIAL 45.00				TOTAL AMOUNT DUE	95-
INSPECTION: Will be ready _____				MINIMUM FEE 35.00	
				or will call <u>X</u>	

CONTRACTORS NAME MILLIKEN BROS MASTER LIC. # M560017389
 ADDRESS 474 RIVERSIDE INDUSTR. PKWY LIMITED LIC. # _____
 TELEPHONE 797-8375

SIGNATURE OF CONTRACTOR [Signature]

ELECTRICAL PERMIT

City of Portland, Me.



To the Chief Electrical Inspector, Portland Maine:
 The undersigned hereby applies for a permit to make electrical installations
 in accordance with the laws of Maine, the City of Portland Electrical Ordinance,
 National Electrical Code and the following specifications:

Date 6/29/01
 Permit # 1658
 CBL# 370 AB 001

SITE LOCATION: 423 RIVERSIDE INDUSTRIAL PKWY

OWNER DOUGLAS BROJ. **TENANT** DOUGLAS BROJ.

WIRING 3 OFFICES + BREAK RM ADDED IN EXIST. BUILDING **TOTAL EACH FEE**

OUTLETS	Receptacles	20	Switches	5	Smoke Detectors				.20	5.-	
FIXTURES	incandescent	10	fluorescent		Strips				.20	2.-	
SERVICES	Overhead		Underground		TTL AMPS	<800			15.00		
	Overhead		Underground		TTL AMPS	>800			25.00		
Temporary Service	Overhead		Underground		TTL AMPS				25.00		
									25.00		
METERS	(number of)								1.00		
MOTORS	(number of)								2.00		
RESID/COM	Electric units								1.00		
HEATING	oil/gas units		Interior		Exterior				5.00		
			Ranges	Cook Tops	Wall Ovens				2.00		
APPLIANCES	Insta-Hot		Water heaters		Fans				2.00		
	Dryers		Disposals		Dishwasher				2.00		
	Compactors		Spa		Washing Machine				2.00		
	Others (denote)								2.00		
	MISC. (number of)	Air Cond/win								3.00	
		Air Cond/cent				Pools				10.00	
		HVAC		EMS		Thermostat				5.00	
		Signs								10.00	
	Alarms/res								5.00		
	Alarms/com								15.00		
	Heavy Duty(CRKT)								2.00		
	Circus/Carnv								25.00		
	Alterations								5.00		
	Fire Repairs								15.00		
	E Lights								1.00		
	E Generators								20.00		
PANELS	Service	1	Remote		Main				4.00	4.-	
TRANSFORMER	0-25 Kva								5.00		
	25-200 Kva								8.00		
	Over 200 Kva								10.00		
									TOTAL AMOUNT DUE		
									MINIMUM FEE	25.00	
									MINIMUM FEE/COMMERCIAL	35.00	

INSPECTION: Will be ready _____ or will call X

CONTRACTORS NAME MILLIKEN BROJ. INC.
ADDRESS 454 RIVERSIDE INDUSTRIAL PKWY
TELEPHONE 227-2375

MASTER LIC. # M560015399
LIMITED LIC. # _____

SIGNATURE OF CONTRACTOR

[Handwritten Signature]

ELECTRICAL PERMIT

City of Portland, Me.



To the Chief Electrical Inspector, Portland Maine:
 The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the City of Portland Electrical Ordinance, National Electrical Code and the following specifications:

Date 4/12/01
 Permit # 1412
 CBL# 870 AB001

LOCATION: 423 Riverside Industrial Park METER MAKE & # _____
 CMP ACCOUNT # _____ OWNER _____
 TENANT Douglas Bros. Stainless Steel Fabricators PHONE # _____

						TOTAL EACH FEE			
OUTLETS	20	Receptacles		Switches		Smoke Detector	20	.20	4.00
FIXTURES	7	Incandescent	60	Fluorescent		Strips	67	.20	13.40
SERVICES		Overhead		Underground		TTL AMPS <800		15.00	
		Overhead		Underground		TTL AMPS >800		25.00	
Temporary Service		Overhead		Underground		TTL AMPS		25.00	
METERS		(number of)						25.00	
MOTORS		(number of)						1.00	
RESID/COM		Electric units						2.00	
HEATING		oil/gas units		Interior		Exterior		5.00	
		Ranges		Cook Tops		Wall Ovens		2.00	
APPLIANCES		Insta-Hot		Water heaters		Fans		2.00	
		Dryers		Disposals		Dishwasher		2.00	
		Compactors		Spa		Washing Machine		2.00	
		Others (denote)						2.00	
MISC. (number of)		Air Cond/win				Pools		3.00	
		Air Cond/cent				Thermostat		10.00	
	2	HVAC		EMS				5.00	10.00
		Signs						10.00	
		Alarms/res						5.00	
		Alarms/com						15.00	
		Heavy Duty(CRKT)						2.00	
		Circus/Carnv						25.00	
		Alterations						5.00	
		Fire Repairs						15.00	
	6	E Lights					6	1.00	6.00
		E Generators						20.00	
PANELS		Service		Remote		Main		4.00	
TRANSFORMER		0-25 Kva						5.00	
		25-200 Kva						8.00	
		Over 200 Kva						10.00	
						TOTAL AMOUNT DUE			20.40 33.40
						MINIMUM FEE	35.00		

INSPECTION: Will be ready _____ or will call _____

~~20.40~~ 33.40
 \$45.00

CONTRACTORS NAME Seabee Electric MASTER LIC. # 60017768
 ADDRESS 200 Anderson St. LIMITED LIC. # _____
 TELEPHONE 774-4880

SIGNATURE OF CONTRACTOR _____

ELECTRICAL PERMIT

City of Portland, Me.



To the Chief Electrical Inspector, Portland Maine:
 The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the City of Portland Electrical Ordinance, National Electrical Code and the following specifications:

Date 4/12/01
 Permit # 1412
 CBL# 870 AB001

LOCATION: 423 Riverside Industrial Park METER MAKE & # _____
 CMP ACCOUNT # _____ OWNER _____
 TENANT Douglas Bros. Stainless Steel Fabricators PHONE # _____

						TOTAL EACH FEE			
OUTLETS	20	Receptacles		Switches		Smoke Detector	20	.20	4.00
FIXTURES	7	Incandescent	60	Fluorescent		Strips	67	.20	13.40
SERVICES		Overhead		Underground		TTL AMPS	<800		15.00
		Overhead		Underground			>800		25.00
Temporary Service		Overhead		Underground		TTL AMPS			25.00
METERS		(number of)							25.00
MOTORS		(number of)							1.00
RESID/COM		Electric units							2.00
HEATING		oil/gas units		Interior		Exterior			1.00
APPLIANCES		Ranges		Cook Tops		Wall Ovens			5.00
		Insta-Hot		Water heaters		Fans			2.00
		Dryers		Disposals		Dishwasher			2.00
		Compactors		Spa		Washing Machine			2.00
		Others (denote)							2.00
MISC. (number of)		Air Cond/win							3.00
		Air Cond/cent							10.00
	2	HVAC		EMS		Pools			5.00
		Signs				Thermostat			10.00
		Alarms/res							10.00
		Alarms/com							5.00
		Heavy Duty(CRKT)							15.00
		Circus/Carnv							2.00
		Alterations							25.00
		Fire Repairs							5.00
	6	E Lights							15.00
		E Generators					6	1.00	6.00
									20.00
PANELS		Service		Remote		Main			4.00
TRANSFORMER		0-25 Kva							5.00
		25-200 Kva							8.00
		Over 200 Kva							10.00
MINIMUM FEE/COMMERCIAL 45.00						TOTAL AMOUNT DUE			
INSPECTION: Will be ready _____ or will call _____						MINIMUM FEE 35.00			20.00 33.40

CONTRACTORS NAME Seabee Electric MASTER LIC. # 60017768
 ADDRESS 200 Anderson St. LIMITED LIC. # _____
 TELEPHONE 774-4880

SIGNATURE OF CONTRACTOR _____
831-0975 (Anna)

W/R# _____

CBL: 370 A B.001

PORTLAND

Service Address 423 Riverside Industrial Pkwy

Account # _____

Meter make and Number _____

House # _____ Lot # _____ Apartment # _____

Development Name _____

Owner/Contractor Name Douglas Bros.

Electrician Milligen Bros

Circle one on each line

NEW

UPGRADE ←

OK
CH

TEMP

PERM

OVERHEAD

UNDERGROUND ←

Inspector: M. Collins

Comments: PASS

City of Portland Electrical Permit: 1492

Called in by: M. Collins Date: 7/31/01 Time: 8:30 AM

Faxed to CMP: 7/31/01 by: C. HARRIS

Portland Service Operations
Central Maine Power Company

207-791-8000

PLUMBING APPLICATION

Department of Human Sciences
Division of Health Engineering

PROPERTY ADDRESS

Town or Plantation: Portland, Maine

Street: Riverside Ind. Pkwy

PROPERTY OWNERS NAME

Douglas Brothers

Last:

First:

Applicant Name: Kelley Mechanical, Inc

Mailing Address of Owner/Applicant (if Different): 610 Grandwater St Westbrook, ME 04092

Owner/Applicant Statement

I certify that the information submitted is correct to the best of my knowledge and understand that any falsification is reason for the Local Plumbing Inspectors to deny a Permit.

Signature of Owner/Applicant

Date: 5/2/01

PORTLAND

Date Permit Issued: 5/10/01

7698

TOWN COPY

\$ 1040.01

Double Fee FEE Charged

L.P.I. # 011814

Caution: Inspection Required

I have inspected the installation authorized above and found it to be in compliance with the Maine Plumbing Rules.

Local Plumbing Inspector Signature

Date Approved

PERMIT INFORMATION

This Application is for

- NEW PLUMBING
- RELOCATED PLUMBING

Type of Structure To Be Served:

- SINGLE FAMILY DWELLING
- MODULAR OR MOBILE HOME
- MULTIPLE FAMILY DWELLING
- OTHER - SPECIFY Commercial

Plumbing To Be Installed By:

- MASTER PLUMBER
- OIL BURNERMAN
- MFG'D. HOUSING DEALER/MECHANIC
- PUBLIC UTILITY EMPLOYEE
- PROPERTY OWNER

LICENSE # ME93621

Hook-Up & Piping Relocation Maximum of 1 Hook-Up

HOOK-UP: to public sewer in those cases where the connection is not regulated and inspected by the local Sanitary District.

OR

HOOK-UP: to an existing subsurface wastewater disposal system.

PIPING RELOCATION: of sanitary lines, drains, and piping without new fixtures.

OR

TRANSFER FEE
[\$6.00]

Column 2 Type of Fixture

Number	Type of Fixture
1	Hosebibb / Sillcock
1	Floor Drain
1	Urinal
1	Drinking Fountain
1	Indirect Waste
1	Water Treatment Softener, Filter, etc.
1	Grease / Oil Separator
1	Dental Cuspidor
1	Bidet
1	Other: _____
4	Fixtures (Subtotal) Column 2

Column 1 Type of Fixture

Number	Type of Fixture
1	Bathtub (and Shower)
1	Shower (Separate)
1	Sink
1	Wash Basin
2	Water Closet (Toilet)
1	Clothes Washer
1	Dish Washer
1	Garbage Disposal
1	Laundry Tub
1	Water Heater
4	Fixtures (Subtotal) Column 1
4	Fixtures (Subtotal) Column 2
4	Total Fixtures
	Fixture Fee
	Transfer Fee
	Hook-Up & Relocation Fee
	Permit Fee (Total)

SEE PERMIT FEE SCHEDULE FOR CALCULATING FEE

24.00