

. . . Fire Protection by Computer Design

FREEDOM FIRE PROTECTION INC.
209 QUAKER RIDGE ROAD
CASCO, MAINE 04015
207-627-4109

Job Name : RICK HOLDEN RESIDENCE HC1
Building : 20 BALLPARK LANE
Location : PORTLAND, MAINE 04103
System : #1 AREA #1
Contract :
Data File : Rick Holden Residence HC1.WXF

HYDRAULIC DESIGN INFORMATION SHEET

Name - RICK HOLDEN RESIDENCE Date - 4/20/12
Location - PORTLAND, MAINE 04103
Building - 20 BALLPARK LANE System No. - #1 AREA #1
Contractor - FREEDOM FIRE PROTECTION Contract No. -
Calculated By - MICHAEL NOBLIT Drawing No. - FP-2
Construction: (X) Combustible () Non-Combustible Ceiling Height 8'-3"
OCCUPANCY - HOUSE

S Type of Calculation: (X)NFPA 13 Residential ()NFPA 13R (X)NFPA 13D
Y Number of Sprinklers Flowing: ()1 (X)2 ()4 ()
S ()Other
T ()Specific Ruling Made by Date
E
M Listed Flow at Start Point - 14 Gpm System Type
Listed Pres. at Start Point - 10.1 Psi (X) Wet () Dry
D MAXIMUM LISTED SPACING 14 x 14 () Deluge () PreAction
E Domestic Flow Added - 0 Gpm Sprinkler or Nozzle
S Additional Flow Added - 0 Gpm Make TYCO Model LFII
I Elevation at Highest Outlet - 25'-7"Feet Size 1/2" K-Factor 4.4
G Note: Temperature Rating 155
N

Calculation Gpm Required 28.197 Psi Required 57.879 At Test
Summary C-Factor Used: Overhead 150 Underground 150

W Water Flow Test: Pump Data: Tank or Reservoir:
A Date of Test - 1/24/2012 Rated Cap. Cap.
T Time of Test - @ Psi Elev.
E Static (Psi) - 63 Elev.
R Residual (Psi) - 0 Other Well
Flow (Gpm) - 838 Proof Flow Gpm
S Elevation -

P Location:
P
L Source of Information: PORTLAND WATER DISTRICT
Y

Water Supply Curve (C)

FREEDOM FIRE PROTECTION INC.
RICK HOLDEN RESIDENCE HC1


Page 2
Date 4/20/12

City Water Supply:

C1 - Static Pressure : 63
C2 - Residual Pressure: 0
C2 - Residual Flow : 838

Demand:

D1 - Elevation : 11.423
D2 - System Flow : 28.1969
D2 - System Pressure : 57.879
Hose (Adj City) : _____
Hose (Demand) : _____
D3 - System Demand : 28.1969
Safety Margin : 5.003



Fittings Used Summary

FREEDOM FIRE PROTECTION INC.
 RICK HOLDEN RESIDENCE HC1

Page 3
 Date 4/20/12

Fitting Legend

Abbrev.	Name	½	¾	1	1¼	1½	2	2½	3	3½	4	5	6	8	10	12	14	16	18	20	24
E	90' Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
T	90' Flow Thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zaa	Ames 2000B	Fitting generates a Fixed Loss Based on Flow																			

Pressure / Flow Summary - STANDARD

FREEDOM FIRE PROTECTION INC.
RICK HOLDEN RESIDENCE HC1

Page 4
Date 4/20/12

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
101	26.375	4.4	10.1	na	13.98	0.05	0.001	10.1
102	26.375	4.4	10.44	na	14.21	0.05	0.001	10.1
9	26.375		10.45	na				
8	18.292		15.48	na				
7	18.292		18.94	na				
6	18.292		22.35	na				
5	18.292		22.9	na				
4	7.166		30.39	na				
3	7.166		33.91	na				
2	7.166		39.31	na				
1	0.0		47.35	na				
0	0.0		57.88	na				
TEST	0.0		57.88	na				

The maximum velocity is 10.47 and it occurs in the pipe between nodes 4 and 3

Final Calculations - Hazen-Williams

FREEDOM FIRE PROTECTION INC.
 RICK HOLDEN RESIDENCE HC1

Page 5
 Date 4/20/12

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	***** Notes *****
101 to 9	13.98	1.101 150 0.0351	1T 9.563 0.0 0.0	0.500 9.562 10.062	10.100 0.0 0.353		K Factor = 4.40 Vel = 4.71
	0.0 13.98				10.453		K Factor = 4.32
102 to 9	14.21	1.101 150 0.0360	0.0 0.0 0.0	0.500 0.0 0.500	10.435 0.0 0.018		K Factor = 4.40 Vel = 4.79
9 to 8	13.99	1.101 150 0.1285	1E 3.825 0.0 0.0	8.083 3.825 11.908	10.453 3.501 1.530		Vel = 9.50
8 to 7	0.0	1.101 150 0.1284	1E 3.825 1T 9.563 0.0	13.500 13.387 26.887	15.484 0.0 3.453		Vel = 9.50
7 to 6	0.0	1.101 150 0.1285	1T 9.563 0.0 0.0	17.000 9.562 26.562	18.937 0.0 3.412		Vel = 9.50
6 to 5	0.0	1.101 150 0.1286	1E 3.825 0.0 0.0	0.500 3.825 4.325	22.349 0.0 0.556		Vel = 9.50
5 to 4	0.0	1.101 150 0.1284	1T 9.563 0.0 0.0	11.166 9.562 20.728	22.905 4.819 2.662		Vel = 9.50
4 to 3	0.0	1.049 120 0.2456	1T 5.0 0.0 0.0	9.330 5.000 14.330	30.386 0.0 3.520		Vel = 10.47
3 to 2	0.0	1.049 120 0.2457	1E 2.0 0.0 0.0	20.000 2.000 22.000	33.906 0.0 5.405		Vel = 10.47
2 to 1	0.0	1.38 120 0.0645	1Zaa 0.0 0.0 0.0	6.166 0.0 6.166	39.311 7.637 0.398		* Fixed loss = 4.533 Vel = 6.05
1 to 0	0.0	1.329 150 0.0514	1E 2.375 1T 4.75 0.0	120.000 7.125 127.125	47.346 4.000 6.530		* Fixed loss = 4 Vel = 6.52
0 to TEST	0.0	8.27 140 0.0	1T 55.354 0.0 0.0	250.000 55.354 305.354	57.876 0.0 0.003		Vel = 0.17
	0.0 28.20				57.879		K Factor = 3.71