Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 05/27/16

BASEMENT FLOOR PLAN
1/4" = 1'-0"

NOTES:

1. PROVIDE ENTIRE BUILDING WITH AUTOMATIC SPRINKLER SYSTEM NFPA 13D AND SUBMIT SPRINKLER PLANS TO AUTHORITIES HAVING JURISDICTION FOR APPROVALS BEFORE INSTALLATION.

REGISTERED ARCHITECT
JOHN H. LEASURE
No. 310
STATE OF MAINE

REV.	DATE	STATUS
0	3-28-16	PERMIT SUBMISSION

JOHN H. LEASURE ARCHITECT, INC.
6 Q STREET
SOUTH PORTLAND, MAINE 04106

MICHAEL & MARY ANN JIMINO RESIDENCE
1637 WASHINGTON AVENUE
PORTLAND, MAINE

BASEMENT FLOOR PLAN

A1