15095

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 05/27/16

Portland Fire Department Checklist

1. Name, address, telephone number of applicant

The applicant for the project is:

Michael Jimino
1407 Riverside Street
Portland, Maine 04103
207-776-0994

2. Name Address, telephone number of architect

The architect for the project is:

John H. Leasure – Architect Inc.
6 Q Street
South Portland, Maine 04106
207-272-3267

3. Proposed uses of any structures [NFPA and IBC classification]

The project is the construction of a single family residence with attached garage.

4. Square footage of all structures [total and per story]

The total square footage of the proposed home and garage is approximately 3,020 sq. ft.

5. Elevation of all structures

House Foundation Elevation	139.40
Garage Foundation Elevation	138.00

6. Proposed fire protection of all structures

Per City Code (NFPA 101 2009 ed.) the home will be sprinkled in compliance with NFPA 13D.

7. Hydrant Locations

There is an existing hydrant located on the opposite side of Washington Avenue from the proposed driveway entrance. No new hydrants are proposed at this time.