

CITY OF PORTLAND, MAINE - FIRE PREVENTION BUREAU
 Test and Maintenance Report - Private Fire Hydrant

Property/Business Information: Chart: _____ Block: _____ Lot: _____
 Property Address: 31 Croquet Lane Zip Code: 04101
 Hydrant # / Location(attach map): 1 /
 Business/Owner Name: Sitahon Houses
 Contact Person: NORM MAZE Phone No: 874 1080
 Mailing Address: 106 Guilman St Portland Zip Code: 04101

Test Type	
New Installation	[]
Annual	[]
5 Year Flow Test	[]
Other	
Describe:	

Please be advised that we (owner / contractor) have made the following maintenance and test of the fire hydrant in accordance with National Fire Protection Standards 25, 24 and 291. This form must be completed for each hydrant located on the premises:

CONTACT THE PORTLAND WATER DISTRICT TO COORDINATE PRIOR TO FLOWING ANY FIRE HYDRANT

Report of private fire hydrant service condition (new installation, annual and 5-year flow test):

Criteria	Status (Pass/Fail)	Corrective Action (Identify)
Accessibility (clear/unobstructed space all around Private fire hydrant shall be no less than three feet)	PASS	
Leaks in outlets or at top of hydrant (no leakage allowed)		
Proper drainage from hydrant barrel		
Cracks in hydrant barrel/flange		
Tightness of outlets (wrench tight)		
Worn or incorrect outlet threads		
Worn hydrant operating nut		
Hydrant has 4 1/2" steamer port		

IF THE PRIVATE FIRE HYDRANT IS FOUND NOT SERVICEABLE, IMMEDIATELY NOTIFY THE DISPATCH CENTER AT 874-8576, COVER AND SECURE THE HYDRANT WITH A BAG, AND THEN NOTIFY FIRE PREVENTION AT 874-8400.

Barrel Flow Test (new installation or annual):

Checked boxes below indicate "yes"

Hydrant fully opened All foreign material cleared
 Flow duration greater than one minute Barrel is plugged and pumped out

Maintenance (new installation or annual):

Weeds and obstructions cleared from within three feet of hydrant Hydrant caps and threads inspected
 Rust and scale removed Lubricated Flagged

Marking (new installation or annual):

Painted [] (Bonnet - Gray) (All paint shall be Rust-Oleum brand or equal)
 (Caps- Silver)
 (Barrel- Red) →
 (Bonnet Flange - per table)

Flow (gpm)	Class	Color
< 500	C	RED
500-999	B	ORANGE
1000-1499	A	GREEN
≥1500	AA	LIGHT BLUE

3" red hydrant number painted on street side of the bonnet - starting with 1 at the furthest hydrant from the complex or street entrance

High Pressure Hydrants (static pressures ≥ 125 psi) shall be marked "HP" before the hydrant number (ex. HP-1, HP-2, etc.)

Flow test (new installation, once every five years thereafter, or if previous flow report not available):

Hydrant flow testing per NFPA 24 Annex C. Attach NFPA Hydrant Flow Test Report (See NFPA 24 Figure C.4.11.2)

Certification:

I hereby certify the foregoing data to be correct and the statements to be true.

Testing company: Advanced Fire Protection Services Phone No: 783 3600 FAX No: 783 9980
 Address: PO Box 81 City: Munich State: ME Zip Code: 04258
 Tester's name (print): Douglas Campbell Tester's signature: [Signature]
 Test date: 3 / 22 / 12 Contractor's Lic. # 746
 M M D D Y Y