

EXHAUST FAN INFORMATION - Job#1986426

FAN UNIT NO.	FAN UNIT MODEL #	CFM	ESP.	RPM	H.P.	Ø	VOLT	FLA	WEIGHT (LBS.)	SDNES
1	NCA18HPFA	2025	1.000	1082	1.000	1	230	6.8	199	10.1

MUA FAN INFORMATION - Job#1986426

FAN UNIT NO.	FAN UNIT MODEL #	BLDWR	HOUSING	CFM	ESP.	RPM	H.P.	Ø	VOLT	FLA	WEIGHT (LBS.)	SDNES
2	A1-D250-G10	G10	A1-D250	1822	0.350	934	1.000	1	230	6.8	695	14.7

GAS FIRED MAKE-UP AIR UNITS

FAN UNIT NO.	ACTUAL INPUT AIR BTUS	OUTPUT BTUS	TEMP. RISE	REQUIRED INPUT GAS PRESSURE	GAS TYPE	
2	YES	175743	161684	85 deg F	7 in. w.c. - 14 in. w.c.	Natural

FAN OPTIONS

FAN UNIT NO.	OPTION (Qty. - Descr.)
1	1 - Grease Box
1	1 - Full Grating For Exhaust Fans
1	1 - 3 Year Extended Motor Warranty
1	1 - Extra Set of Belts
1	1 - Fan Base Ceramic Seal - For Grease Ducts
1	1 - Motorized Backdraft Damper for A1-D Housing
1	1 - AC Interlock Relay - 24VAC Coil
1	1 - Full Grating For Commercial Heater
1	1 - Low Fire Start
1	1 - Inlet Pressure Gauge, 0-35"
1	1 - Manifold Pressure Gauge, -5 to 15" wc

FAN ACCESSORIES

FAN UNIT NO.	EXHAUST	SUPPLY
2	GREASE CUP GRAVITY DAMPER WALL MOUNT SIDE DISCHARGE	GRAVITY DAMPER MOTORIZED DAMPER WALL MOUNT

CURB ASSEMBLIES

DN FAN NO.	WEIGHT	ITEM	SIZE
1 # 1	41 LBS	Curb	26.500"V x 26.500"L x 20.000"H Vented Hinged
2 # 2	63 LBS	Curb	21.000"V x 71.000"L x 20.000"H 3.000x12.000 Pitch Along Width, Right Insulated

CUSTOMER APPROVAL TO MANUFACTURE:

Approved as Noted

Approved with ND Exception Taken

Revise and Resubmit

SIGNATURE _____ Date _____

Your Title _____

JOB First Lutheran Church
 LOCATION LEWISTON, ME
 DATE 3/3/2014
 DWG # 3
 REV.

JOB # 1986426
 DRAWN BY BFC-21
 SCALE 3/8" = 1'-0"

