DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



This is to certify that

BROWN C N COMPANY

Located at

194 AUBURN ST

PERMIT ID: 2014-02199

ISSUE DATE: 10/06/2014

CBL: 374 A030001

has permission to install a Non-Water-Based Fire Suppression System above fuel dispenser provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ David Petruccelli

/s/ Tammy Munson

Fire Official

Building Official

THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY THERE IS A PENALTY FOR REMOVING THIS CARD

Approved Property Use - Zoning

Building Inspections

Fire Department

Heating oil office & minor auto service station with no automobile repair

BUILDING PERMIT INSPECTION PROCEDURES Please call 874-8703 (ONLY)

or email: buildinginspections@portlandmaine.gov

Check the Status or Schedule an Inspection On-Line at http://www.portlandmaine.gov/planning/permitstatus.asp

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.
- Permits expire in 6 months. If the project is not started or ceases for 6 months.
- If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.
- Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.

REQUIRED INSPECTIONS:

Final - Fire

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No: 2014-02199

Date Applied For: 09/22/2014

CBL:

374 A030001

Proposed Use:

Heating Oil Office & Minor Auto Service Station - no repair, just fuel dispensing

Proposed Project Description:

install a Non-Water-Based Fire Suppression System above fuel dispenser

Dept: Zoning

Status: Approved

Reviewer: Ann Machado

Approval Date:

09/23/2014

Ok to Issue:

Ok to Issue: ✓

Note:

Conditions:

Dept: Fire

Status: Approved w/Conditions

Reviewer: David Petruccelli

Approval Date:

10/03/2014

Note:

Conditions:

- 1) Application requires State Fire Marshal approval.
- 2) Street addresses shall be marked on the structure and shall be as approved by the City E-911 Addressing Officer.
- 3) All outstanding code violations shall be corrected prior to final inspection.
- 4) Construction or installation shall comply with City Code Chapter 10.
- 5) Any cutting and welding done will require a Hot Work Permit from Fire Department.
- 6) Shall meet the requirements of 2009 NFPA 1 Fire Code.
- 7) All construction shall comply with City Code Chapter 10.

http://www.portlandmaine.gov/citycode/chapter010.pdf

Shall meet the requirements of 2009 NFPA 1 Fire Code.

Shall meet the requirements the most recent NFPA 30 Flammable and Combustible Liquids Code.

Shall meet the requirements the most recent NFPA 30A Code for Motor Fuel Dispensing Facilities and Repair Garages.

Shall have State Fire Marshall Permit.

Shall have DEP Permit.