

COMMENTS

4/5/02 - ① Front Left Side of Pool Does NOT meet 48" Requirement
② Deck has been added w/o permit
③ Stairs to pool has NO protection (E)

4/8/02 - Owner submitted Ammendment for deck and ladder barriers for pool. Discussed area @ The pool 36" away from 48" pool wall to maintain 48" height JB

5/21/02 Items # 1, # 2, # 3 (4/5/02) - Work Complete
Close out (D)
374-B-8
145 Auburn St.

Inspection Record

Type	Date
Foundation: _____	_____
Framing: _____	_____
Plumbing: _____	_____
Final: _____	_____
Other: _____	_____