

CITY OF PORTLAND
 FIRE PREVENTION BUREAU
 380 Congress Street, Portland, Maine 04101
 fireprevention@portlandmaine.gov
 (207) 874-8400

NOTICE OF VIOLATION AND ORDER TO CORRECT

February 3, 2017

Responsible Party 1: CITY OF PORTLAND 389 CONGRESS ST PORTLAND, ME 04101		
Location 171 AUBURN ST	CBL 374 B012001	Inspection Date 1/27/2017
Inspector Michael Scherb	Inspection Type FP School Inspection	Status Failed

The City of Portland Fire Department inspected this property, and found the fire and life safety code violations listed below, which you are hereby ordered to correct. You must propose date of completion to remedy each violation and a final date of completion and re-inspection.

You must send this form to the Fire Prevention Bureau no later than 2/28/2017.

Your failure to submit a plan of action by the date provided, or to correct any violation within the applicable time frame, may result in legal action against you, the imposition of civil penalties, and the pursuit of other legal remedies.

Violation	Proposed Date of Completion
NFPA 101- 13.2.3.1 EGRESS; The capacity of means of egress shall be in accordance with one of the following: (1) Section 7.3 for other than theater-type seating or smoke-protected assembly seating (2) 13.2.3.2 for rooms with theater-type seating or similar seating arranged in rows (3) 13.4.2 for smoke-protected assembly seating Items stored in front of emergency exit windows in multipule classrooms	
NFPA 54- 9.6.4 UTILITY DISCONNECTS BLOCKED; Each appliance connected to a piping system shall have an accessible, approved manual shutoff valve with a nondisplaceable valve member, or a listed gas convenience outlet. Appliance shutoff valves and convenience outlets shall serve a single appliance only and shall be installed in accordance with 9.6.4.1. Sub panels in hallways blocked	
FINAL DATE OF COMPLETED VIOLATION(S)	___/___/___
FIRE PREVENTION BUREAU RE-INSPECTION OF COMPLETED VIOLATION(S)	___/___/___

The Bureau reserves the right to reject or modify any proposed plan of action, and may require evidence of sufficient financial and technical capacity to complete the proposed plan. Please contact the Bureau with any questions.

VIOLATOR CERTIFICATION

I agree to remedy the violations listed within the timeframes provided. If I require additional time to comply, I understand that I must contact the Fire Prevention Bureau prior to the deadline to request an extension, which is entirely within the Bureau's discretion to grant or deny.

I further understand that it is my responsibility to schedule a reinspection of my property once the violations have been remedied to do so. My failure to schedule a reinspection shall be deemed an admission that the violations have not been remedied.

If I fail to comply with this agreement, I understand that I am liable for penalties pursuant to the City of Portland Code of Ordinances §§ 1-15 and 10-25, and 30-A M.R.S. § 4452 and may be subject to further legal action.

Date

Responsible Party

Date

Responsible Party

SEEN AND AGREED

Date

Fire Prevention Bureau