Reviewed for Code Compliance
Approved as Noted
Approved with Conditions
Date: 10/14/13

SYSTEM OUTPUTS

	SYSTEM INPUTS	A: ACTIVATE NOTIFICATION DEVICES	B: DEACTIVATE NOTIFICATION DEVICES	C: GENERATE TROUBLE CONDITION ON BOOSTER PANEL
1	ALARM SIGNAL FROM MASTER FACP	●		
2	SILENCE SIGNAL FROM FACP		●	
3	NAC BOOSTER PANEL AC POWER FAILURE			●

REVISION 2	DATE:	
REVISION 1	DATE:	
REVISION 0 SUBMITTAL	DATE:	10/03/2013

CAUSE AND EFFECT MATRIX

PROJECT NAME
LYMAN MOORE MIDDLE SCHOOL
171 AUBURN STREET
PORTLAND, ME 04103

SCALE NTS
BY: JRS
CK BY:
SAVED AS:

NORRIS INC
Prepared For Tomorrow; Delivered Today
2257 BROADWAY, SO. PORTLAND, MAINE