

Portland Fire Department Monthly School Inspection

Name: <u>LYMAN MOORE</u>	Address: <u>171 AUBURN ST</u>
Principal:	Emergency contact #: <u>874-8150</u>

Date inspected: <u>1-18-12</u>	Inspector: <u>LT D. LORA</u>
Time in: <u>0950</u>	Time out: <u>1010</u>

Fire Drills Conducted Yes No Date of last drill: 11-14-11

EXITS:	Pass	Fail	Notes:
Exit / Escapes clear of obstructions	<u>X</u>		
Exit signs & Emer lights properly lit	<u>X</u>		

Fire Alarm System	Pass	Fail	Notes:
Panel clear, accessible, operational	<u>X</u>		

Fire Extinguishers	Pass	Fail	Notes:
Extinguishers full & tagged annually	<u>X</u>		
Extinguishers accessible	<u>X</u>		


Heating System	Pass	Fail	Notes:
Boiler room clear of all combustibles	<u>X</u>		
Boiler room properly rated/protected	<u>X</u>		

Electrical system	Pass	Fail	Notes:
Extension cord use vs. permanent	<u>X</u>		
Electrical panels clear & accessible	<u>X</u>		
Electrical circuits clearly identified	<u>X</u>		

Sprinkler System	Pass	Fail	Notes:
Sprinkler heads >18" of clearance	<u>X</u>		
Sprinkler Rm & FDC labeled & clear	<u>X</u>		
Spare heads & wrench supplied	<u>X</u>		
Sprinkler system tagged insp. date	<u>X</u>		

House Keeping	Pass	Fail	Notes:
Furnishings & decorations flame rest	<u>X</u>		
Art work displayed < 20% wall area	<u>X</u>		
Housekeeping organized for safety	<u>X</u>		

Additional Safety Concerns:



Portland Fire Department Monthly School Inspection

Name: <u>LYMAN MOORE</u>	Address: <u>171 AUBURN ST</u>
Principal: <u>Stephen Rogers</u>	Emergency contact #: <u>874-8150</u>

Date inspected: <u>6-5-12</u>	Inspector: <u>DYER</u>
Time in: <u>0900</u>	Time out: <u>0930</u>

Fire Drills Conducted Yes No Date of last drill: 2-10-12

EXITS:

Exit / Escapes clear of obstructions
Exit signs & Emer lights properly lit

Pass	Fail	Notes:
✓		
✓		

Fire Alarm System

Panel clear, accessible, operational

✓		
---	--	--

Fire Extinguishers

Extinguishers full & tagged annually
Extinguishers accessible

✓		
✓		

Heating System

Boiler room clear of all combustibles
Boiler room properly rated/protected

✓		
✓		

Electrical system

Extension cord use vs. permanent
Electrical panels clear & accessible
Electrical circuits clearly identified

✓		
✓		
✓		

Sprinkler System

Sprinkler heads >18" of clearance
Sprinkler Rm & FDC labeled & clear
Spare heads & wrench supplied
Sprinkler system tagged insp. date


✓		
✓		
✓		
		<u>Last inspection 11-11-11</u>

House Keeping

Furnishings & decorations flame rest
Art work displayed < 20% wall area
Housekeeping organized for safety

✓		
✓		
✓		

Additional Safety Concerns:



Portland Fire Department Monthly School Inspection

Name: <u>LYMAN MOORE</u>	Address: <u>171 ALBURN ST</u>
Principal:	Emergency contact #: <u>874-8150</u>

Date inspected: <u>10-1-12</u>	Inspector: <u>LT D. LORD</u>
Time in: <u>1030</u>	Time out: <u>1045</u>

Fire Drills Conducted Yes No Date of last drill: LAST YEAR
2 SCHEDULED

EXITS:	Pass	Fail	Notes:
Exit / Escapes clear of obstructions	<u>A</u>		
Exit signs & Emer lights properly lit	<u>A</u>		

Fire Alarm System

Panel clear, accessible, operational	<u>A</u>	
--------------------------------------	----------	--

Fire Extinguishers

Extinguishers full & tagged annually	<u>A</u>	
Extinguishers accessible	<u>A</u>	

Heating System

Boiler room clear of all combustibles	<u>A</u>	
Boiler room properly rated/protected	<u>A</u>	

Electrical system

Extension cord use vs. permanent	<u>A</u>	
Electrical panels clear & accessible	<u>A</u>	
Electrical circuits clearly identified	<u>A</u>	

Sprinkler System

Sprinkler heads >18" of clearance	<u>A</u>	
Sprinkler Rm & FDC labeled & clear	<u>A</u>	
Spare heads & wrench supplied	<u>A</u>	
Sprinkler system tagged insp. date	<u>A</u>	

House Keeping

Furnishings & decorations flame rest	<u>A</u>	
Art work displayed < 20% wall area	<u>A</u>	
Housekeeping organized for safety	<u>A</u>	

Additional Safety Concerns: