Form # P 01

375-A-007

ELECTRICAL PERMIT
City of Portland, Me.

To the Chief Electrical Inspector, Portland Maine:
The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the City of Portland Electrical Ordinance, National Electrical code and the following specification:

Date 25 July 1996

Permit # LH 14983

LOCATION: 1483 Washington Ave

OWNER Riddle, Charles **ADDRESS**

									TOTAL	EACH FEE
OUTLETS										1.20
		Receptacles	5 X	Switches	1	Smoke Detector		X 6	.20	XXX
FIXTURES		(number of)								
		incandescent		fluorescent				2	.20	.40
		fluorescent strip							.20	
SERVICES										
		Overhead	Upgrade 60 - 100			TTL AMPS TO	800	100	15.00	15.00
		Underground					800		15.00	
TEMPORARY SERV.										
		Overhead				AMPS OVER	800		25.00	
		Underground					800		25.00	
METERS		(number of)							1.00	
MOTORS		(number of)							2.00	
RESID/COM		Electric units							1.00	
HEATING		oil/gas units							5.00	
APPLIANCES		Ranges		Cook Tops		Wall Ovens			2.00	
		Water heaters		Fans		Dryers			2.00	
Disposals		Dishwasher		Compactors		Others (denote)			2.00	
MISC. (number of)		Air Cond/win							3.00	
		Air Cond/cent							10.00	
		Signs							5.00	
		Pools							10.00	
		Alarms/res							5.00	
		Alarms/com							15.00	
		Heavy Duty							2.00	
		Outlets								
		Circus/Carnv							25.00	
		Alterations							5.00	
		Fire Repairs							15.00	
		E Lights							1.00	
		E Generators							20.00	
		Panels							4.00	
TRANSFORMER		0-25 Kva							5.00	
		25-200 Kva							8.00	
		Over 200 Kva							10.00	
						TOTAL AMOUNT DUE				
		MINIMUM FEE/COMMERCIAL 35.00				**MINIMUM FEE**		**25.00**		25.00

INSPECTION: Will be ready set up or will call

CONTRACTORS NAME Cumberland Electric Keith Hillock

ADDRESS XX 25 Glenwood Ave Westbrook, ME

TELEPHONE 854-3121

MASTER LICENSE No.

LIMITED LICENSE No. LH 14983

SIGNATURE OF CONTRACTOR Keith E Hillock

ELECTRICAL INSTALLATIONS—

Permit Number 14983

Location 1483 Washington Ave.

Owner Charles Riddle

Date of Permit 7/25/96

Final Inspection 7/25/96

By Inspector [illegible]

INSPECTION: Service 7/25/96 by [illegible]

Service called in 7/25/96

Closing-in _____ by _____

PROGRESS INSPECTIONS: 7/25/96 (SERVICE)

DATE:	REMARKS:
7/25/96	- spliced grounding electrode conductor above ceiling
	- must install 1/2" PVC on ground rod wire outside
	- cutting cmp seals & working without a permit