

ELECTRICAL PERMIT

City of Portland, Me.

375-A-019

Beak



Tues
OK

To the Chief Electrical Inspector, Portland Maine:
The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the City of Portland Electrical Ordinance, National Electrical Code and the following specifications:

Date 5/1
Permit # 375
CBL# 375-A-019

SITE LOCATION: 22 Sanborn ST.
OWNER Min Chen TENANT _____

						TOTAL EACH FEE			
OUTLETS	Receptacles	20	Switches	Smoke Detectors	4		.20	10.00	
FIXTURES	incandescent	8	fluorescent	Strips			.20	8.00	
SERVICES	Overhead		Underground	TTL AMPS	<800		15.00		
	Overhead		Underground		>800		25.00		
Temporary Service	Overhead		Underground	TTL AMPS			25.00		
							25.00		
METERS	(number of)						1.00		
MOTORS	(number of)						2.00		
RESID/COM	Electric units						1.00		
HEATING	oil/gas units		Interior	Exterior			5.00		
APPLIANCES	Ranges		Cook Tops	Wall Ovens			2.00		
	Insta-Hot		Water heaters	Fans			2.00		
	Dryers		Disposals	Dishwasher			2.00		
	Compactors		Spa	Washing Machine			2.00		
	Others (denote)						2.00		
	MISC. (number of)	Air Cond/win						3.00	
		Air Cond/cent			Pools			10.00	
	HVAC		EMS	Thermostat			5.00		
	Signs						10.00		
	Alarms/res						5.00		
	Alarms/com						15.00		
	Heavy Duty(CRKT)						2.00		
	Circus/Carnv						25.00		
	Alterations						5.00		
	Fire Repairs						15.00		
	E Lights						1.00		
	E Generators						20.00		
PANELS	Service		Remote	Main			4.00		
TRANSFORMER	0-25 Kva						5.00		
	25-200 Kva						8.00		
	Over 200 Kva						10.00		
						TOTAL AMOUNT DUE		1040	
						MINIMUM FEE/COMMERCIAL 35.00		35.00	
						MINIMUM FEE	25.00		

INSPECTION: Will be ready 5/4/00 or will call _____

CONTRACTORS NAME John Scala MASTER LIC. # MS 60007840
 ADDRESS 1747 Congress ST LIMITED LIC. # _____
 TELEPHONE 874-2989

SIGNATURE OF CONTRACTOR John Scala

ELECTRICAL INSTALLATIONS

Permit Number _____

Location _____

Owner _____

Date of Permit _____

Final Inspection _____

By Inspector _____

INSPECTION: Service _____ by _____
Service called in _____
Closing-in _____ by _____

PROGRESS INSPECTIONS: _____ / _____ / _____
_____ / _____ / _____
_____ / _____ / _____
_____ / _____ / _____
_____ / _____ / _____
_____ / _____ / _____

DATE:	REMARKS:
1-9-01	375-A-019 NEEDS JUMPER ACROSS WTR FILTER TO BOND
	PLUMBING DISTRIBUTION PIPING - A/CW
	Contractor called & stated jumper is installed.