

CITY OF PORTLAND  
 FIRE PREVENTION BUREAU  
 380 Congress Street, Portland, Maine 04101  
 fireprevention@portlandmaine.gov  
 (207) 874-8400

**NOTICE OF VIOLATION AND ORDER TO CORRECT**

November 2, 2017

Radiant Images Salon  
 9A SANBORN ST  
 PORTLAND ME 04103

DeRice Robert  
 9 SANBORN ST  
 PORTLAND, ME 04103

|                                              |                                                 |                                     |
|----------------------------------------------|-------------------------------------------------|-------------------------------------|
| <b>Location</b><br>9A SANBORN ST ( Radiant I | <b>CBL</b><br>375 B008001                       | <b>Inspection Date</b><br>8/23/2017 |
| <b>Inspector</b><br>Edward Doughty           | <b>Inspection Type</b><br>FP Routine Inspection | <b>Status</b><br>Failed             |

The City of Portland Fire Department inspected this property, and found the fire and life safety code violations listed below, which you are hereby ordered to correct. You must propose a date of completion to remedy each violation, a final date of completion, and a date of re-inspection.

**You must send this form to the Fire Prevention Bureau no later than 11/30/2017.**

Your failure to submit a plan of action by the date provided, or to correct any violation within the applicable time frame, may result in legal action against you, the imposition of civil penalties, and the pursuit of other legal remedies.

| <b>Violation</b>                                                                                                                                                                                                               | <b>Proposed Date of Completion</b> |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------|
| <b>NFPA 70- ARTICLE 314.28 OPEN ELECTRICAL JUNCTION BOX;</b> Boxes and conduit bodies used as pull or junction boxes shall comply with 314.28 (A) through (D).<br>Junction Box above Washing Machine does not have a cover     |                                    |
| <b>NFPA 70- ARTICLE 314.28 OPEN ELECTRICAL JUNCTION BOX;</b> Boxes and conduit bodies used as pull or junction boxes shall comply with 314.28 (A) through (D).<br>Junction Box outside Laundry Room Door does not have a cover |                                    |
| <b>NFPA 70- ARTICLE 314.28 OPEN ELECTRICAL JUNCTION BOX;</b> Boxes and conduit bodies used as pull or junction boxes shall comply with 314.28 (A) through (D).<br>Junction Boxes near the Furnace have no covers               |                                    |
| <b>FINAL DATE OF COMPLETED VIOLATION(S)</b>                                                                                                                                                                                    | ___/___/___                        |
| <b>FIRE PREVENTION BUREAU RE-INSPECTION OF COMPLETED VIOLATION(S)</b>                                                                                                                                                          | ___/___/___                        |

The Bureau reserves the right to reject or modify any proposed plan of action, and may require evidence of sufficient financial and technical capacity to complete the proposed plan. Please contact the Bureau with any questions.

**VIOLATOR CERTIFICATION**

*I agree to remedy the violations listed within the timeframes provided. If I require additional time to comply, I understand that I must contact the Fire Prevention Bureau prior to the deadline to request an extension, which is entirely within the Bureau's discretion to grant or deny.*

*I further understand that it is my responsibility to schedule a reinspection of my property once the violations have been remedied to do so. My failure to schedule a reinspection shall be deemed an admission that the violations have not been remedied.*

*If I fail to comply with this agreement, I understand that I am liable for penalties pursuant to the City of Portland Code of Ordinances §§ 1-15 and 10-25, and 30-A M.R.S. § 4452 and may be subject to further legal action.*

\_\_\_\_\_

Date

\_\_\_\_\_

Responsible Party

\_\_\_\_\_

Date

\_\_\_\_\_

Responsible Party

**SEEN AND AGREED**

\_\_\_\_\_

Date

\_\_\_\_\_

Fire Prevention Bureau