

# Record of Completion

Presented To

## North Deering Fire Station

386 Allen Avenue  
Portland ME 04103  
USA

This site has been inspected and tested in compliance with applicable standards.

Completed  
Friday, April 19, 2019

Test Session: 03/22/19

ACCEPTED BY

North Deering Fire Station  
386 Allen Avenue  
Portland ME 04103  
USA

TESTED BY

Norris Inc. - Michael Todd  
Norris Inc  
2257 Broadway  
South Portland ME 4106  
USA

# Inspection Location and Organizations

## Building Information

PROPERTY	North Deering Fire Station	CONTACT
ADDRESS	386 Allen Avenue	PHONE
CITY/STATE/ZIP	Portland, ME 04103	MOBILE
COUNTRY	USA	EMAIL

## Installer Information

NAME	Corey Electric
ADDRESS	609 Main St. Westbrook, ME
PHONE	207-591-8151
EMAIL	mcorey@coreyelectric.com

## Service Company Information

NAME	Norris Inc
ADDRESS	2257 Broadway South Portland ME 4106
PHONE	(207) 883-3473
EMAIL	NICentralOperations@norrisinc.com

## Testing Company Information

NAME	Norris Inc
ADDRESS	2257 Broadway South Portland ME 4106
PHONE	(207) 883-3473
EMAIL	NICentralOperations@norrisinc.com
CONTRACT DATE	

## Description of Service

This is a new system.

Permit #

NFPA72 Edition: 2013

Number of devices participating in Alarm Verification: 0

## Initiating Device Summary

EQUIPMENT TYPE	TOTAL
Initiating Device	17
Alarm Notification Appliance	19
Supervising Station Transmitting Equipment	1
Emergency Control Equipment	2
Fire Control Panel	5
Combination System	2

## Notification Device Summary

EQUIPMENT TYPE	TOTAL
Initiating Device	17
Alarm Notification Appliance	19
Supervising Station Transmitting Equipment	1
Emergency Control Equipment	2
Fire Control Panel	5
Combination System	2

Norris Inc

## Device Summary

EQUIPMENT TYPE	TOTAL
Initiating Device	17
Alarm Notification Appliance	19
Supervising Station Transmitting Equipment	1
Emergency Control Equipment	2
Fire Control Panel	5
Combination System	2

## System Control Functions

Function	Count
Fan Control	0
Smoke Damper	0
HVAC Shutdown	0
Elevator Recall	0
Elevator Power Shutdown	0
Elevator Short Trip	0
Door Holder Release	0
Shutter Release	0
Door Unlock	0
Other	2

# Certification Information

## Certification

The equipment specified herein was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Friday, April 19, 2019

INSTALLED BY

4/23/2019

Corey Electric

Installer

TESTED BY



4/23/2019

Norris Inc. - Michael Todd

Technician

ACCEPTED BY

4/23/2019

Building Representative

ACCEPTED BY

4/23/2019

PFD - Mike Clinton

AHJ

# Testing Details

## Fire Control Panel

### Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Fire Alarm Panel		Boiler Room	Manual	4/23/2019 11:32 AM
Fire Panel Batteries		Inside FACP	Manual	4/23/2019 11:32 AM
Interface Equipment	M02	AES Wateflow Trip	Manual	4/23/2019 11:33 AM
Interface Equipment	M03	AES Smokes/Pulls Trip	Manual	4/23/2019 11:33 AM
Interface Equipment	M15	Exterior Masterbox AES Trip	Manual	4/23/2019 11:35 AM

## Initiating Device

### Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	D02	Dorm Room 3	Manual	3/22/2019 3:33 PM
Smoke Detector - General	D03	Dorm Room 4	Manual	3/22/2019 3:33 PM
Smoke Detector - General	D04	Rear Hall O/S Bedrooms	Manual	3/22/2019 3:33 PM
Smoke Detector - General	D05	Dorm Room 5	Manual	3/22/2019 3:33 PM
Smoke Detector - General	D06	Dorm Room 6	Manual	3/22/2019 3:33 PM
Smoke Detector - General	D07	Dorm Room 2	Manual	3/22/2019 3:33 PM
Smoke Detector - General	D08	Hallway O/S Dorm 2	Manual	3/22/2019 3:34 PM
Smoke Detector - General	D09	Dorm Room 1 (Captain)	Manual	3/22/2019 3:34 PM
Manual Pull Station	M05	Hallway Rear Exit	Manual	3/22/2019 3:34 PM
Manual Pull Station	M10	Main Entry Vestibule	Manual	3/22/2019 3:34 PM
Valve Tamper Switch	M11	Sprinkler Bypass Tamper	Manual	3/22/2019 3:34 PM
Mechanical, Electrosonic, or Pressure Waterflow Device	M12	Sprinkler Main Flow	Manual	3/22/2019 3:34 PM
Manual Pull Station	M14	Apparatus Bay Pullstation	Manual	3/22/2019 3:34 PM
Heat Detector - Restorable Spot	D01	Boiler Room	Manual	4/23/2019 11:32 AM
Manual Pull Station	M01	Exterior Masterbox Monitor	Manual	4/23/2019 11:33 AM
Fire Suppression Alarm Switch	M08	Kitchen Hood Monitor	Manual	4/23/2019 11:34 AM
Valve Tamper Switch	M13	Sprinkler Main Tamper	Manual	4/23/2019 11:34 AM

## Alarm Notification Appliance

### Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible		Hallway 104	Manual	3/22/2019 3:35 PM
Visible		Mens Room 112	Manual	3/22/2019 3:35 PM
Audible And Visible		Hallway 113	Manual	3/22/2019 3:35 PM
Visible		Womens Room 111	Manual	3/22/2019 3:35 PM
Audible		Dorm Room 3	Manual	3/22/2019 3:35 PM
Audible And Visible		Hallway 113 O/S Bedrooms	Manual	3/22/2019 3:35 PM
Audible		Dorm Room 4	Manual	3/22/2019 3:35 PM
Audible		Dorm Room 5	Manual	3/22/2019 3:35 PM
Audible		Dorm Room 6	Manual	3/22/2019 3:35 PM
Audible And Visible		PPE Storage Wash Room	Manual	3/22/2019 3:35 PM
Audible And Visible		PPE Storage Wash Room	Manual	3/22/2019 3:35 PM

Norris Inc

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible		Hallway 104 O/S Exercise Room	Manual	3/22/2019 3:35 PM
Audible And Visible		Exercise Room 108	Manual	3/22/2019 3:35 PM
Visible		Toilet 120	Manual	3/22/2019 3:35 PM
Audible		Dorm Room 2	Manual	3/22/2019 3:35 PM
Audible		Dorm Room 1 (Captain)	Manual	3/22/2019 3:35 PM
Audible And Visible		Hallway 104 O/S Dorm 1	Manual	3/22/2019 3:35 PM
Audible And Visible		Living Room	Manual	3/22/2019 3:35 PM
Audible And Visible		Main Entry Vestibule	Manual	3/22/2019 3:36 PM

## Supervising Station Transmitting Equipment

### Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Radio Alarm Transmitter		AES Citybox	Manual	4/23/2019 11:32 AM

## Combination System

### Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
CO Detector	M04	Rear Hallway O/S Bedrooms	Manual	3/22/2019 3:34 PM
CO Detector	M06	Hallway O/S Dorm 2	Manual	3/22/2019 3:34 PM

## Emergency Control Equipment

### Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Kitchen Hood Shunt	M07	Kitchen Hood Shunt Trip	Manual	4/23/2019 11:33 AM
VOC output	M09	VOC System Trip	Manual	4/23/2019 11:34 AM

# Device/Equipment Details

## Fire Control Panel

ADDRESS	DESCRIPTION	Manufacturer	Model	SERIAL	INSTALL DATE
Fire Alarm Panel					
	Boiler Room	Notifier	NFW-100X		3/22/2019
Fire Panel Batteries					
	Inside FACP		12v12ah		3/22/2019
Interface Equipment					
M15	Exterior Masterbox AES Trip	Notifier	NC-100R		3/22/2019
M02	AES Waterflow Trip	Notifier	NC-100R		3/22/2019
M03	AES Smokes/Pulls Trip	Notifier	NC-100R		3/22/2019

## Initiating Device

ADDRESS	DESCRIPTION	Manufacturer	Model	SERIAL	INSTALL DATE
Fire Suppression Alarm Switch					
M08	Kitchen Hood Monitor	Denlar			3/22/2019
Heat Detector - Restorable Spot					
D01	Boiler Room	Notifier			3/22/2019
Manual Pull Station					
M05	Hallway Rear Exit	Notifier	NOT-BG-12LX		3/22/2019
M14	Apparatus Bay Pullstation	Notifier	NOT-BG-12LX		3/22/2019
M10	Main Entry Vestibule	Notifier	NOT-BG-12LX		3/22/2019
M01	Exterior Masterbox Monitor				3/22/2019
Mechanical, Electrosonic, or Pressure Waterflow Device					
M12	Sprinkler Main Flow				3/22/2019
Smoke Detector - General					
D03	Dorm Room 4	Notifier	NP-100		3/22/2019
D05	Dorm Room 5	Notifier	NP-100		3/22/2019
D07	Dorm Room 2	Notifier	NP-100		3/22/2019
D02	Dorm Room 3	Notifier	NP-100		3/22/2019
D09	Dorm Room 1 (Captain)	Notifier	NP-100		3/22/2019
D04	Rear Hall O/S Bedrooms	Notifier	NP-100		3/22/2019
D06	Dorm Room 6	Notifier	NP-100		3/22/2019
D08	Hallway O/S Dorm 2	Notifier	NP-100		3/22/2019
Valve Tamper Switch					
M11	Sprinkler Bypass Tamper				3/22/2019
M13	Sprinkler Main Tamper				3/22/2019

## Alarm Notification Appliance

ADDRESS	DESCRIPTION	Manufacturer	Model	SERIAL	INSTALL DATE
Audible					
	Dorm Room 2	System Sensor			3/22/2019
	Dorm Room 6	System Sensor			3/22/2019
	Dorm Room 3	System Sensor			3/22/2019
	Dorm Room 5	System Sensor			3/22/2019
	Dorm Room 4	System Sensor			3/22/2019
	Dorm Room 1 (Captain)	System Sensor			3/22/2019
Audible And Visible					

Norris Inc

ADDRESS	DESCRIPTION	Manufacturer	Model	SERIAL	INSTALL DATE
	PPE Storage Wash Room	System Sensor			3/22/2019
	Exercise Room 108	System Sensor			3/22/2019
	Hallway 113	System Sensor			3/22/2019
	PPE Storage Wash Room	System Sensor			3/22/2019
	Hallway 104 O/S Dorm 1	System Sensor			3/22/2019
	Main Entry Vestibule	System Sensor			3/22/2019
	Hallway 104	System Sensor			3/22/2019
	Hallway 104 O/S Exercise Room	System Sensor			3/22/2019
	Hallway 113 O/S Bedrooms	System Sensor			3/22/2019
	Living Room	System Sensor			3/22/2019

Visible					
	Mens Room 112	System Sensor			3/22/2019
	Womens Room 111	System Sensor			3/22/2019
	Toilet 120	System Sensor			3/22/2019

### Supervising Station Transmitting Equipment

ADDRESS	DESCRIPTION	Manufacturer	Model	SERIAL	INSTALL DATE
Radio Alarm Transmitter					
	AES Citybox	AES			3/22/2019

### Combination System

ADDRESS	DESCRIPTION	Manufacturer	Model	SERIAL	INSTALL DATE
CO Detector					
M04	Rear Hallway O/S Bedrooms	System Sensor			3/22/2019
M06	Hallway O/S Dorm 2	System Sensor	CO-1224		3/22/2019

### Emergency Control Equipment

ADDRESS	DESCRIPTION	Manufacturer	Model	SERIAL	INSTALL DATE
Kitchen Hood Shunt					
M07	Kitchen Hood Shunt Trip	Notifier	NC-100R		3/22/2019
VOC output					
M09	VOC System Trip	Notifier	NC-100R		3/22/2019



# Supplementary Information

## Interconnected Systems

## Monitoring Information

TYPE	Radio Alarm Transmitter	DESCRIPTION	AES Citybox
ORGANIZATION NAME		ACCOUNT NUMBER	
ORGANIZATION ADDR.		PHONE LINE 1	
ORGANIZATION PHONE		PHONE LINE 2	
ORGANIZATION EMAIL		ENTITY TO RETRANSMIT ALARMS TO	