

City of Portland, Maine – Building or Use Permit Application 389 Congress Street, 04101, Tel: (207) 874-8703, FAX: 874-8716

Location of Construction: 32 Auburn St		Owner: Edward Daniel Robertson Trs		Phone:		Permit No:
Owner Address:		Lessee/Buyer's Name: Lib's Dairy Treats 32 Auburn St Portland, ME 04103		Phone: 797-6252		
Contractor Name: Sign Solutions		Address:		Phone:		Permit Issued:
Past Use: Retail Food		Proposed Use: Same		COST OF WORK: \$		
Proposed Project Description: Erect Signage as per plans		Signature:		FIRE DEPT. <input type="checkbox"/> Approved <input type="checkbox"/> Denied		INSPECTION: Use Group: Type:
				Signature:		Signature:
Permit Taken By: Mary Gresik		Date Applied For: 04 September 1997		PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.) Action: Approved <input type="checkbox"/> Approved with Conditions: <input type="checkbox"/> Denied <input type="checkbox"/>		Zoning Approval: Special Zone or Reviews: <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan maj <input type="checkbox"/> minor <input type="checkbox"/> mm <input type="checkbox"/>
				Signature: Date:		

1. This permit application does not preclude the Applicant(s) from meeting applicable State and Federal rules.
2. Building permits do not include plumbing, septic or electrical work.
3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..

CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit

Matthew Pawloski
SIGNATURE OF APPLICANT Matt Pawloski ADDRESS: DATE: 04 September 1997 PHONE:

RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE PHONE:

White-Permit Desk Green-Assessor's Canary-D.P.W. Pink-Public File Ivory Card-Inspector

Zone: CBL: 375-E-001

CEO DISTRICT

SIGNAGE

PLEASE ANSWER ALL QUESTIONS

Address: 32 AUBURN ST. Zone: B-1

Owner: RUTH LIBBY Assessors #: _____

Applicant: SAME

Single Tenant Lot?: Yes No _____

Multi Tenant Lot?: Yes _____ No _____

Freestanding (Ext pole sign)? Yes No _____ Dimensions 8' x 8' x 2' = 64'

More than (1) one sign?: Yes _____ No Dimensions _____

Bldg Wall Sign (att to bldg)? Yes _____ No Dimensions _____

List all existing signage and their dimensions:

THIS IS THE ONLY SIGN ON THE PROPERTY . This is an existing pole sign only replacing the panel

Lot Frontage(feet): 631 Tenant Frontage(feet): 631

AWNINGS


Awning?: Yes _____ No Is Awning Backlit?: Yes _____ No _____

Is there any communication, message, trademark or symbol on awning? _____

Height of Awning?: _____

PLEASE NOTE: Approvals for signs on the Public Sidewalk and temporary signs under different requirements and regulations.

See reverse side for additional information, requirements and materials needed for signage application submittal.



8'-0"

5'-0"

LIB'S

DAIRY TREATS

SUNDAES · SHAKES · SPLITS

3'-0"

4'-2"

ON THE WALL

10'



DATE: 8/9/97	SCALE: 1/2"=1'-0"
DWG NO: 1	DESIGNER: Steve Emma
CLIENT: Lib's Dairy Treat	
LOCATION:	

REVISION:
2

APPROVED:
B.P.

1 - D/F Pan-Face Replacement

Faces: White Poles:
Copy: Black, Rose, Dk. Aqua

Materials: Vacuum-Formed Lexan Faces
Vinyl Copy & Graphics

PACIFIC LIGHT FLUORESCENT

BUILDING PERMIT REPORT

DATE: 12-Sept-97 ADDRESS: 32 Auburn ST.
REASON FOR PERMIT: To Erect Signage
BUILDING OWNER: Edward Daniel Robertson TRS
CONTRACTOR: Sign Solution
PERMIT APPLICANT: Matt Pawloski APPROVAL: *1 ~~DENIED~~
USE GROUP _____ BOCA 1996 CONSTRUCTION TYPE _____

CONDITION(S) OF APPROVAL

1. This permit does not excuse the applicant from meeting applicable State and Federal rules and laws.
2. Before concrete for foundation is placed, approvals from the Development Review Coordinator and Inspection Services must be obtained. (A 24 hour notice is required prior to inspection)
3. Precaution must be taken to protect concrete from freezing.
4. It is strongly recommended that a registered land surveyor check all foundation forms before concrete is placed. This is done to verify that the proper setbacks are maintained.
5. Private garages located beneath habitable rooms in occupancies in Use Group R-1, R-2, R-3 or I-1 shall be separated from adjacent interior spaces by fire partitions and floor/ceiling assembly which are constructed with not less than 1-hour fire resisting rating. Private garages attached side-by-side to rooms in the above occupancies shall be completely separated from the interior spaces and the attic area by means of ½ inch gypsum board or the equivalent applied to the garage means of ½ inch gypsum board or the equivalent applied to the garage side. (Chapter 4 Section 407.0 of the BOCA/1996)
6. All chimneys and vents shall be installed and maintained as per Chapter 12 of the City's Mechanical Code. (The BOCA National Mechanical Code/1993) U.L. 103.
7. Sound transmission control in residential building shall be done in accordance with Chapter 12 section 1214.0 of the city's building code.
8. Guardrail & Handrails A guardrail system is a system of building components located near the open sides of elevated walking surfaces for the purpose of minimizing the possibility of an accidental fall from the walking surface to the lower level. Minimum height all Use Groups 42" , except Use Group R which is 36". In occupancies in Use Group A, B, H-4, I-1, I-2 M and R and public garages and open parking structures, open guards shall have balusters or be of solid material such that a sphere with a diameter of 4" cannot pass through any opening. Guards shall not have an ornamental pattern that would provide a ladder effect.
9. Headroom in habitable space is a minimum of 7'6".
10. Stair construction in Use Group R-3 & R-4 is a minimum of 10" tread and 7 3/4" maximum rise. All other Use group minimum 11" tread. 7" maximum rise.
11. The minimum headroom in all parts of a stairway shall not be less than 80 inches.
12. Every sleeping room below the fourth story in buildings of use Groups R and I-1 shall have at least one operable window or exterior door approved for emergency egress or rescue. The units must be operable from the inside without the use of special knowledge or separate tools. Where windows are provided as means of egress or rescue they shall have a sill height not more than 44 inches (1118mm) above the floor. All egress or rescue windows from sleeping rooms shall have a minimum net clear opening height dimension of 24 inches (610mm). The minimum net clear opening width dimension shall be 20 inches (508mm), and a minimum net clear opening of 5.7 sq. ft.
13. Each apartment shall have access to two (2) separate, remote and approved means of egress. A single exit is acceptable when it exits directly from the apartment to the building exterior with no communications to other apartment units.
14. All vertical openings shall be enclosed with construction having a fire rating of at least one (1)hour, including fire doors with self closer's.
15. The boiler shall be protected by enclosing with (1) hour fire-rated construction including fire doors and ceiling, or by providing automatic extinguishment.
16. All single and multiple station smoke detectors shall be of an approved type and shall be installed in accordance with the provisions of the City's Building Code Chapter 9, Section 19, 920.3.2 (BOCA National Building Code/1996), and NFPA 101 Chapter 18 & 19. (Smoke detectors shall be installed and maintained at the following locations):
 - In the immediate vicinity of bedrooms
 - In all bedrooms
 - In each story within a dwelling unit, including basements