

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that

A & D REALTY LLC

Located at

91 AUBURN ST

PERMIT ID: 2015-01756

ISSUE DATE: 09/14/2015

CBL: 375 C001001

has permission to **Interior alterations to existing space for nurse practitioner office. Interior remodel to include accessibility improvements and creation of two small offices.**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statutes of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Keith Gautreau

/s/ Tammy Munson

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

Building Inspections

Fire Department

CVS - Retail, pharmacy, and nurse
practioners office

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

**Check the Status or Schedule an Inspection On-Line at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

REQUIRED INSPECTIONS:

Close-in Plumbing/Framing

Electrical - Commercial

Final Inspection

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No: 2015-01756	Date Applied For: 07/22/2015	CBL: 375 C001001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Adding Nurse Practitioner Office to retail space	Proposed Project Description: Interior alterations to existing space for nurse practitioner office. Interior remodel to include accessibility improvements and creation of two small offices.			
Dept: Zoning Status: Approved w/Conditions Reviewer: Christina Stacey Approval Date: 09/04/2015				
Note:				Ok to Issue: <input checked="" type="checkbox"/>
Conditions:				
1) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.				
2) Separate permits shall be required for any new signage.				
Dept: Building Inspecti Status: Approved w/Conditions Reviewer: Tammy Munson Approval Date: 09/11/2015				
Note:				Ok to Issue: <input checked="" type="checkbox"/>
Conditions:				
1) Separate Permits shall be required for any new signage.				
2) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems, fire suppression and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.				
3) This project includes alterations that Maine state law requires for compliance with the 2010 ADA Standards for Accessible Design.				
4) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.				
Dept: Engineering DPS Status: Not Applicable Reviewer: Approval Date: 07/27/2015				
Note:				Ok to Issue: <input checked="" type="checkbox"/>
Conditions:				
1) This approval is non-applicable to Engineering DPS as it relates to approval for Grease Control Equipment for the Fats, Oil, and Grease Program. If approval is needed for this project by the Engineering Department of Public Services for any other reason than FOG, please contact David Margolis-Pineo at 207-874-8850 or dmp@portlandmaine.gov				
Dept: Fire Status: Approved w/Conditions Reviewer: Keith Gautreau Approval Date: 09/11/2015				
Note:				Ok to Issue: <input type="checkbox"/>
Conditions:				
1) Installation of a sprinkler or fire alarm system requires a Knox Box to be installed per city ordinance.				
2) A separate Suppression System Permit is required for all new suppression systems, including standpipe systems, and sprinkler work effecting more than 20 heads. This review does not include approval of system design or installation.				
3) All means of egress to remain accessible at all times.				
4) A separate Fire Alarm Permit is required for new systems; or for work effecting more than 5 fire alarm devices; or replacement of a fire alarm panel with a different model. This review does not include approval of fire alarm system design or installation.				

5) All construction shall comply with City Code Chapter 10.

<http://www.portlandmaine.gov/citycode/chapter010.pdf>

A separate Fire Alarm Permit is required for new systems; or for work effecting more than 5 fire alarm devices; or replacement of a fire alarm panel with a different model. This review does not include approval of fire alarm system design or installation.

A separate Suppression System Permit is required for all new suppression systems or sprinkler work effecting more than 20 heads. This review does not include approval of sprinkler system design or installation.

Shall meet the requirements of 2009 NFPA 1 Fire Code.

Shall meet the requirements the most recent NFPA 30 Flammable and Combustible Liquids Code.

Shall meet the requirements the most recent NFPA 30A Code for Motor Fuel Dispensing Facilities and Repair Garages.

Shall have State Fire Marshall Permit.

Shall have DEP Permit.