

LIGHTING FIXTURE SCHEDULE									
ALL FIXTURES SHALL BE FURNISHED COMPLETE WITH ALL HARDWARE LAMPS, HANGERS, FITTINGS, ETC. FOR A COMPLETE AND PROPER INSTALLATION									
TYPE	MANUFACTURER	CATALOG NO.	MTG.	VOLT	LAMPS			REMARKS/BALLAST INFORMATION	
					NO.	WATT	TYPE		
A	HIGH BAY - ALUMINUM REFLECTOR DAY-BRITE	HCF642CU-A24CF	P	120	6	42W	CFL		
B	2' X 2' - PARABOLIC COLUMBIA	P422-317G-33-EU	R	120	3	17W	F17T8		
C	TRACK HEAD HALO	L1701MB-L283MB	S	120	1	50W	PAR20		
D	6" DOWNLIGHT CFL PRESCOLITE	LF6CFV42-6CFV-WT-B24	R	120	1	42W	CFL		
E	DECORATIVE PENDANT - FISHER ISLAND FORECAST	F1852-68	P	120	4	26W	CFL	PROVIDE WITH SAFARI FABRIC SHADE AND ETCHED GLASS - MOUNT BOTTOM UP 8'AFF	
E1	DECORATIVE PENDANT - URBAN OASIS FORECAST	F510-49	P	120	2	26W	CFL	PROVIDE WITH BEIGE ARTISAN PAPER SHADE AND ETCHED GLASS - MOUNT BOTTOM UP 8'AFF	
F	DECORATIVE VANITY LITHONIA	11890 2' GEB 10IS	S	120	2	17W	F17T8	MOUNT ABOVE MIRROR	
G	4' STRIP COLUMBIA	K4-232-EU	S	120	2	32W	F32T8		
H	MINI SCONCE - CFL GARDCO	111EMC-MT-26QF-120-BRP-PCB	S	120	1	26W	CFL	CENTER ABOVE DOOR	

FIRE ALARM SYSTEM NOTE

THESE DOCUMENTS DO NOT FULLY COMPLY WITH THE REQUIREMENTS OF THE CITY OF PORTLAND FIRE DEPARTMENT. ADDITIONAL INFORMATION FOR FIRE ALARM SYSTEM EXTENSION THROUGHOUT THE PLAZA WILL BE REQUIRED TO FINALIZE SYSTEM DESIGN.

GENERAL NOTE

ELECTRICAL CIRCUITS INDICATED SHALL BE RUN TO OWNER PROVIDED PANEL IN ANYTIME FITNESS. COORDINATE EXACT PANEL LOCATION.

LEGEND

LP-1,3	HOMERUN TO PNLBRD - ARROWS INDICATE NUMBER OF CIRCUITS. CROSS LINES INDICATE NUMBER OF CONDUCTORS OTHER THEN TWO.
↑	CIRCUIT NUMBER(S)
—	PANEL DESIGNATION
—	WIRING CONCEALED IN WALL OR CEILING
----	WIRING IN EXPOSED RACEWAY
----	WIRING IN RACEWAY CONCEALED UNDER FLOOR
- UG -	WIRING IN RACEWAY CONCEALED UNDERGROUND
- UD -	WIRING IN UNDER FLOOR DUCT
----	ITEMS SHOWN DASED ARE EXISTING
- E -	EXISTING WIRING
□	2' x 4' FLUORESCENT FIXTURE
□	1' x 4' FLUORESCENT FIXTURE
□	1' x 8' FLUORESCENT FIXTURE
□	4' x 6" FLUORESCENT FIXTURE
□	8' x 6" FLUORESCENT FIXTURE
□	2' x 2' FLUORESCENT FIXTURE
○	WALL MOUNTED FIXTURE
○	CEILING MOUNTED FIXTURE
□	RECESSED MOUNTED FIXTURE
S	SINGLE POLE SWITCH - MTD CL UP 4'-0"
S ₂	DOUBLE POLE SWITCH - MTD CL UP 4'-0"
S ₃	THREE-WAY SWITCH - MTD CL UP 4'-0"
S	DIMMER SWITCH - MTD CL UP 4'-0"
□	SERVICE SWITCH
○	SIMPLEX RECEPTACLE - CL UP 15" OR AS NOTED
○	DUPLEX CONVENIENCE RECEPTACLE - MOUNTED - CL UP 18" OR AS NOTED
○	DUPLEX CONVENIENCE RECEPTACLE - MOUNTED CL UP 48" OR AS NOTED
○	GFCI DUPLEX CONVENIENCE RECEPTACLE - MOUNTED CL UP 48" OR AS NOTED
○	DOUBLE DUPLEX RECEPTACLE IN TWO GANG WALL BOX - CL UP 18" OR AS NOTED
□	TELEPHONE & DATA OUTLET IN SINGLE GANG WALL BOX- MOUNTED CL UP SAME AS ASSOCIATED RECEPTACLE
□	TELEPHONE ONLY OUTLET - MOUNTED CL UP SAME AS ASSOCIATED DUPLEX RECEPTACLE, W= WALL CL UP 46"
○	FLOOR MOUNTED DUPLEX RECEPTACLE - SEE PEDESTAL OR FLUSH FLOOR OUTLET DETAIL
□	TELEPHONE/DATA OUTLET - MOUNTED UP SAME AS ASSOCIATED RECEPTACLE
□	DATA OUTLET
□	MODEM OUTLET
□	JUNCTION BOX - SIZE AS REQUIRED OR AS INDICATED
□	TELEPHONE (TEL) OR DATA (IDF) BACKBOARD - SIZE AS INDICATED
■	LIGHTING/POWER PANELBOARD
■	EXISTING PANELBOARD
□	POWER COMPANY METER
-----	FIRE ALARM DEVICES -----
M	MASTER FIRE BOX - COORDINATE WITH LOCAL FIRE DEPARTMENT FOR REQUIREMENTS
ANN	FIRE ALARM ANNUNCIATOR PANEL
□	FIREMANS KEY BOX
FACP	FIRE ALARM CONTROL PANEL
○	SMOKE DETECTOR - MOUNTED ON CEILING
○	DUCT DETECTOR WITH SAMPLING TUBE - "S" = SUPPLY & "R" = RETURN
□	FIRE ALARM HORN/LIGHT UNIT. CANDLE POWER (CD) PER NFPA 72 AND AS NOTED - MOUNTED BOTTOM OF STROBE UP 80" ON WALL
□	FIRE ALARM STROBE LIGHT UNIT. CANDLE POWER (CD) PER NFPA 72 AND AS NOTED - MOUNTED BOTTOM OF STROBE UP 80" ON WALL
□	FIRE ALARM MINI-HORN/LIGHT UNIT. CANDLE POWER (CD) PER NFPA 72 AND AS NOTED - MOUNTED BOTTOM OF STROBE UP 80" ON WALL
□	FIRE ALARM MANUAL PULL STATION - MOUNTED CL UP 4'-0" ON WALL
FCPS	FIRE ALARM APPLIANCE/DEVICE POWER SUPPLY
SFS	SPRINKLER FLOW SWITCH
STS	SPRINKLER TAMPER SWITCH
-----	EMERGENCY LIGHTING DEVICES -----
□	EXIT SIGN WITH ARROWS AS INDICATED - CEILING MOUNTED, EXCEPT AS NOTED
□	EXIT SIGN WITH ARROWS AS INDICATED - WALL MOUNTED TIGHT TO CEILING, EXCEPT AS NOTED
□	EMERGENCY LIGHTING WITH BATTERY UNIT - WALL MOUNTED UP 7'-6". DUALLITE LZ-20-N
□	EMERGENCY LIGHTING REMOTE HEAD WITH NUMBER OF HEADS AS INDICATED - MOUNTED UP 7'-6". NUMERAL INDICATES BATTERY UNIT CONNECTED TO.

-----	MISCELLANEOUS -----
CP	CONTROL PANEL
DS	DOOR SWITCH
DL	DOOR LOCK
ISD	INTRUSION DETECTION SECURITY PANEL
EDH	ELECTRIC DOOR HOLDER
MD	MOTION DETECTOR - MOUNTED UP 7'-6" ON WALL
AKP	ACCESS KEY PAD - MOUNTED UP 4'-6" ON WALL
TCO	TELEVISION COAXIAL OUTLET - MOUNTED UP SAME AS ASSOCIATED RECEPTACLE
RC	RELAY OR CONTACTOR - SIZE AS REQUIRED OR AS INDICATED
WP	WEATHER PROOF
KT	KEYNOTE TAG
EL	EQUIPMENT LABEL - SEE EQUIPMENT SCHEDULE FOR WIRING REQUIREMENTS. VERIFY EXACT LOCATION WITH ASSOCIATED PLAN.
C	- INDICATES CEILING MOUNTED

HARRIMAN
Architects + Engineers

46 Harriman Drive
Portland, ME 04210
707.754.5100 tel

18 Middle Street
Portland, ME 04101
207.775.0053 tel

One Parimeter Road
Manchester, NH 03103
603.626.1242 tel


www.harriman.com
© 2011

STATE OF MAINE
LICENSED PROFESSIONAL ENGINEER
PHILIP R. HARRISSETTE
No. 3917

Project Title
WESTGATE SHOPPING CENTER ANYTIME FITNESS
PORTLAND, MAINE

HA Project No. **11110**

Key Plan



Mark	Date	Description
-	07-13-11	ISSUED FOR CONSTRUCTION
-	06-13-11	95% REVIEW

Issue Dates

Drawing Status

Drawing Title
ELECTRICAL SCHEDULES & LEGEND

PA / PE: **JWT** Drawn By: **JWT**

Drawing Number
E00.1