

375 0001

SimplexGrinnell

BE SAFE.

A Tyco International Company

RANGE HOOD SYSTEMS REPORT

20 Thomas Drive
Westbrook, ME 04092
P 207-842-8440 F 207-842-8439

Customer: Little Cakes
Address: 91 Auburn St
Portland, ME
Attention: _____
Phone: (____) _____
Fax: (____) _____

Date of Service <u>12/14/11</u>		Time <u>7:30</u>		AM	PM
Annual	Semi-Annual	Recharge	Installation	Renovation	Other
			<input checked="" type="checkbox"/>		
Location of System Cylinders <u>Rt end of Appliance & Hood</u>					
Manufacturer <u>Amsul</u>		Model <u>K102</u>		Wet	Dry Chemical
		<input checked="" type="checkbox"/>			
Cylinder Size (Master) <u>1.5g.</u>		Cylinder Size (Slave)		Cylinder Size (Slave)	
Fuse Links 360°F Qty. <u>2</u>		Fuse Links 450°F Qty. _____		Fuse Links 500°F Qty. _____	
Other		Other		Other	
Fuel Shut Off <input checked="" type="checkbox"/>		Electric		Gas <u>mech.</u>	
Serial Number		Last Hydro Test Date <u>2011</u>		Last Recharge Date	

COOKING APPLIANCE SIZES (NOTE: List appliances from left to right and indicate nozzles used for each)

Plenum Size(s)	<u>2-IN</u>		
Duct Size(s)	<u>3 Tier Pizza Oven</u>		

- | | | | |
|--|-------------------------------------|---|-------------------------------------|
| 1. All appliances properly covered w/correct nozzles | <input checked="" type="checkbox"/> | 19. Check travel of cable nuts/S-hooks | <input checked="" type="checkbox"/> |
| 2. Duct and plenum covered w/correct nozzles | <u>N/A</u> | 20. Piping and conduit securely bracketed | <input checked="" type="checkbox"/> |
| 3. Check positioning of all nozzles | <input checked="" type="checkbox"/> | 21. Proper separation between fryers and flame | <u>N/A</u> |
| 4. System installed in accordance w/Mfg UL listing | <input checked="" type="checkbox"/> | 22. Proper clearance—flame to filters | <input checked="" type="checkbox"/> |
| 5. Hood/duct penetrations sealed w/weld or UL device | <input checked="" type="checkbox"/> | 23. Exhaust fan operating properly | <input checked="" type="checkbox"/> |
| 6. Check if seals intact, evidence of tampering | <input checked="" type="checkbox"/> | 25. All filters reinstalled | <input checked="" type="checkbox"/> |
| 7. If system has been discharged, report same | <u>N/A</u> | 25. Fuel shut-off in ON position | <input checked="" type="checkbox"/> |
| 8. Pressure gauge in proper range (if gauged) | <u>N/A</u> | 26. Manual and remote set/seals in place | <input checked="" type="checkbox"/> |
| 9. Check cartridge weight (replace, if needed) | <input checked="" type="checkbox"/> | 27. Replace systems covers | <input checked="" type="checkbox"/> |
| 10. Hydrostatic/6 year maintenance date | <u>2023</u> | 28. System operational and seals in place | <input checked="" type="checkbox"/> |
| 11. Inspect cylinder and mount | <input checked="" type="checkbox"/> | 29. Slave system operational | <u>N/A</u> |
| 12. Operate system from terminal link | <input checked="" type="checkbox"/> | 30. Clean cylinder and mount | <input checked="" type="checkbox"/> |
| 13. Test for proper operation from remote | <input checked="" type="checkbox"/> | 31. Fan warning sign on hood | <input checked="" type="checkbox"/> |
| 14. Check operation of micro switch | <input checked="" type="checkbox"/> | 32. Personnel instructed in manual operation of system | <input checked="" type="checkbox"/> |
| 15. Check operation of gas valve | <input checked="" type="checkbox"/> | 33. Proper hand portable extinguishers
(K Class and ABC) | <input checked="" type="checkbox"/> |
| 16. Proper nozzle covers in place/clean nozzles | <input checked="" type="checkbox"/> | 34. Portable extinguishers properly serviced | <input checked="" type="checkbox"/> |
| 17. Check fuse links and clean | <input checked="" type="checkbox"/> | 35. Service and certification tag on system | <input checked="" type="checkbox"/> |
| 18. Replaced fusible links (record date here) | <u>12/10/11</u> | | |

NOTE DISCREPANCIES OR DEFICIENCIES 1. Pull test performed on 12/12/11
2. Fire Alarm tested with Morris on 12/14/11.

IMPORTANT NOTICE TO CUSTOMER

Customer acknowledges and agrees to the terms and conditions on the reverse side of this Range Hood Systems Report, agrees that the services have been completed to Customer's satisfaction and that the system is in good working order and repair, unless services performed were of a temporary nature, in which case Customer acknowledges that part of customer's system may have been bypassed or is otherwise inoperable until service can be completed.

CUSTOMER'S ATTENTION IS DIRECTED TO THE LIMITATION OF LIABILITY, WARRANTY, INDEMNITY AND OTHER CONDITIONS ON THE REVERSE SIDE.

Acceptance of customer or customer's representative

Service Technician <u>Roger Blanchette</u>	Date <u>12/14/11</u>	Time <u>8:00</u>	AM	PM	Customer's Authorized Agent <u>[Signature]</u>
---	-------------------------	---------------------	----	----	---

TOTAL SERVICE	
TOTAL SALES	
LABOR or FRT or TRIP CHARGE	
GRAND TOTAL	