



**DEPARTMENT OF PUBLIC SAFETY  
OFFICE OF STATE FIRE MARSHAL  
FIRE SPRINKLER DIVISION**

## CASCO BAY QUALITY HOMES

### LIMITED FIRE SPRINKLER PERMIT

Permit Number: LSP13435  
 Status: [Closed and Verified](#)  
 First Licensure: 10/10/2017  
 Expiration Date: 02/20/2018

Street Location Address: 127 BRAMBLEWOOD DRIVE  
 UNIT A-1  
 PORTLAND, ME 04112

#### History

License Type	Start Date	End Date
LIMITED FIRE SPRINKLER PERMIT	10/10/2017	02/19/2018

#### Contractor [\(1 record\) hide](#)

Name	Issue Date	License Number	License Status	License Cancel Date
<a href="#">TIM DAVIS MECHANICAL</a>	10/10/2017	LSC1069	<a href="#">Active</a>	

#### Managing Supervisor [\(1 record\) hide](#)

Name	Issue Date	License Number	License Status	License Cancel Date
<a href="#">THOMAS J. KILLEEN</a>	10/10/2017	RMS351	<a href="#">Active</a>	

### GENERAL INFORMATION

Type of Sprinkler Work: New System(s)  
 Type of Building/Structure Work: New Construction  
 Primary Building Use: Residential  
 Building Use Layout: Single Use  
 New fire sprinkler head(s): 24  
 Relocated existing head(s): 0  
 Dwelling units of each NFPA 13D: 1  
     NFPA 13D  
     2 to 5 Head Calc  
     Light  
     Wet  
 Date of Last Test: 07/17/1990  
     Static: 54  
     Residual: 45  
     Flow: 804  
 Type of Water Test: Single Hydrant Test  
 Project Comments: Per attached PDF from Portland, ME - Water District @ POD-HYD01430 (WS005320)

Warning: Despite our efforts to be accurate, these pages may contain errors. We present this website to you with a good-faith representation that the information it contains is generally reliable. Information on this site should not be relied upon for legal purposes. If you need further information, we would encourage you to contact us directly (207-626-3880).

Date: 02/20/2018 06:21:51 PM