

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND

BUILDING PERMIT

This is to certify that
DKC Properties LLC
#5 Rear Industry RD
SOUTH PORTLAND, ME 04106

For installation at
TBA SUMAC ST

CBL: 378- A-022-001

Job ID: 2012-04-3820-SF

has permission to install an NFPA 13D sprinkler system for single-family provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statutes of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be

Fire Prevention Officer

J. G. B. Wallace

Code Enforcement Officer / Plan Reviewer

THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
PENALTY FOR REMOVING THIS CARD

BUILDING PERMIT INSPECTION PROCEDURES

Please call 874-8703 or 874-8693 (ONLY)

or email: buildinginspections@portlandmaine.gov

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**

Final Fire

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.



PORTLAND MAINE

Strengthening a Remarkable City, Building a Community for Life • www.portlandmaine.gov

Director of Planning and Urban Development
Penny St. Louis

Job ID: 2012-04-3820-SF
install NFPA 13D sprinkler system for
single-famil

For installation at:
0 SUMAC ST

CBL: 378- A-022-001

Conditions of Approval:

Fire

1. The sprinkler system shall be installed in accordance with NFPA 13D. A compliance letter is required.
2. All control valves shall be supervised in accordance with NFPA 13D. Pad locks shall only be installed on valves designed to be secured in the open position by pad lock.
3. Application requires State Fire Marshal approval.

City of Portland, Maine - Building or Use Permit Application

389 Congress Street, 04101 Tel: (207) 874-8703, FAX: (207) 8716

Job No: 2012-04-3820-SF 2012-43820-FSS	Date Applied: 5/11/2012	CBL: 378-A-022-001	
Location of Construction: 0 SUMAC ST	Owner Name: BRENT D BRAASCH	Owner Address: 25 SUMAC ST PORTLAND, 04103 ME - MAINE	Phone:
Business Name:	Contractor Name: SPB Plumbing & Heating	Contractor Address:	Phone: (207) 252-0698
Lessee/Buyer's Name: DKC Properties LLC-Duane Christian	Phone: (207) 749-2236	Permit Type: FSS-Fire Suppression	Zone: R-2
Past Use: New Single family home	Proposed Use: Same - new single family home - install sprinkler system	Cost of Work:	CEO District:
		Fire Dept: 5/28/12 Signature: <i>[Signature]</i> (SB)	Inspection: Use Group: Type: Signature:
Proposed Project Description: install fire sprinkler		Pedestrian Activities District (P.A.D.)	

Permit Taken By:	Zoning Approval		
<p>1. This permit application does not preclude the Applicant(s) from meeting applicable State and Federal Rules.</p> <p>2. Building Permits do not include plumbing, septic or electrical work.</p> <p>3. Building permits are void if work is not started within six (6) months of the date of issuance. False informatin may invalidate a building permit and stop all work.</p>	Special Zone or Reviews <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetlands <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan <input type="checkbox"/> Maj <input type="checkbox"/> Min <input type="checkbox"/> MM Date: OK 5/11/12 <i>ABN</i>	Zoning Appeal <input type="checkbox"/> Variance <input type="checkbox"/> Miscellaneous <input type="checkbox"/> Conditional Use <input type="checkbox"/> Interpretation <input type="checkbox"/> Approved <input type="checkbox"/> Denied Date:	Historic Preservation <input checked="" type="checkbox"/> Not in Dist or Landmark <input type="checkbox"/> Does not Require Review <input type="checkbox"/> Requires Review <input type="checkbox"/> Approved <input type="checkbox"/> Approved w/Conditions <input type="checkbox"/> Denied Date: <i>ABN</i>
	CERTIFICATION		

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provision of the code(s) applicable to such permit.

SIGNATURE OF APPLICANT	ADDRESS	DATE	PHONE
RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE		DATE	PHONE

Parent - 2012-04-3820
Child# - 2012-43829

One- or Two-family Fire Sprinkler Permit

If you or the property owner owes real estate or property taxes or user charges on any property within the city, payment arrangements must be made before permits of any kind are accepted.

Installation address: "25A" Sumac St.

Building owner: DKC Properties LLC. Phone: 749-2236

Installer: SPB Plumbing & Heating Phone: 252-0698

Total sq/ft of building floor space per unit: 1664 sq ft Single-family home
or

Sq/ft of sprinklered floor space per unit: _____ Two-family home

Is this a multipurpose piping system? / N Sprinkler piping uses Pex? / N

Water supply: Municipal Water Well pump Stored water Other

Include electronic copy of approved State Sprinkler Permit plans:

Additional cost to the owner for the home fire sprinkler system for each dwelling unit minus costs necessary for domestic needs (See below): **A =** 5800

Attach cost breakdown:

A City plumbing permit has been pulled:

RECEIVED

MAY 11 2012

Dept. of Building Inspections
City of Portland Maine

COST OF WORK: 5800
(A times number of units)

NO FEE REQUIRED

Additional information and Frequently asked questions about home fire sprinkler systems may be found at

www.portlandmaine.gov/fireprevention.

Sprinkler system cost must deduct costs that would have been incurred if the system did not provide sprinkler service. In a well pump system it would include the difference between the well pump to be installed and the one that would have been installed if there were no sprinkler demand on the system. Includes additional piping and valves that are required only because of NFPA Standard 13D, and not already required for domestic needs. Includes cost of sprinkler heads and additional installation costs.

Uponor

AQUASAFE® Fire Safety System

Uponor
5925 148th Street West

Apple Valley, MN 55124
800-321-4739



Handwritten signature and date: 3-7-12

Job Name : 25A SUMAC - One Head Calculation (H.16)
Drawing : RESIDENTIAL
Location : 25A SUMAC PORTLAND ME
Remote Area : 1
Contract : 120228-41N
Data File : 120228-41N 25A Sumac.wx1

HYDRAULIC DESIGN INFORMATION SHEET

Name - 25A SUMAC Date - 3/05/12
Location - PORTLAND ME
Building - RESIDENTIAL System No. - 1
Contractor - SPB PLG & HTG Contract No. - 120228-41N
Calculated By - DEVON HUYNH Drawing No. - 1
Construction: (X) Combustible () Non-Combustible Ceiling Height VARIES
OCCUPANCY - RESIDENTIAL

S Type of Calculation: ()NFPA 13 Residential ()NFPA 13R (X)NFPA 13D
Y Number of Sprinklers Flowing: (X)1 ()2 ()4 ()
S ()Other
T ()Specific Ruling Made by Date

E
M Listed Flow at Start Point - 13 Gpm System Type
Listed Pres. at Start Point - 9.14 Psi (X) Wet () Dry
D MAXIMUM LISTED SPACING 16 x 16 () Deluge () PreAction
E Domestic Flow Added - 0 Gpm Sprinkler or Nozzle
S Additional Flow Added - Gpm Make RELIABE-ASSEMBLIES Model AFC43
I Elevation at Highest Outlet - 128 Feet Size 3/8 K-Factor 4.3
G Note: Temperature Rating 155
N

Calculation Gpm Required 13 Psi Required 53.3 At Ref Pt STR
Summary C-Factor Used: Overhead 150 Underground 150

W Water Flow Test: Pump Data: Tank or Reservoir:
A Date of Test - x Rated Cap. Cap.
T Time of Test - x @ Psi Elev.
E Static (Psi) - 80 Elev.
R Residual (Psi) - 75 Other Well
Flow (Gpm) - 300 Proof Flow Gpm
S Elevation - 100

P Location: x
P
L Source of Information: CITY SUPPLY
Y

Water Supply Curve (C)

Uponor
25A SUMAC - One Head Calculation (H.16)


Page 2
Date 3/5/2012

City Water Supply:

C1 - Static Pressure : 80
C2 - Residual Pressure: 75
C2 - Residual Flow : 300

Demand:

D1 - Elevation : 12.127
D2 - System Flow : 12.9999
D2 - System Pressure : 53.303
Hose (Adj City) : _____
Hose (Demand) : _____
D3 - System Demand : 12.9999
Safety Margin : 26.682



Fittings Used Summary

Uponor
25A SUMAC - One Head Calculation (H.16)

Page 3
Date 3/5/2012

Fitting Legend		½	¾	1	1¼	1½	2	2½	3	3½	4	5	6	8	10	12	14	16	18	20	24	
Abbrev.	Name																					
E	90' Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61	
G	Generic Gate Valve	1	1	1	1	1	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13	
R	CPVC Coupling Tee - Run	1	1	1	1	1	1	2	2	0	0	0	0	0	0	0	0	0	0	0	0	
T	90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121	
U	UnAdjusted Fitting	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	
Utb	Aquapex Tee - Branch	2	6	6	9.08	12.88	13.22	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
Utr	Aquapex Tee - Run	1	2	2	1.64	2.39	2.39	0	0	0	0	0	0	0	0	0	0	0	0	0	0	

Units Summary

Diameter Units Inches
 Length Units Feet
 Flow Units US Gallons per Minute
 Pressure Units Pounds per Square Inch

Flow Summary - NFPA 2007

Uponsor
25A SUMAC - One Head Calculation (H.16)

Page 4
Date 3/5/2012

SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
STR	80.0	75	300.0	79.985	13.0	53.303

NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
H.16	128.0	4.3	9.14	13.0	
H.12	128.0		17.39		
H.2	128.0		19.09		
H.3	128.0		19.0		
H.4	128.0		19.12		
H.9	118.0		24.43		
M.22	128.0		19.3		
H.1	128.0		19.04		
T.23	128.0		18.16		
H.7	128.0		18.97		
M.25	108.0		30.0		
H.5	108.0		29.57		
H.8	118.0		24.4		
H.6	108.0		29.52		
H.10	128.0		17.36		
H.13	108.0		29.48		
T.24	108.0		30.03		
M.27	118.0		24.53		
T.26	118.0		24.54		
H.17	118.0		24.1		
H.11	128.0		17.4		
T.30	128.0		13.39		
H.15	118.0		24.53		
H.14	118.0		24.57		
T.28	118.0		24.46		
H.20	108.0		29.61		
T.29	128.0		13.27		
H.19	108.0		29.54		
T.33	118.0		24.53		
H.18	128.0		17.4		
T.31	118.0		24.31		
T.32	118.0		24.1		
H.21	118.0		24.1		
T.34	118.0		23.19		
S.1	104.0		32.46		
MTR	100.0		40.75		
STR	100.0		53.3		

Final Calculations - Hazen-Williams

Uponor
25A SUMAC - One Head Calculation (H.16)

Page 5
Date 3/5/2012

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
H.16 to H.12	3.28	0.475 150.0	42U	42.0 0.0	15.000 42.300	9.140 0.0			K Factor = 4.30	
	3.28	0.1440		0.0	57.300	8.254			Vel = 5.94	
	0.0 3.28					17.394			K Factor = 0.79	
H.2 to H.1	-0.18	0.475 150.0	42U	42.0 0.0	22.000 42.300	19.086 0.0				
	-0.18	-0.0007		0.0	64.300	-0.043			Vel = 0.33	
	0.0 -0.18					19.043			K Factor = -0.04	
H.3 to H.1	0.20	0.475 150.0	42U	42.0 0.0	10.000 42.300	18.999 0.0				
	0.2	0.0008		0.0	52.300	0.044			Vel = 0.36	
	0.0 0.20					19.043			K Factor = 0.05	
H.4 to H.1	-0.28	0.475 150.0	42U	42.0 0.0	8.000 42.300	19.118 0.0				
	-0.28	-0.0015		0.0	50.300	-0.075			Vel = 0.51	
	0.0 -0.28					19.043			K Factor = -0.06	
H.9 to H.4	-1.02	0.475 150.0	42U	42.0 0.0	17.000 42.300	24.431 -4.331				
	-1.02	-0.0166		0.0	59.300	-0.982			Vel = 1.85	
H.4 to H.3	0.68	0.475 150.0	42U	42.0 0.0	12.000 42.300	19.118 0.0				
	-0.34	-0.0022		0.0	54.300	-0.119			Vel = 0.62	
	0.0 -0.34					18.999			K Factor = -0.08	
M.22 to H.3	-0.76	0.475 150.0	1T 21U	1.219 21.0	9.000 22.369	19.301 0.0				
	-0.76	-0.0096		0.0	31.369	-0.302			Vel = 1.38	
	0.0 -0.76					18.999			K Factor = -0.17	
H.1 to H.7	-0.26	0.475 150.0	42U	42.0 0.0	16.000 42.300	19.043 0.0				
	-0.26	-0.0013		0.0	58.300	-0.075			Vel = 0.47	
	0.0 -0.26					18.968			K Factor = -0.06	
T.23 to H.2	1.33	0.475 150.0	1R 21U	1.0 21.0	11.000 23.150	18.156 0.0				
	1.33	0.0272	1Utr	1.0	34.150	0.930			Vel = 2.41	
	0.0 1.33					19.086			K Factor = 0.30	
M.22 to H.2	-0.55	0.475 150.0	1T 21U	1.219 21.0	18.000 22.369	19.301 0.0				
	-0.55	-0.0053		0.0	40.369	-0.215			Vel = 1.00	
H.2 to H.8	1.51	0.475 150.0	42U	42.0 0.0	23.000 42.300	19.086 4.331				
	0.96	0.0150		0.0	65.300	0.978			Vel = 1.74	

Final Calculations - Hazen-Williams

Uponor
25A SUMAC - One Head Calculation (H.16)

Page 6
Date 3/5/2012

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
	0.0 0.96									
						24.395			K Factor = 0.19	
H.3 to H.11	-1.30 -1.3	0.475 150.0 -0.0262	42U	42.0 0.0 0.0	19.000 42.300 61.300	18.999 0.0 -1.604			Vel = 2.35	
	0.0 -1.30									
						17.395			K Factor = -0.31	
H.7 to H.4	0.40 0.4	0.475 150.0 0.0029	42U	42.0 0.0 0.0	9.000 42.300 51.300	18.968 0.0 0.150			Vel = 0.72	
	0.0 0.40									
						19.118			K Factor = 0.09	
M.22 to T.26	7.81 7.81	0.862 150.0 0.0393	1Utb	6.0 0.0 0.0	17.000 6.000 23.000	19.301 4.331 0.904			Vel = 4.29	
	0.0 7.81									
						24.536			K Factor = 1.58	
M.22 to H.7	-0.83 -0.83	0.475 150.0 -0.0113	1T 21U	1.219 21.0 0.0	7.000 22.369 29.369	19.301 0.0 -0.333			Vel = 1.50	
	0.0 -0.83									
						18.968			K Factor = -0.19	
M.25 to H.5	-0.88 -0.88	0.475 150.0 -0.0127	1T 21U	1.219 21.0 0.0	12.000 22.369 34.369	30.002 0.0 -0.435			Vel = 1.59	
	0.0 -0.88									
						29.567			K Factor = -0.16	
H.9 to H.6	0.84 0.84	0.475 150.0 0.0115	42U	42.0 0.0 0.0	24.000 42.300 66.300	24.431 4.331 0.761			Vel = 1.52	
	0.0 0.84									
						29.523			K Factor = 0.15	
H.8 to H.9	0.18 0.18	0.475 150.0 0.0006	42U	42.0 0.0 0.0	14.000 42.300 56.300	24.395 0.0 0.036			Vel = 0.33	
	0.0 0.18									
						24.431			K Factor = 0.04	
H.6 to H.13	-0.16 -0.16	0.475 150.0 -0.0005	42U	42.0 0.0 0.0	28.000 42.300 70.300	29.523 0.0 -0.038			Vel = 0.29	
	0.0 -0.16									
						29.485			K Factor = -0.03	
H.10 to T.23	1.33 1.33	0.475 150.0 0.0273	21U 1R	21.0 1.0 0.0	7.000 22.150 29.150	17.361 0.0 0.795			Vel = 2.41	
	0.0 1.33									
						18.156			K Factor = 0.31	

Final Calculations - Hazen-Williams

Uponsor
25A SUMAC - One Head Calculation (H.16)

Page 7
Date 3/5/2012

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Fng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
M.22 to H.11	-2.02	0.475 150.0	1T 21U	1.219 21.0	10.000 22.369	19.301 0.0				
	-2.02	-0.0589		0.0	32.369	-1.906			Vel = 3.66	
	0.0									
	-2.02					17.395			K Factor = -0.48	
M.22 to H.12	-1.96	0.475 150.0	1T 21U	1.219 21.0	12.000 22.369	19.301 0.0				
	-1.96	-0.0555		0.0	34.369	-1.907			Vel = 3.55	
	0.0									
	-1.96					17.394			K Factor = -0.47	
M.25 to H.6	-0.90	0.475 150.0	1T 21U	1.219 21.0	14.000 22.369	30.002 0.0				
	-0.9	-0.0132		0.0	36.369	-0.479			Vel = 1.63	
	0.0									
	-0.90					29.523			K Factor = -0.17	
H.13 to H.5	0.27	0.475 150.0	42U	42.0	17.000	29.485				
	0.27	0.0014		0.0	42.300	0.0			Vel = 0.49	
	0.0									
	0.27					29.567			K Factor = 0.05	
H.7 to H.12	-1.49	0.475 150.0	42U	42.0	5.000	18.968				
	-1.49	-0.0333		0.0	42.300	0.0			Vel = 2.70	
	0.0									
	-1.49					47.300			-1.574	
	0.0									
	-1.49					17.394			K Factor = -0.36	
H.8 to T.28	0.34	0.475 150.0	21U 1R	21.0 1.0	5.000 23.150	24.395 0.0				
	0.34	0.0021	1Utr	1.0	28.150	0.060			Vel = 0.62	
	0.0									
	0.34					24.455			K Factor = 0.07	
T.24 to S.1	13.00	1.054 150.0	1T	2.44	16.000	30.027				
	13.0	0.0380		0.0	2.440	1.732			Vel = 4.78	
	0.0									
	13.00					18.440			0.700	
	0.0									
	13.00					32.459			K Factor = 2.28	
H.10 to H.12	0.16	0.475 150.0	42U	42.0	18.000	17.361				
	0.16	0.0005		0.0	42.300	0.0			Vel = 0.29	
	0.0									
	0.16					60.300			0.033	
	0.0									
	0.16					17.394			K Factor = 0.04	
M.25 to T.24	3.37	0.862 150.0	1Utr	2.0	1.000	30.002				
	3.37	0.0083		0.0	2.000	0.0			Vel = 1.85	
	0.0									
	3.37				3.000	0.025				
T.24 to T.26	-13.00	0.862 150.0	1Utb 1Utr	6.0 2.0	12.000 8.000	30.027 -4.331				
	-9.63	-0.0580		0.0	20.000	-1.160			Vel = 5.29	
	0.0									
	-9.63					24.536			K Factor = -1.94	

Final Calculations - Hazen-Williams

Uponsor
25A SUMAC - One Head Calculation (H.16)

Page 8
Date 3/5/2012

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
M.27 to H.8	-0.45 -0.45	0.475 150.0 -0.0037	1T 21U	1.219 21.0 0.0	15.000 22.369 37.369	24.533 0.0 -0.138			Vel = 0.81	
	0.0 -0.45						24.395		K Factor = -0.09	
T.26 to M.27	-1.83 -1.83	0.862 150.0 -0.0030		0.0 0.0 0.0	1.000 0.0 1.000	24.536 0.0 -0.003			Vel = 1.01	
	0.0 -1.83						24.533		K Factor = -0.37	
H.17 to H.10	-1.69 -1.69	0.475 150.0 -0.0421	42U	42.0 0.0 0.0	15.000 42.300 57.300	24.104 -4.331 -2.412			Vel = 3.06	
	0.0 -1.69						17.361		K Factor = -0.41	
H.11 to T.29	-3.31 -3.31	0.475 150.0 -0.1466	21U 1R 1Utr	21.0 1.0 1.0	5.000 23.150 28.150	17.395 0.0 -4.127			Vel = 5.99	
	0.0 -3.31						13.268		K Factor = -0.91	
T.30 to H.10	3.18 3.18	0.475 150.0 0.1363	1R 21U 1Utb	1.0 21.0 2.0	5.000 24.150 29.150	13.387 0.0 3.974			Vel = 5.76	
	0.0 3.18						17.361		K Factor = 0.76	
H.15 to H.5	0.79 0.79	0.475 150.0 0.0104	42U	42.0 0.0 0.0	26.000 42.300 68.300	24.527 4.331 0.709			Vel = 1.43	
	0.0 0.79						29.567		K Factor = 0.15	
H.14 to H.9	-0.36 -0.36	0.475 150.0 -0.0024	42U	42.0 0.0 0.0	14.000 42.300 56.300	24.567 0.0 -0.136			Vel = 0.65	
	0.0 -0.36						24.431		K Factor = -0.07	
M.27 to H.14	0.22 0.22	0.475 150.0 0.0010	1T 21U	1.219 21.0 0.0	13.000 22.369 35.369	24.533 0.0 0.034			Vel = 0.40	
	0.0 0.22						24.567		K Factor = 0.04	
T.28 to H.15	0.34 0.34	0.475 150.0 0.0021	1R 21U	1.0 21.0 0.0	12.000 22.150 34.150	24.455 0.0 0.072			Vel = 0.62	
	0.0 0.34						24.527		K Factor = 0.07	
H.20 to H.5	-0.18 -0.18	0.475 150.0 -0.0006	42U	42.0 0.0 0.0	21.000 42.300 63.300	29.607 0.0 -0.040			Vel = 0.33	

Final Calculations - Hazen-Williams

Uponsor
25A SUMAC - One Head Calculation (H.16)

Page 9
Date 3/5/2012

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftg's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
	0.0 -0.18					29.567			K Factor = -0.03	
M.22 to H.18	-1.68	0.475 150.0	1T 21U	1.219 21.0	23.000 22.369	19.301 0.0			Vel = 3.04	
	-1.68	-0.0420		0.0	45.369	-1.906				
	0.0 -1.68					17.395			K Factor = -0.40	
H.14 to H.13	0.76	0.475 150.0	42U	42.0 0.0	18.000 42.300	24.567 4.331			Vel = 1.38	
	0.76	0.0097		0.0	60.300	0.587				
	0.0 0.76					29.485			K Factor = 0.14	
H.6 to H.19	0.10	0.475 150.0	42U	42.0 0.0	18.000 42.300	29.523 0.0			Vel = 0.18	
	0.1	0.0002		0.0	60.300	0.013				
	0.0 0.10					29.536			K Factor = 0.02	
T.29 to H.16	-3.31	0.475 150.0	1R 21U	1.0 21.0	4.000 24.150	13.268 0.0			Vel = 5.99	
	-3.31	-0.1466	1Utb	2.0	28.150	-4.128				
H.16 to T.30	6.49	0.475 150.0	21U 1R	21.0 1.0	9.000 22.150	9.140 0.0			Vel = 5.76	
	3.18	0.1363		0.0	31.150	4.247				
	0.0 3.18					13.387			K Factor = 0.87	
H.11 to H.18	-0.02	0.475 150.0	42U	42.0 0.0	22.000 42.300	17.395 0.0			Vel = 0.04	
	-0.02	0.0		0.0	64.300	0.0				
	0.0 -0.02					17.395			K Factor = 0	
M.25 to H.20	-0.77	0.475 150.0	1T 21U	1.219 21.0	18.000 22.369	30.002 0.0			Vel = 1.39	
	-0.77	-0.0098		0.0	40.369	-0.395				
	0.0 -0.77					29.607			K Factor = -0.14	
H.14 to H.15	-0.19	0.475 150.0	42U	42.0 0.0	12.000 42.300	24.567 0.0			Vel = 0.34	
	-0.19	-0.0007		0.0	54.300	-0.040				
	0.0 -0.19					24.527			K Factor = -0.04	
M.27 to H.17	-0.77	0.475 150.0	1T 21U	1.219 21.0	21.000 22.369	24.533 0.0			Vel = 1.39	
	-0.77	-0.0099		0.0	43.369	-0.429				
	0.0 -0.77					24.104			K Factor = -0.16	
M.25 to H.19	-0.82	0.475 150.0	1T 21U	1.219 21.0	20.000 22.369	30.002 0.0			Vel = 1.48	
	-0.82	-0.0110		0.0	42.369	-0.466				

Final Calculations - Hazen-Williams

Uponor
25A SUMAC - One Head Calculation (H.16)

Page 10
Date 3/5/2012

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
	0.0 -0.82					29.536			K Factor = -0.15	
H.20 to H.13	-0.34	0.475 150.0	42U	42.0 0.0	15.000 42.300	29.607 0.0			Vel = 0.62	
	-0.34	-0.0021		0.0	57.300	-0.122				
	0.0 -0.34					29.485			K Factor = -0.06	
H.15 to T.31	-0.64	0.475 150.0	21U 1R	21.0 1.0	8.000 23.150	24.527 0.0			Vel = 1.16	
	-0.64	-0.0071	1Utr	1.0	31.150	-0.221				
	0.0 -0.64					24.306			K Factor = -0.13	
M.27 to H.21	-0.82	0.475 150.0	1T 21U	1.219 21.0	17.000 22.369	24.533 0.0			Vel = 1.48	
	-0.82	-0.0110		0.0	39.369	-0.434				
	0.0 -0.82					24.099			K Factor = -0.17	
H.16 to H.18	3.22	0.475 150.0	42U	42.0 0.0	17.000 42.300	9.140 0.0			Vel = 5.83	
	3.22	0.1392		0.0	59.300	8.255				
	0.0 3.22					17.395			K Factor = 0.77	
H.19 to H.20	0.25	0.475 150.0	42U	42.0 0.0	14.000 42.300	29.536 0.0			Vel = 0.45	
	0.25	0.0013		0.0	56.300	0.071				
	0.0 0.25					29.607			K Factor = 0.05	
T.33 to H.17	-0.97	0.475 150.0	1R 21U	1.0 21.0	5.000 23.150	24.533 0.0			Vel = 1.76	
	-0.97	-0.0152	1Utr	1.0	28.150	-0.429				
	0.0 -0.97					24.104			K Factor = -0.20	
H.18 to T.34	1.52	0.475 150.0	21U 1R	21.0 1.0	19.000 23.150	17.395 4.331			Vel = 2.75	
	1.52	0.0347	1Utr	1.0	42.150	1.464				
	0.0 1.52					23.190			K Factor = 0.32	
T.31 to H.21	-0.64	0.475 150.0	1R 21U	1.0 21.0	7.000 22.150	24.306 0.0			Vel = 1.16	
	-0.64	-0.0071		0.0	29.150	-0.207				
	0.0 -0.64					24.099			K Factor = -0.13	
T.32 to H.17	0.06	0.475 150.0	1R 21U	1.0 21.0	10.000 23.150	24.101 0.0			Vel = 0.11	
	0.06	0.0001	1Utr	1.0	33.150	0.003				
	0.0 0.06					24.104			K Factor = 0.01	

Final Calculations - Hazen-Williams

Uponsor
25A SUMAC - One Head Calculation (H.16)

Page 11
Date 3/5/2012


Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
H.21 to T.32	0.06	0.475 150.0	21U 1R	21.0 1.0 0.0	9.000 22.150 31.150	24.099 0.0 0.002			Vel = 0.11	
	0.0 0.06					24.101			K Factor = 0.01	
T.34 to H.21	1.52	0.475 150.0	1R 21U	1.0 21.0 0.0	4.000 22.150 26.150	23.190 0.0 0.909			Vel = 2.75	
	0.0 1.52					24.099			K Factor = 0.31	
H.19 to T.33	-0.97	0.475 150.0	21U 1R	21.0 1.0 2.0	20.000 24.150 44.150	29.536 -4.331 -0.672			Vel = 1.76	
	0.0 -0.97					24.533			K Factor = -0.20	
S.1 to MTR	13.00	0.785 150.0	2E	4.773 0.0 0.0	5.000 4.773 9.773	32.459 6.732 1.557			* Fixed loss = 5 Vel = 8.62	
MTR to STR	0.0	0.911 150.0	1E 1T	1.521 3.801 0.76	40.000 6.082 46.082	40.748 9.000 3.555			* Fixed loss = 9 Vel = 6.40	
	0.0 13.00					53.303			K Factor = 1.78	

Uponor

AQUASAFE® Fire Safety System

Uponor
5925 148th Street West

Apple Valley, MN 55124
800-321-4739



Handwritten signature and date: 3/7.12

Job Name : 25A SUMAC - Two Head Calculation (H.18 & H.12)
Drawing : RESIDENTIAL
Location : 25A SUMAC PORTLAND ME
Remote Area : 1
Contract : 120228-41N
Data File : 120228-41N 25A Sumac.wx2

HYDRAULIC DESIGN INFORMATION SHEET

Name - 25A SUMAC Date - 3/05/12
Location - PORTLAND ME
Building - RESIDENTIAL System No. - 1
Contractor - SPB PLG & HTG Contract No. - 120228-41N
Calculated By - DEVON HUYNH Drawing No. - 1
Construction: (X) Combustible () Non-Combustible Ceiling Height VARIES
OCCUPANCY - RESIDENTIAL

S Type of Calculation: ()NFPA 13 Residential ()NFPA 13R (X)NFPA 13D
Y Number of Sprinklers Flowing: ()1 (X)2 ()4 ()
S ()Other
T ()Specific Ruling Made by Date

E
M Listed Flow at Start Point - 13 Gpm System Type
Listed Pres. at Start Point - 9.14 Psi (X) Wet () Dry
D MAXIMUM LISTED SPACING 16 x 16 () Deluge () PreAction
E Domestic Flow Added - 0 Gpm Sprinkler or Nozzle
S Additional Flow Added - Gpm Make RELIABE-ASSEMBLIES Model AFC43
I Elevation at Highest Outlet - 128 Feet Size 3/8 K-Factor 4.3
G Note: Temperature Rating 155
N

Calculation Gpm Required 26.411 Psi Required 75.53 At Ref Pt STR
Summary C-Factor Used: Overhead 150 Underground 150

W Water Flow Test: Pump Data: Tank or Reservoir:
A Date of Test - x Rated Cap. Cap.
T Time of Test - x @ Psi Elev.
E Static (Psi) - 80 Elev.
R Residual (Psi) - 75 Other Well
Flow (Gpm) - 300 Proof Flow Gpm
S Elevation - 100

P Location: x
P
L Source of Information: CITY SUPPLY
Y

Water Supply Curve (C)

Uponor
25A SUMAC - Two Head Calculation (H.18 & H.12)


Page 2
Date 3/5/2012

City Water Supply:

C1 - Static Pressure : 80
C2 - Residual Pressure: 75
C2 - Residual Flow : 300

Demand:

D1 - Elevation : 12.127
D2 - System Flow : 26.411
D2 - System Pressure : 75.534
Hose (Adj City) : _____
Hose (Demand) : _____
D3 - System Demand : 26.411
Safety Margin : 4.411



Fittings Used Summary

Uponor
25A SUMAC - Two Head Calculation (H.18 & H.12)

Page 3
Date 3/5/2012

Fitting Legend		½	¾	1	1¼	1½	2	2½	3	3½	4	5	6	8	10	12	14	16	18	20	24	
Abbrev.	Name																					
E	90' Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61	
G	Generic Gate Valve	1	1	1	1	1	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13	
R	CPVC Coupling Tee - Run	1	1	1	1	1	1	2	2	0	0	0	0	0	0	0	0	0	0	0	0	
T	90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121	
U	UnAdjusted Fitting	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	
Utb	Aquapex Tee - Branch	2	6	6	9.08	12.88	13.22	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
Utr	Aquapex Tee - Run	1	2	2	1.64	2.39	2.39	0	0	0	0	0	0	0	0	0	0	0	0	0	0	

Units Summary

Diameter Units Inches
Length Units Feet
Flow Units US Gallons per Minute
Pressure Units Pounds per Square Inch

Flow Summary - NFPA 2007

Uponsor
25A SUMAC - Two Head Calculation (H.18 & H.12)

Page 4
Date 3/5/2012

SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
STR	80.0	75	300.0	79.944	26.41	75.534

NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
H.12	128.0	4.3	9.73	13.41	
H.18	128.0	4.3	9.14	13.0	
H.2	128.0		19.77		
H.3	128.0		19.37		
H.4	128.0		19.61		
H.9	118.0		27.51		
M.22	128.0		20.11		
H.1	128.0		19.4		
T.23	128.0		17.82		
H.7	128.0		18.66		
M.25	108.0		36.41		
H.5	108.0		34.8		
H.8	118.0		27.38		
H.6	108.0		34.65		
H.10	128.0		16.16		
H.13	108.0		34.5		
T.24	108.0		36.5		
M.27	118.0		27.84		
T.26	118.0		27.85		
H.17	118.0		26.48		
H.11	128.0		16.19		
T.30	128.0		14.54		
H.15	118.0		27.81		
H.14	118.0		27.98		
T.28	118.0		27.58		
H.20	108.0		34.96		
H.16	128.0		12.81		
T.29	128.0		14.5		
H.19	108.0		34.71		
T.33	118.0		28.0		
T.31	118.0		26.91		
T.32	118.0		26.26		
H.21	118.0		26.06		
T.34	118.0		21.24		
S.1	104.0		40.83		
MTR	100.0		53.34		
STR	100.0		75.53		

Final Calculations - Hazen-Williams

Uponor
25A SUMAC - Two Head Calculation (H.18 & H.12)

Page 5
Date 3/5/2012

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftg's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
H.12 to M.22	4.90 4.9	0.475 150.0 0.3021	1T 21U	1.219 21.0 0.0	12.000 22.369 34.369	9.727 0.0 10.384			K Factor = 4.30 Vel = 8.87	
	0.0 4.90						20.111		K Factor = 1.09	
H.18 to M.22	4.34 4.34	0.475 150.0 0.2418	1T 21U	1.219 21.0 0.0	23.000 22.369 45.369	9.140 0.0 10.971			K Factor = 4.30 Vel = 7.86	
	0.0 4.34						20.111		K Factor = 0.97	
H.2 to H.1	-0.57 -0.57	0.475 150.0 -0.0057	42U	42.0 0.0 0.0	22.000 42.300 64.300	19.771 0.0 -0.367			Vel = 1.03	
	0.0 -0.57						19.404		K Factor = -0.13	
H.3 to H.1	0.17 0.17	0.475 150.0 0.0006	42U	42.0 0.0 0.0	10.000 42.300 52.300	19.374 0.0 0.030			Vel = 0.31	
	0.0 0.17						19.404		K Factor = 0.04	
H.4 to H.1	-0.48 -0.48	0.475 150.0 -0.0041	42U	42.0 0.0 0.0	8.000 42.300 50.300	19.608 0.0 -0.204			Vel = 0.87	
	0.0 -0.48						19.404		K Factor = -0.11	
H.9 to H.4	-2.05 -2.05	0.475 150.0 -0.0602	42U	42.0 0.0 0.0	17.000 42.300 59.300	27.509 -4.331 -3.570			Vel = 3.71	
H.4 to H.3	1.56 -0.49	0.475 150.0 -0.0043	42U	42.0 0.0 0.0	12.000 42.300 54.300	19.608 0.0 -0.234			Vel = 0.89	
	0.0 -0.49						19.374		K Factor = -0.11	
M.22 to H.3	-1.23 -1.23	0.475 150.0 -0.0235	1T 21U	1.219 21.0 0.0	9.000 22.369 31.369	20.111 0.0 -0.737			Vel = 2.23	
	0.0 -1.23						19.374		K Factor = -0.28	
H.1 to H.7	-0.88 -0.88	0.475 150.0 -0.0127	42U	42.0 0.0 0.0	16.000 42.300 58.300	19.404 0.0 -0.740			Vel = 1.59	
	0.0 -0.88						18.664		K Factor = -0.20	
T.23 to H.2	1.99 1.99	0.475 150.0 0.0571	1R 21U 1Utr	1.0 21.0 1.0	11.000 23.150 34.150	17.821 0.0 1.950			Vel = 3.60	
	0.0 1.99						19.771		K Factor = 0.45	

Final Calculations - Hazen-Williams

Uponsor
25A SUMAC - Two Head Calculation (H.18 & H.12)

Page 6
Date 3/5/2012

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
M.22 to H.2	-0.71	0.475 150.0	1T 21U	1.219 21.0	18.000 22.369	20.111 0.0				
	-0.71	-0.0084		0.0	40.369	-0.340			Vel = 1.29	
H.2 to H.8	2.57	0.475 150.0	42U	42.0 0.0	23.000 42.300	19.771 4.331				
	1.86	0.0502		0.0	65.300	3.279			Vel = 3.37	
	0.0									
	1.86					27.381			K Factor = 0.36	
H.3 to H.11	-1.89	0.475 150.0	42U	42.0 0.0	19.000 42.300	19.374 0.0				
	-1.89	-0.0519		0.0	61.300	-3.182			Vel = 3.42	
	0.0									
	-1.89					16.192			K Factor = -0.47	
H.7 to H.4	1.08	0.475 150.0	42U	42.0 0.0	9.000 42.300	18.664 0.0				
	1.08	0.0184		0.0	51.300	0.944			Vel = 1.96	
	0.0									
	1.08					19.608			K Factor = 0.24	
M.22 to T.26	16.00	0.862 150.0	1Utb	6.0 0.0	17.000 6.000	20.111 4.331				
	16.0	0.1483		0.0	23.000	3.410			Vel = 8.80	
	0.0									
	16.00					27.852			K Factor = 3.03	
M.22 to H.7	-1.84	0.475 150.0	1T 21U	1.219 21.0	7.000 22.369	20.111 0.0				
	-1.84	-0.0493		0.0	29.369	-1.447			Vel = 3.33	
	0.0									
	-1.84					18.664			K Factor = -0.43	
M.25 to H.5	-1.79	0.475 150.0	1T 21U	1.219 21.0	12.000 22.369	36.412 0.0				
	-1.79	-0.0468		0.0	34.369	-1.610			Vel = 3.24	
	0.0									
	-1.79					34.802			K Factor = -0.30	
H.9 to H.6	1.70	0.475 150.0	42U	42.0 0.0	24.000 42.300	27.509 4.331				
	1.7	0.0424		0.0	66.300	2.814			Vel = 3.08	
	0.0									
	1.70					34.654			K Factor = 0.29	
H.8 to H.9	0.35	0.475 150.0	42U	42.0 0.0	14.000 42.300	27.381 0.0				
	0.35	0.0023		0.0	56.300	0.128			Vel = 0.63	
	0.0									
	0.35					27.509			K Factor = 0.07	
H.6 to H.13	-0.34	0.475 150.0	42U	42.0 0.0	28.000 42.300	34.654 0.0				
	-0.34	-0.0022		0.0	70.300	-0.152			Vel = 0.62	
	0.0									
	-0.34					34.502			K Factor = -0.06	

Final Calculations - Hazen-Williams

Uponor
25A SUMAC - Two Head Calculation (H.18 & H.12)

Page 7
Date 3/5/2012

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftnng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
H.10 to T.23	1.99	0.475 150.0	21U 1R	21.0 1.0	7.000 22.150	16.157 0.0				
	1.99	0.0571		0.0	29.150	1.664			Vel = 3.60	
	0.0									
	1.99					17.821			K Factor = 0.47	
M.22 to H.11	-2.99	0.475 150.0	1T 21U	1.219 21.0	10.000 22.369	20.111 0.0				
	-2.99	-0.1211		0.0	32.369	-3.919			Vel = 5.41	
	0.0									
	-2.99					16.192			K Factor = -0.74	
M.25 to H.6	-1.82	0.475 150.0	1T 21U	1.219 21.0	14.000 22.369	36.412 0.0				
	-1.82	-0.0483		0.0	36.369	-1.758			Vel = 3.30	
	0.0									
	-1.82					34.654			K Factor = -0.31	
H.13 to H.5	0.54	0.475 150.0	42U	42.0 0.0	17.000 42.300	34.502 0.0				
	0.54	0.0051		0.0	59.300	0.300			Vel = 0.98	
	0.0									
	0.54					34.802			K Factor = 0.09	
H.7 to H.12	-3.80	0.475 150.0	42U	42.0 0.0	5.000 42.300	18.664 0.0				
	-3.8	-0.1889		0.0	47.300	-8.937			Vel = 6.88	
	0.0									
	-3.80					9.727			K Factor = -1.22	
H.8 to T.28	0.64	0.475 150.0	21U 1R	21.0 1.0	5.000 23.150	27.381 0.0				
	0.64	0.0070	1Utr	1.0	28.150	0.196			Vel = 1.16	
	0.0									
	0.64					27.577			K Factor = 0.12	
T.24 to S.1	26.41	1.054 150.0	1T	2.44 0.0	16.000 2.440	36.503 1.732				
	26.41	0.1408		0.0	18.440	2.596			Vel = 9.71	
	0.0									
	26.41					40.831			K Factor = 4.13	
H.10 to H.12	-2.79	0.475 150.0	42U	42.0 0.0	18.000 42.300	16.157 0.0				
	-2.79	-0.1066		0.0	60.300	-6.430			Vel = 5.05	
	0.0									
	-2.79					9.727			K Factor = -0.89	
M.25 to T.24	6.80	0.862 150.0	1Utr	2.0 0.0	1.000 2.000	36.412 0.0				
	6.8	0.0303		0.0	3.000	0.091			Vel = 3.74	
T.24 to T.26	-26.41	0.862 150.0	1Utb 1Utr	6.0 2.0	12.000 8.000	36.503 -4.331				
	-19.61	-0.2160		0.0	20.000	-4.320			Vel = 10.78	
	0.0									
	-19.61					27.852			K Factor = -3.72	

Final Calculations - Hazen-Williams

Uponor
25A SUMAC - Two Head Calculation (H.18 & H.12)

Page 8
Date 3/5/2012

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Fting's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
M.27 to H.8	-0.87	0.475 150.0	1T 21U	1.219 21.0	15.000 22.369	27.842 0.0				
	-0.87	-0.0123		0.0	37.369	-0.461			Vel = 1.58	
	0.0									
	-0.87					27.381			K Factor = -0.17	
T.26 to M.27	-3.61	0.862 150.0		0.0	1.000	27.852				
	-3.61	-0.0100		0.0	0.0	0.0			Vel = 1.98	
	0.0				1.000	-0.010				
	-3.61					27.842			K Factor = -0.68	
H.17 to H.10	-2.76	0.475 150.0	42U	42.0	15.000	26.477				
	-2.76	-0.1045		0.0	42.300	-4.331			Vel = 5.00	
	0.0				57.300	-5.989				
	-2.76					16.157			K Factor = -0.69	
H.11 to T.29	-2.04	0.475 150.0	21U 1R	21.0 1.0	5.000 23.150	16.192 0.0				
	-2.04	-0.0601	1Utr	1.0	28.150	-1.691			Vel = 3.69	
	0.0									
	-2.04					14.501			K Factor = -0.54	
T.30 to H.10	1.96	0.475 150.0	1R 21U	1.0 21.0	5.000 24.150	14.539 0.0				
	1.96	0.0555	1Utb	2.0	29.150	1.618			Vel = 3.55	
	0.0									
	1.96					16.157			K Factor = 0.49	
H.15 to H.5	1.62	0.475 150.0	42U	42.0	26.000	27.814				
	1.62	0.0389		0.0	42.300	4.331			Vel = 2.93	
	0.0				68.300	2.657				
	1.62					34.802			K Factor = 0.27	
H.14 to H.9	-0.70	0.475 150.0	42U	42.0	14.000	27.975				
	-0.7	-0.0083		0.0	42.300	0.0			Vel = 1.27	
	0.0				56.300	-0.466				
	-0.70					27.509			K Factor = -0.13	
M.27 to H.14	0.46	0.475 150.0	1T 21U	1.219 21.0	13.000 22.369	27.842 0.0				
	0.46	0.0038		0.0	35.369	0.133			Vel = 0.83	
	0.0									
	0.46					27.975			K Factor = 0.09	
T.28 to H.15	0.64	0.475 150.0	1R 21U	1.0 21.0	12.000 22.150	27.577 0.0				
	0.64	0.0069		0.0	34.150	0.237			Vel = 1.16	
	0.0									
	0.64					27.814			K Factor = 0.12	
H.20 to H.5	-0.36	0.475 150.0	42U	42.0	21.000	34.959				
	-0.36	-0.0025		0.0	42.300	0.0			Vel = 0.65	
	0.0				63.300	-0.157				

Final Calculations - Hazen-Williams

Uponor
25A SUMAC - Two Head Calculation (H.18 & H.12)

Page 9
Date 3/5/2012

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftg's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
	0.0 -0.36					34.802			K Factor = -0.06	
H.16 to H.12	-1.93	0.475 150.0	42U	42.0 0.0	15.000 42.300	12.810 0.0			Vel = 3.49	
	0.0 -1.93					9.727			K Factor = -0.62	
H.14 to H.13	1.56	0.475 150.0	42U	42.0 0.0	18.000 42.300	27.975 4.331			Vel = 2.82	
	0.0 1.56					34.502			K Factor = 0.27	
H.6 to H.19	0.22	0.475 150.0	42U	42.0 0.0	18.000 42.300	34.654 0.0			Vel = 0.40	
	0.0 0.22					34.710			K Factor = 0.04	
T.29 to H.16	-2.04	0.475 150.0	1R 21U	1.0 21.0	4.000 24.150	14.501 0.0			Vel = 3.69	
H.16 to T.30	-2.04	-0.0601	1Utb	2.0	28.150	-1.691			Vel = 3.55	
	4.00	0.475 150.0	21U 1R	21.0 1.0	9.000 22.150	12.810 0.0			Vel = 3.55	
	1.96	0.0555		0.0	31.150	1.729			Vel = 3.55	
	0.0 1.96					14.539			K Factor = 0.51	
H.11 to H.18	-2.83	0.475 150.0	42U	42.0 0.0	22.000 42.300	16.192 0.0			Vel = 5.12	
	-2.83	-0.1097		0.0	64.300	-7.052			Vel = 5.12	
	0.0 -2.83					9.140			K Factor = -0.94	
M.25 to H.20	-1.55	0.475 150.0	1T 21U	1.219 21.0	18.000 22.369	36.412 0.0			Vel = 2.81	
	-1.55	-0.0360		0.0	40.369	-1.453			Vel = 2.81	
	0.0 -1.55					34.959			K Factor = -0.26	
H.14 to H.15	-0.40	0.475 150.0	42U	42.0 0.0	12.000 42.300	27.975 0.0			Vel = 0.72	
	-0.4	-0.0030		0.0	54.300	-0.161			Vel = 0.72	
	0.0 -0.40					27.814			K Factor = -0.08	
M.27 to H.17	-1.44	0.475 150.0	1T 21U	1.219 21.0	21.000 22.369	27.842 0.0			Vel = 2.61	
	-1.44	-0.0315		0.0	43.369	-1.365			Vel = 2.61	
	0.0 -1.44					26.477			K Factor = -0.28	
M.25 to H.19	-1.64	0.475 150.0	1T 21U	1.219 21.0	20.000 22.369	36.412 0.0			Vel = 2.97	
	-1.64	-0.0402		0.0	42.369	-1.702			Vel = 2.97	

Final Calculations - Hazen-Williams

Uponsor
25A SUMAC - Two Head Calculation (H.18 & H.12)

Page 10
Date 3/5/2012

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
	0.0 -1.64									
H.20 to H.13	-0.69	0.475 150.0	42U	42.0 0.0	15.000 42.300	34.710 0.0			K Factor = -0.28	
	-0.69	-0.0080		0.0	57.300	-0.457			Vel = 1.25	
	0.0 -0.69									
H.15 to T.31	-1.38	0.475 150.0	21U 1R	21.0 1.0	8.000 23.150	27.814 0.0			K Factor = -0.12	
	-1.38	-0.0291	1Utr	1.0	31.150	-0.905			Vel = 2.50	
	0.0 -1.38									
M.27 to H.21	-1.75	0.475 150.0	1T 21U	1.219 21.0	17.000 22.369	27.842 0.0			K Factor = -0.27	
	-1.75	-0.0452		0.0	39.369	-1.781			Vel = 3.17	
	0.0 -1.75									
H.16 to H.18	-2.08	0.475 150.0	42U	42.0 0.0	17.000 42.300	12.810 0.0			K Factor = -0.34	
	-2.08	-0.0619		0.0	59.300	-3.670			Vel = 3.77	
	0.0 -2.08									
H.19 to H.20	0.50	0.475 150.0	42U	42.0 0.0	14.000 42.300	34.710 0.0			K Factor = -0.69	
	0.5	0.0044		0.0	56.300	0.249			Vel = 0.91	
	0.0 0.50									
T.33 to H.17	-1.93	0.475 150.0	1R 21U	1.0 21.0	5.000 23.150	27.996 0.0			K Factor = 0.08	
	-1.93	-0.0540	1Utr	1.0	28.150	-1.519			Vel = 3.49	
	0.0 -1.93									
H.18 to T.34	3.75	0.475 150.0	21U 1R	21.0 1.0	19.000 23.150	9.140 4.331			K Factor = -0.38	
	3.75	0.1843	1Utr	1.0	42.150	7.770			Vel = 6.79	
	0.0 3.75									
T.31 to H.21	-1.38	0.475 150.0	1R 21U	1.0 21.0	7.000 22.150	26.909 0.0			K Factor = 0.81	
	-1.38	-0.0291		0.0	29.150	-0.848			Vel = 2.50	
	0.0 -1.38									
T.32 to H.17	0.61	0.475 150.0	1R 21U	1.0 21.0	10.000 23.150	26.263 0.0			K Factor = -0.27	
	0.61	0.0065	1Utr	1.0	33.150	0.214			Vel = 1.10	
	0.0 0.61									
									K Factor = 0.12	

Final Calculations - Hazen-Williams

Uponsor
25A SUMAC - Two Head Calculation (H.18 & H.12)

Page 11
Date 3/5/2012

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
H.21 to T.32	0.61 0.61	0.475 150.0 0.0065	21U 1R	21.0 1.0 0.0	9.000 22.150 31.150	26.061 0.0 0.202				
	0.0 0.61					26.263			Vel = 1.10	
T.34 to H.21	3.75 3.75	0.475 150.0 0.1843	1R 21U	1.0 21.0 0.0	4.000 22.150 26.150	21.241 0.0 4.820				
	0.0 3.75					26.061			K Factor = 0.12	
H.19 to T.33	-1.93 -1.93	0.475 150.0 -0.0540	21U 1R 1Utb	21.0 1.0 2.0	20.000 24.150 44.150	34.710 -4.331 -2.383				
	0.0 -1.93					27.996			Vel = 6.79	
									K Factor = 0.73	
S.1 to MTR	26.41 26.41	0.785 150.0 0.5911	2E	4.773 0.0 0.0	5.000 4.773 9.773	40.831 6.732 5.777				
									* Fixed loss = 5	
MTR to STR	0.0 26.41	0.911 150.0 0.2863	1E 1T 1G	1.521 3.801 0.76	40.000 6.082 46.082	53.340 9.000 13.194				
	0.0 26.41					75.534			Vel = 17.51	
									* Fixed loss = 9	
									Vel = 13.00	
									K Factor = 3.04	