

378-A-002

Angus S. King
Governor



Maine Department of Public Safety
State Fire Marshal's Office
164 State House Station
Augusta, Maine 04333-0164



Michael F. Kelly
Commissioner
Chief John C. Dean
State Fire Marshal
Fax 207-624-8767

Phone 207-624-8744

Statement of Deficiencies and Plan of Corrections

Facility Name: Melissa Mirachi Location: 106 Summit Street Portland, ME 04103 Facility Type CBH Telephone : 207-878-0905 Resource ID : 381981 (FILE#: 63350)	Owner Name: Melissa Mirachi Address: Same Same <div style="text-align: right; font-family: cursive; font-size: 2em;">area 2</div>
---	--

<p>During an inspection of your facility a certified State Inspector has found the following violations.</p>	<p>In this right hand column you are required to indicate how and when you will have these violations corrected. Complete this information and return this "Plan of Correction" to the above address within 10 days of receipt of this statement.</p>
--	---

- dc10** All floor levels of residence must have a smoke detector that is powered by the house electrical supply. This also includes the basement or usable crawl space. (NFPA 72)

WR:led

(PENDING)

~~cc: Portland Fire Department~~

cc: DHS

Date of Inspection: January 5, 2000

Inspector: William Romano

Date Sent : 3 April, 2000

Owner/Occupant Signature

Date: