



Permitting and Inspections <buildinginspections@portlandmaine.gov>

Fast Track-After the Fact Basement Permit-245 Auburn St.

Dore, Joshua P <Joshua.Dore@gdbiw.com>

Mon, Dec 11, 2017 at 8:37 AM

To: Permitting and Inspections <buildinginspections@portlandmaine.gov>

Good Morning Tori,

Here is some more information I have acquired for you:

The dry wall is 5/8" rated at 1 hour (Fire Rating).

The ceiling is sheetrock, 5/8" rated at one hour (Fire Rating).

Framing is 2x4, 12-16" spacing.

The windows are 15"x31".

Attached you will find the original floor plan drawing.

Hopefully I got everything, let me know if you need anything else.

V/R,

Joshua Dore

CDM Analyst

Bath Iron Works / General Dynamics Corp.

700 Washington Street

Bath, Maine 04530

[Phone] (207) 442-1135 [FAX] (207) 442-1912

[E-Mail] Joshua.Dore@gdbiw.com

[CDM E-Mail] CDM@gdbiw.com

THIS MESSAGE IS INTENDED ONLY FOR USE BY THE INDIVIDUAL(S) TO WHOM ADDRESSED AND MAY CONTAIN INFORMATION THAT IS GENERAL DYNAMICS PRIVATE INFORMATION THAT IS PRIVILEGED AND EXEMPT FROM DISCLOSURE UNDER APPLICABLE LAW. IF YOU ARE NOT AN INTENDED RECIPIENT, YOU ARE HEREBY NOTIFIED THAT ANY REVIEW, USE, DISSEMINATION, DISTRIBUTION OR COPYING IS STRICTLY PROHIBITED. YOU ARE ASKED TO DISREGARD AND DELETE THIS MESSAGE WITH ANY ATTACHMENTS AND DESTROY ALL COPIES IN ANY FORM. THANK YOU IN ADVANCE FOR YOUR COOPERATION.

THIS CORRESPONDENCE IS CONSIDERED TO BE WITHIN THE SCOPE OF EXISTING CONTRACT WITH BIW AND NO CHANGE IN THE PRICE, TERMS OR SCHEDULE OF THE CONTRACT(S) ARE AUTHORIZED. IF THE PARTY ASSIGNED ACTION CONSIDERS A COST OR SCHEDULE IMPACT WILL RESULT, THEY SHOULD PROMPTLY, AND IN ANY EVENT WITHIN TWENTY (20) CALENDAR DAYS, NOTIFY THE BUYER IN WRITING WITH A ROUGH ORDER OF MAGNITUDE ESTIMATE OF THE IMPACT AND AWAIT WRITTEN AUTHORIZATION PRIOR TO PROCEEDING.

From: Permitting and Inspections [mailto:buildinginspections@portlandmaine.gov]

Sent: Thursday, December 07, 2017 3:03 PM

[Quoted text hidden]

[Quoted text hidden]

 **Original Floor Plan.pdf**
84K