

382 - B-016
Inspection Services
Samuel P. Hoffses
Chief



Planning and Urban Development
Joseph E. Gray Jr.
Director

CITY OF PORTLAND

September 23, 1991

Mrs. Jennifer Major
31 Clayton St
Portland, ME 04103


Re: 31 Clayton St

Dear Mrs. Major:

Your application to extend existing deck 3' and enclose has been reviewed and a permit cannot be issued because a 25' rear yard setback is required, and your plan shows only 21'.

If you have any questions regarding these requirements, please do not hesitate to contact this office.

Sincerely,



P. Samuel Hoffses
Chief of Inspection Services

cc: William Giroux, Zoning Administrator