Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 07/18/16

ROOF FRAMING 1/4"=1'

NOTE

ALL RAFTERS
2"x12"-16 OC
WITH HURRICANE CLIPS
AND RIDGE STRAPS
SPRUCE

SEC. BB