

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that
DIPIETRO DAVID D

Located at
8 LAMBERT ST

PERMIT ID: 2017-00359 ISSUE DATE: 06/20/2017 CBL: 384 A006001

has permission to **Change of Use - Add an accessory dwelling unit to single-family home**
provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 hour notice is required.

A final inspection must be completed before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Greg Gilbert

/s/ Greg Gilbert

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

Building Inspections

Fire Department

Use Group:

Type:

Classification:

Single Family Residence w/ accessory unit

ENTIRE

ENTIRE

Mubec / 2009 IRC

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703
or email: buildinginspections@portlandmaine.gov

**Check the Status of Permit or Schedule an Inspection at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the City of Portland Inspections Division for the inspections listed below. Appointments must be requested 48 to 72 hours in advance. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that are attached to this permit.**
- **Permits expire in 6 months if the project is not started or ceases for 6 months.**
- **If the inspection requirements below are not followed, then additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC), one set of printed approved stamped construction documents will be kept at the site of work and open to inspection by building officials.**

REQUIRED INSPECTIONS:

Plumbing Only

Final Inspection

The project cannot move to the next phase prior to the required inspection and approval to continue.

If the permit requires a certificate of occupancy, it must be paid and issued to the owner or designee before the space may be occupied.

City of Portland, Maine - Building or Use Permit		Permit No: 2017-00359	Date Applied For: 03/20/2017	CBL: 384 A006001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Accessory Dwelling Unit	Proposed Project Description: Change of Use - Add an accessory dwelling unit to single-family home			
Dept: Zoning Status: Approved w/Conditions Reviewer: Ann Machado Approval Date: 03/30/2017 Note: R-2 & R-3 Zones Ok to Issue: <input checked="" type="checkbox"/> - The ZBA granted a Conditional Use appeal application on March 2, 2017.				
Conditions:				
1) As a conditional use, all conditions listed under sections 14-78(a)(2) and 14-88(a)(2) must be maintained as long as the accessory dwelling unit remains. 2) With the issuance of this permit and the certificate of occupancy, this property shall remain a single family dwelling with an accessory dwelling unit. Any change of use shall require a separate permit application for review and approval. 3) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.				
Dept: Building Inspecti Status: Approved w/Conditions Reviewer: Greg Gilbert Approval Date: 06/20/2017 Note: Ok to Issue: <input checked="" type="checkbox"/>				
Conditions:				
2) Separate permits are required for any electrical: plumbing, sprinkler, fire alarm, HVAC systems, commercial hood exhaust systems and fuel tanks. Separate plans may need to be submitted for approval as a part of this process. 3) Review and approval by the Authority having Jurisdiction shall not relieve the applicant of the responsibility of compliance with this Code 4) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.				
Dept: Fire Status: Approved w/Conditions Reviewer: Greg Gilbert Approval Date: 06/20/2017 Note: Ok to Issue: <input checked="" type="checkbox"/>				
Conditions:				
1) Smoke Alarms City of Portland Code Chapter 10 section 10-3 (i) all new single-station and or multiple-station smoke alarms shall be non-ionization (photoelectric) type. Smoke Alarms shall be installed per NFPA 101 2009 section 9.6.2.10. Detectors are required to be installed in the following locations <ol style="list-style-type: none"> 1. Inside all sleeping rooms. 2. Outside each separate sleeping area, in the immediate vicinity of the sleeping areas 3. On each level of the dwelling unit, including basements but excluding attics and crawl spaces. Fire extinguishers are required per NFPA 1 (2009 Edition) Table 13.6.2. The quantity, size, type and location shall be in accordance with NFPA 1, 13.6.8.				
2) Carbon Monoxide Detectors City of Portland Code Chapter 10 section 10-3 (L) all residential occupancies, and all new multiple occupancies containing attached parking structures or fuel burning appliances shall be protected in accordance with NFPA 720, Standard for the Installation of Carbon Monoxide (CO) Detection and Warning Equipment, 2009 edition. Detectors shall be provided in the following areas. <ol style="list-style-type: none"> 1. Outside each separate sleeping area, in the immediate vicinity of the sleeping areas 2. On each level of the dwelling unit, including basements but excluding attics and crawl spaces. 				

3) General Conditions

All construction shall comply with City Code, Chapter 10.

All construction shall comply with 2009 NFPA 101 Life Safety Code, Chapter # 43

All construction shall comply with 2009 NFPA 1, Fire Code.

This review and approval by the AHJ shall not relieve the applicant of the responsibility of compliance with this Code. NFPA 1 (section 1.14.4).