

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that
BRAMBLEWOOD LLC

Located at
24 HAVERTYS WAY

PERMIT ID: 2017-00302 **ISSUE DATE:** 03/31/2017 **CBL:** 384 A041001

has permission to **Installation of Mitsubishi Ductless Heat Pump**
provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 hour notice is required.

A final inspection must be completed before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ David Petruccelli

/s/ Greg Gilbert

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning
single-family

Building Inspections
Use Group: Single Family Residence
Type: ENTIRE
MUBEC / 2009 IRC

Fire Department
Classification: One or Two Family Dwellings
ENTIRE

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703
or email: buildinginspections@portlandmaine.gov

**Check the Status of Permit or Schedule an Inspection at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the City of Portland Inspections Division for the inspections listed below. Appointments must be requested 48 to 72 hours in advance. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that are attached to this permit.**
- **Permits expire in 6 months if the project is not started or ceases for 6 months.**
- **If the inspection requirements below are not followed, then additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC), one set of printed approved stamped construction documents will be kept at the site of work and open to inspection by building officials.**

REQUIRED INSPECTIONS:

Electrical - Residential
Final Inspection

The project cannot move to the next phase prior to the required inspection and approval to continue.

If the permit requires a certificate of occupancy, it must be paid and issued to the owner or designee before the space may be occupied.

City of Portland, Maine - Building or Use Permit		Permit No: 2017-00302	Date Applied For: 03/08/2017	CBL: 384 A041001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Single family		Proposed Project Description: Installation of Mitsubishi Ductless Heat Pump		
Dept: Zoning Status: Approved Reviewer: Christina Stacey Approval Date: 03/09/2017		Note: Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:				
Dept: Building Inspecti Status: Approved w/Conditions Reviewer: Greg Gilbert Approval Date: 03/22/2017		Note: Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:				
1) Maintain proper setback(s) from property lines/buildings and proper clearances from vertical openings when direct venting				
2) The installation must comply with UL, the Manufacturers' Listing, MUBEC (IRC, 2009), and State of Maine Gas Regulations.				
3) Separate permits are required for any electrical: plumbing, sprinkler, fire alarm, HVAC systems, commercial hood exhaust systems and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.				
4) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.				
Dept: Fire Status: Approved w/Conditions Reviewer: David Petrucci Approval Date: 03/09/2017		Note: Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:				
1) Installation shall comply with NFPA 211, Standard for Chimneys, Fireplaces, Vents, and Solid Fuel-Burning Appliances; NFPA 31, Standard for the Installation of Oil-Burning Equipment; NFPA 54, National Fuel Gas Code; NFPA 90A, Standard for the Installation of Air-Conditioning and Ventilating Systems; NFPA 91, Standard for Exhaust Systems for Air Conveying Vapors, Gases, Mists, and Noncombustible Particulate Solids; NFPA 70, National Electrical Code; and the manufacturer's published instructions.				
2) Fuel-fired boilers shall be protected in accordance with NFPA 101, Life Safety Code. Boiler and Fuel-fired heater rooms serving more than a single dwelling unit require 1 hour separation and sprinklers.				
3) Installation shall comply with City Code Chapter 10.				