

CONTRACTOR'S MATERIAL & TEST CERTIFICATE FOR ABOVEGROUND PIPING

5301

PROCEDURE

Upon completion of work, inspection and tests shall be made by the contractor's representative and witnessed by an owner's representative. All defects shall be corrected and system left in service before contractor's personnel finally leave the job.

A certificate shall be filled out and signed by both representatives. Copies shall be prepared for approving authorities, owners and contractor. It is understood the owner's representative's signature in no way prejudices any claim against contractor for faulty material, poor workmanship, or failure to comply with approving authority's requirements or local ordinances.

PROPERTY NAME Matt Flaherty Residence DATE _____

PROPERTY ADDRESS Havertys Rd Portland, ME

PLANS

ACCEPTED BY APPROVING AUTHORITY(S) NAMES
State Fire Marshal

ADDRESS
Augusta, ME

INSTALLATION CONFORMS TO ACCEPTED PLANS YES NO
EQUIPMENT USED IS APPROVED YES NO
IF NO, EXPLAIN DEVIATIONS

INSTRUCTIONS

HAS PERSON IN CHARGE OF FIRE EQUIPMENT BEEN INSTRUCTED AS TO LOCATION OF CONTROL VALVES AND CARE AND MAINTENANCE OF THIS NEW EQUIPMENT YES NO
IF NO, EXPLAIN

HAVE COPIES OF APPROPRIATE INSTRUCTIONS AND CARE AND MAINTENANCE CHARTS AND NFPA 13A BEEN LEFT ON PREMISES YES NO
IF NO, EXPLAIN

LOCATION OF SYSTEM

SUPPLIES BLDGS. _____

SPRINKLERS

MAKE	MODEL	YEAR OF MANUFACTURE	ORIFICE SIZE	QUANTITY	TEMPERATURE RATING
<u>TYCO</u>	<u>LFII</u>	<u>2015</u>	<u>1/2"</u>	<u>23</u>	<u>155</u>
<u>RELIABLE</u>	<u>RFS42</u>	<u>2015</u>	<u>1/2"</u>	<u>10</u>	<u>155</u>

PIPE AND FITTINGS

PIPE CONFORMS TO NFPA 13 STANDARD YES NO
FITTINGS CONFORM TO NFPA 13 STANDARD YES NO
IF NO, EXPLAIN

ALARM VALVE OR FLOW INDICATOR

ALARM DEVICE			MAXIMUM TIME TO OPERATE THROUGH TEST PIPE	
TYPE	MAKE	MODEL	MIN.	SEC.
<u>POTTER</u>	<u>USR-3</u>			<u>255sec</u>

DRY PIPE OPERATING TEST

	DRY VALVE			O.O.D.					
	MAKE	MODEL	SERIAL NO.	MAKE	MODEL	SERIAL NO.			
Without O.O.D.	TIME TO TRIP THRU TEST PIPE		WATER PRESSURE	AIR PRESSURE	TRIP POINT AIR PRESSURE	TIME WATER REACHED TEST OUTLET		ALARM OPERATED PROPERLY	
	MIN.	SEC.	PSI	PSI	PSI	MIN.	SEC.	YES	NO
With O.O.D.									

IF NO, EXPLAIN